

# CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

No. : 2014010303743696

## NAME AND ADDRESS OF THE APPLICANT

Schneider Electric South East Asia (HQ) Pte Ltd  
10 Ang Mo Kio Street 65, #02-01/06, Techpoint. Singapore 569059

## NAME AND ADDRESS OF THE MANUFACTURER

P T Schneider Electric MFG Batam  
Batam Industrial park - BLK 4 - Mukakuning - Batam - Indonesia

## NAME AND ADDRESS OF THE FACTORY

P T Schneider Electric MFG Batam  
Batam Industrial park - BLK 4 - Mukakuning - Batam - Indonesia

## NAME, MODEL AND SPECIFICATION

Control Relay

RM22 and RM35 Ui:400V; Ith: 8A; AC-15:Ue/Ie:250V/3A; DC-13:Ue/Ie:24V/2A;  
IP20

## THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB 14048.5-2008

This is to certify that the above mentioned products have met the requirements of implementation rules for compulsory certification(REF NO. CNCA-01C-011:2007).

Date of issue: Jan.19,2015      Date of expiry: Jan.19,2020

Validity of this certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

This certificate can be verified through CNCA's website: [www.cnca.gov.cn](http://www.cnca.gov.cn)



President:


Wang Kejiao



**CHINA QUALITY CERTIFICATION CENTRE**

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China

<http://www.cqc.com.cn>



# 中国国家强制性产品认证证书

证书编号: 2014010303743696

## 委托人名称、地址

Schneider Electric South East Asia (HQ) Pte Ltd  
10 Ang Mo Kio Street 65, #02-01/06, Techpoint, Singapore 569059

## 生产者(制造商)名称、地址

P T Schneider Electric MFG Batam  
Batam Industrial park - BLK 4 - Mukakuning - Batam - Indonesia

## 生产企业名称、地址

P T Schneider Electric MFG Batam  
Batam Industrial park - BLK 4 - Mukakuning - Batam - Indonesia

## 产品名称和系列、规格、型号

### 控制继电器

RM22 and RM35 Ui:400V; Ith: 8A; AC-15:Ue/Ie:250V/3A; DC-13:Ue/Ie:24V/2A;  
IP20; 详细型号解释见附录

## 产品标准和技术要求

GB 14048.5-2008


上述产品符合强制性产品认证实施规则  
CNCA-01C-011:2007的要求, 特发此证。

发证日期: 2015年01月19日

有效期至: 2020年01月19日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

本证书的相关信息可通过国家认监委网站www.cnca.gov.cn查询




主任:

中国质量认证中心

中国·北京·南四环西路188号9区 100070

<http://www.cqc.com.cn>





# 中国国家强制性产品认证证书

附录:

第 1 页 共 2 页

证书编号: 2014010303743696

纸号: 1077974

型号的解释:

RM22	JA	1	2	MU
I	II	III	IV	V

I: Product Range	RM22: Control Relay			
II: Control & Monitoring Function	TG: 3 Phase (Sequence, Lost) TA: 3 Phase (Sequence, Lost, Asymmetrical) TU: 3 Phase (Sequence, Lost, Under-voltage) TR: 3 Phase (Sequence, Lost, Under-voltage, Over-voltage) UA: Single Phase (Under-voltage, Over-voltage, Individual setting) UB: Single Phase (Under-voltage, Over-voltage, Windows setting) JA: Single Phase (Under-current, Over-current, individual setting) LA: Liquid Level (Through Resistive Probe, Adjustable Sensitivity Range) LG: Liquid Level (Through Resistive Probe, Fix Sensitivity Range)			
III: Output	1: 1 contact 2: 2 contacts without adjustable time delay 3: 2 contacts with adjustable time delay			
IV: Input (50/60 Hz)	3 Phase Voltage	Single Phase Voltage	Single Phase Current	Liquid Level
	0: 208V...480V	-	-	-
	1: 200V...240V	50mV...5V	4mA...1A	5kΩ...100kΩ
	2: 220V...240V	1V...100V	-	0.25kΩ...1MΩ
	3: 380V...480V	15V...600V	-	-
	4: -	80V...300V	-	-
V: Power Supply	MR: 24-240 Vdc/Vac			
	MT: 380-415 Vac			
	Blank: same as input			

注: 此附录与证书同时使用时有效。




主任:

## 中国质量认证中心

中国·北京·南四环西路188号9区100070

<http://www.cqc.com.cn>





# 中国国家强制性产品认证证书

附录:

第 2 页 共 2 页


证书编号: 2014010303743696

纸号: 1077974

RM35	JA	3	2	MU
I	II	III	IV	V

I: Product Range	RM35: Control Relay			
II: Control & Monitoring Function	JA: Single Phase (Under-current, Over-current, individual setting)			
III: Output	3: 2 contacts with adjustable time delay			
IV: Input (50/60 Hz)	3 Phase Voltage	Single Phase Voltage	Single Phase Current	Liquid Level
	1: - 2: -	- -	- 0.15A...1.5A	-
V: Power Supply	MR: 24-240 Vdc/Vac	MT: 380-415 Vac	Blank: non	

注: 此附录与证书同时使用时有效。



主任:

## 中国质量认证中心

中国·北京·南四环西路 188 号 9 区 100070

<http://www.cqc.com.cn>

