



# Certificate of Compliance

**Certificate:** 1225765

**Master Contract:** 240515

**Project:** 2234988

**Date Issued:** November 3, 2009

**Issued to:** Telemecanique/Schneider Electric

**Industries SAS**  
**Zone Industrielle No. 3**  
**L'Isle d'Espagnac, 16340**  
**France**  
**Attention: Mr. Christophe Delaitre**

*The products listed below are eligible to bear the CSA Mark shown*



*J.-C. Chow*

**Issued by:** J.-C. Chow

## **PRODUCTS**

**CLASS 3211 03** - INDUSTRIAL CONTROL EQUIPMENT - Motor Controllers - Auxiliary Devices

Limit Switches, Cat. Nos. XCK-N and XCN-R, followed by a four digit number, followed by P20, G11, F12 or P16, may be followed by S1 or Sxx. Contact ratings: A300, R300 when provided with built-in switches; A300, Q300 when provided with contact block type XE2S-P, XE2N-P; B300, R300 when provided with contact block type XE3S-P, XE3N-P. Types 1, 4X indoor use and 12 enclosures.

Limit switches, Cat. Nos. XCN-T and XCN-TR, followed by a four digit number, followed by G11 or P16, may be followed by Sxx. Contact ratings: A300, R300 when provided with built-in switches; A300, Q300 when provided with contact block type XE2N-P. Types 1, 4X indoor use and 12 enclosures.

Notes:

## **APPLICABLE REQUIREMENTS**

CAN/CSA-C22.2 No.14-05 - Industrial Control Equipment

CAN/CSA-C22.2. No. 94-M91 - Special Purpose Enclosures