



Certificate of Compliance

Certificate: 2109506

Master Contract: 240515

Project: 2109506

Date Issued: November 26, 2008

Issued to: Telemecanique/Schneider Electric

Industries SAS
Zone Industrielle No. 3
L'Isle d'Espagnac, 16340
France
Attention: Mr. Christophe Delaitre

The products listed below are eligible to bear the CSA Mark shown



Issued by: J.-C. Chow, Eng.

Authorized by: Helene Vaillancourt, Operations Manager

A handwritten signature in black ink that reads 'Helene Vaillancourt'.

PRODUCTS

CLASS 3211 03 - INDUSTRIAL CONTROL EQUIPMENT - Motor Controllers - Auxiliary Devices

Photoelectric fork sensors, Type XUV followed by R; followed by 03, 06 or 12; followed by a two digit number; followed by P or N; followed by A or B; followed by N; followed by M8 or L with a one or two digit number.

Rating: Class 2 input 12 - 24 Vdc; output solid state PNP/NPN 0.1 A max, general purpose, protected against overload and short-circuit; Type 1, 4/4X indoor and 13 enclosure.

APPLICABLE REQUIREMENTS

CAN/CSA-C22.2 No. 14-05 - Industrial Control Equipment

CAN/CSA-C22.2 No. 94-M91 - Special Purpose Enclosures