

# DEMKO CERTIFICATE

**Certificate No.** D-06546  
**Page** 1/3  
**Date of Issue** 2018-04-26

**Certificate Holder** Schneider Electric Industries SAS  
35 Rue Joseph Monier  
Rueil Malmaison, 92500 France

**Manufacturer** Schneider Electric Sverige AB  
CMS product department  
Eskilstunavägen 7A, 611 65 Nyköping, SWEDEN

**Production site** SP Moulding Poland Sp.zo.o  
Stawiszcz 4, 98-200 Sieradz,  
POPLAND

**Certified Product Model** Junction box  
NVE94950, NVE94958

**Trademark**



**Rated Voltage / Frequency** 400V  
**Rated Current / Power** -  
**Insulation Class** -  
**Degree of protection (IP)** 65  
**Tested acc. to** EN 60670-1:2005/A1:2013, EN 60670-1:2005  
**Test Report No.** 1809585 issued on 2018-04-23  
**Additional**  
**Expire date** 2023-03-12

**Certification Manager**  
Jan-Erik Storgaard

This is to certify that representative sample(s) of the Product described herein ("Certified Product") have been investigated and found in compliance with the Standard(s) indicated on this Certificate, in accordance with the D Mark Requirements. The Designated Certificate holder is entitled to use the d or for cables <DEMKO> for the Certified Product manufactured at the production site(s) identified above, in accordance with the D Mark Service Agreement, including without limitation the D Mark Testing and Certification Services Service Terms. Only those Products bearing the D Mark should be considered as being covered by UL's D Mark Service. This Certificate shall remain valid through the expiration date, unless terminated earlier in accordance with the Service Agreement including without limitation if the Standard identified on this Certificate is amended or withdrawn prior to the expiration date.

**Certification Body** UL International Demko A/S, Borupvang 5A, DK-2750  
Ballerup, Denmark, Tel. +45 44 85 65 65,  
info.dk@ul.com  
www.ul-europe.com



# Appendix DEMKO CERTIFICATE

**Certificate No.** D-06546  
**Page** 2/3  
**Date of Issue** 2018-04-26

External Certification Information:  
1809585 issued on 2018-04-23 by Intertek Semko AB

Additional Information:  
Rated connecting cap: 1,5-2,5mm<sup>2</sup>

Product information:  
Surface mounting boxes of anthracite, white and light grey insulated material with snap-in lid. With membrane inlets for cable diameter 4-14mm and cable anchorage.  
Same construction of the rear part. Only the lids are different.

NVE94950: Schneider Electric lid off anthracite, light grey and white colour.

NVE94958: Elko lid of white and anthracite colour.

---

**Certification Body**

UL International Demko A/S, Borupvang 5A, DK-2750  
Ballerup, Denmark, Tel. +45 44 85 65 65, info.dk@ul.com  
[www.ul-europe.com](http://www.ul-europe.com)



# Appendix DEMKO CERTIFICATE

Certificate No. D-06546  
Page 3/3  
Date of Issue 2018-04-26



---

**Certification Body**

UL International Demko A/S, Borupvang 5A, DK-2750  
Ballerup, Denmark, Tel. +45 44 85 65 65, info.dk@ul.com  
www.ul-europe.com

