



America


CERTIFICATE

No. U8 15 07 60807 006

Holder of Certificate: AMERICAN POWER CONVERSION HOLDINGS INC.
 ,TAIWAN BRANCH
 3F., NO. 205, SEC 3, BEIXIN RD.,
 XINDIAN DIST.,
 231 NEW TAIPEI CITY
 TAIWAN

Production Facility(ies): 81121

Certification Mark:



C US

Product: Uninterruptable power supply

Model(s): BX600YYYY, BX800YYYY, BX1000YYYY
 (Y can be 0 to 9, A to Z, a to z, "-", "_"
 or blank for marketing purpose)

Parameters:

Rating :	BX600YYYY:
	Input: 120VAC, 60Hz, 5A, 1Ø
	Output: 120VAC, 60Hz, 5A, 600VA/300W, 1Ø
	BX800YYYY:
	Input: 120VAC, 60Hz, 6.6A, 1Ø
	Output: 120VAC, 60Hz, 6.6A, 800VA/400W, 1Ø
	BX1000YYYY:
	Input: 120VAC, 60Hz, 8.3A, 1Ø
	Output: 120VAC, 60Hz, 8.3A, 1000VA/600W, 1Ø
Protection Class :	I
Degree of Protection :	IP20

Tested according to: UL1778:2014
 CSA C22.2 No.107.3-14/ R:2014

The product was voluntarily tested according to the relevant safety requirements noted above. It can be marked with the certification mark above. The mark must not be altered in anyway. This product certification system operated by TÜV SÜD America Inc. most closely resembles system 3 as defined in ISO/IEC Guide 67. Certification is based on the TÜV SÜD "Testing and Certification Regulations". TÜV SÜD America Inc. is an OSHA recognized NRTL and a Standards Council of Canada accredited certification body.

Test report no.: 682101513401

Date, 2015-07-21

Page 1 of 1

