



中国国家强制性产品认证证书

证书编号: 2009010301361231

委托人名称、地址

施耐德(广州)母线有限公司
广州经济技术开发区东区骏业路85号

生产者(制造商)名称、地址

施耐德(广州)母线有限公司
广州经济技术开发区东区骏业路85号

生产企业名称、地址

施耐德(广州)母线有限公司
广州经济技术开发区东区骏业路85号

产品名称和系列、规格、型号

母线槽

Canalis KSC50ED430 母线干线单元: In=500A, Icw=25kA;
Ue=690V, Ui=690V; 50Hz; IP54

产品标准和技术要求

GB 7251.2-2006

上述产品符合强制性产品认证实施规则
CNCA-C03-01: 2014的要求, 特发此证。

发证日期: 2014年12月10日

有效期至: 2019年12月10日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

本证书为变更证书, 证书首次颁发日期: 2009年08月26日

本证书的相关信息可通过国家认监委网站www.cnca.gov.cn查询



主任:

中国质量认证中心

中国·北京·南四环西路188号9区 100070

<http://www.cqc.com.cn>



Q 1043987



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

No. : 2009010301361231

NAME AND ADDRESS OF THE APPLICANT

Schneider Busway (Guangzhou) Co., Ltd.
No.85 Jun Ye Road, Eastern Section of Guangzhou Economic & Technological
Development Zone

NAME AND ADDRESS OF THE MANUFACTURER

Schneider Busway (Guangzhou) Co., Ltd.
No.85 Jun Ye Road, Eastern Section of Guangzhou Economic & Technological
Development Zone

NAME AND ADDRESS OF THE FACTORY

Schneider Busway (Guangzhou) Co., Ltd.
No.85 Jun Ye Road, Eastern Section of Guangzhou Economic & Technological
Development Zone

NAME, MODEL AND SPECIFICATION

Busways

Canalis KSC50ED430 母线干线单元:In=500A, Icw=25kA;
Ue=690V, Ui=690V;50Hz;IP54

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB 7251.2-2006

This is to certify that the above mentioned products have met the requirements of implementation rules for compulsory certification(REF NO. CNCA-C03-01:2014).

Date of issue: Dec.10,2014 Date of expiry: Dec.10,2019

Validity of this certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

Date of original certification: Aug.26,2009

This certificate can be verified through CNCA's website: www.cnca.gov.cn



President:

Wang Kejiao



CHINA QUALITY CERTIFICATION CENTRE

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China

<http://www.cqc.com.cn>

Q 1043987