

## CE Declaration of Conformity

### AccuSine SWP 20 – 120 A

We, Schneider Electric IT France SAS, Inovallée 140 avenue Jean Kuntzmann, Zirst-Montbonnot Saint Martin, 38334 Saint-Ismier Cedex, FRANCE, hereby declare that the product(s) listed below, subject to installation, maintenance and use conforming to its (their) intended purpose, to the applicable regulations and standards, to the supplier's instructions and to the accepted rules of the art, is (are) in conformity with the provisions of the following EC directive(s):

- Low Voltage Directive 2006/95/EC
- EMC Directive 2004/108/EC

and that standards and/or technical specifications referenced overleaf have been applied.

1st apposition of CE marking: August 2012.

Montbonnot, July 11th 2012  
Name: Alain Vidron



Function: IT 3 Phase UPS - R&D Director

The signatories act on behalf of the company management with full power of attorney.

#### Harmonized Standards

References of standards applied for this declaration of conformity, or parts thereof:

- EN 60950-1: 2006, EN 60950-1:2006/A1: 2010  
Information Technology Equipment – Safety – General requirements
- EN 61000-6-2: 2005 Generic standards – Immunity for industrial environments
- EN 61000-6-4: 2007 Generic standards – Emission for industrial environments

## Products description

- Active harmonic filter.

<b>Current rating</b>	<b>Product references</b>	
<b>Model</b>	<b>Single</b>	<b>Parallel</b>
<b>20 A</b>	PCS020Y4IP20U	PCS020Y4IP20P
<b>30 A</b>	PCS030Y4IP20U	PCS030Y4IP20P
<b>45 A</b>	PCS045Y4IP20U	PCS045Y4IP20P
<b>60 A</b>	PCS060Y4IP20U	PCS060Y4IP20P
<b>90 A</b>	PCS090Y4IP20U	PCS090Y4IP20P
<b>120 A</b>	PCS120Y4IP20U	PCS120Y4IP20P

These references may be preceded and/or followed by additional alphanumeric characters in other documents.

This declaration shall cease to be valid if modifications are made to the equipment without our approval.