

Schneider Electric Security Notification

Embedded Web Server for Modicon X80 BMXNOR0200H RTU Module (V2.0)

8 June 2021 (10 August 2021)

Overview

Schneider Electric is aware of a vulnerability in its Modicon X80 BMXNOR0200H RTU product commonly used in conjunction with the M340 PLC family.

The [Modicon X80 BMXNOR0200H](#) product brings Remote Terminal Unit (RTU) functionality to the Modicon Mx80 PAC platform. The RTU system provides an extensive set of control and communications features including industry and telemetry standard protocols.

Failure to apply the mitigations provided below may result in information disclosure to an unauthenticated remote user, which could result in an understanding of the network architecture. No direct impact on the control process occurs if this vulnerability is exploited.

August 2021 Update: Remediation now available.

Affected Product and Versions

Modicon X80 BMXNOR0200H RTU SV1.70 IR22 and prior

Vulnerability Details

CVE ID: **CVE-2021-22749**

CVSS v3.1 Base Score 5.3 | Medium | CVSS:3.1/AV:N/AC:L/PR:N/UI:N/S:U/C:L/I:N/A:N

A *CWE-200: Exposure of Sensitive Information to an Unauthorized Actor* vulnerability exists that could cause information leak concerning the current RTU configuration including communication parameters dedicated to telemetry, when a specially crafted HTTP request is sent to the web server of the module.

Remediation

V1.70 IR 23 of the Modicon X80 BMXNOR0200H RTU product includes a fix for this vulnerability and is available for download here:

https://www.se.com/ww/en/download/document/BMXNOR0200H_FW/

Customers should use appropriate patching methodologies when applying these patches to their systems. We strongly recommend the use of back-ups and evaluating the impact of these patches in a Test and Development environment or on an offline infrastructure. Contact Schneider Electric's Customer Care Center if you need assistance removing a patch.

Schneider Electric Security Notification

If customers choose not to apply the remediation provided above, they should immediately apply the following mitigations to reduce the risk of exploit:

- Web access service is disabled by default. Because the Web server is only necessary for specific maintenance and configuration activities, we advise to disable the web (HTTP) service when the service is not needed through the Ecostruxure Control Expert application
- Set up network segmentation and implement a firewall to block all unauthorized access to HTTP port 80/TCP on the controllers
- When used in an architecture including a BMXNOC module, configure the Access Control Lists following the recommendation in [the Modicon Controllers Platform Cyber Security Reference Manual](#).
- Setup a VPN between the Modicon PLC impacted modules and the engineering workstation containing EcoStruxure Control Expert.

Additional recommended best practice:

- Change the default password used to access the device web server. Update username and password for HTTP access rights with the “Security” link on the Setup page. See the [Modicon X80 BMXNOR0200H RTU Module User Manual](#).

To ensure you are informed of all updates, including details on affected products and remediation plans, subscribe to Schneider Electric’s security notification service here:

<https://www.se.com/en/work/support/cybersecurity/security-notifications.jsp>

General Security Recommendations

We strongly recommend the following industry cybersecurity best practices.

- Locate control and safety system networks and remote devices behind firewalls and isolate them from the business network.
- Install physical controls so no unauthorized personnel can access your industrial control and safety systems, components, peripheral equipment, and networks.
- Place all controllers in locked cabinets and never leave them in the “Program” mode.
- Never connect programming software to any network other than the network for the devices that it is intended for.
- Scan all methods of mobile data exchange with the isolated network such as CDs, USB drives, etc. before use in the terminals or any node connected to these networks.
- Never allow mobile devices that have connected to any other network besides the intended network to connect to the safety or control networks without proper sanitation.
- Minimize network exposure for all control system devices and systems and ensure that they are not accessible from the Internet.
- When remote access is required, use secure methods, such as Virtual Private Networks (VPNs). Recognize that VPNs may have vulnerabilities and should be updated to the

Schneider Electric Security Notification

most current version available. Also, understand that VPNs are only as secure as the connected devices.

For more information refer to the Schneider Electric [Recommended Cybersecurity Best Practices](#) document.

Acknowledgements

Schneider Electric recognizes the following researcher for identifying and helping to coordinate a response to this vulnerability:

| CVE | Researcher |
|----------------|--|
| CVE-2021-22749 | Chizuru Toyama (TXOne IoT/ICS Security Research Labs of Trend Micro) |

For More Information

This document provides an overview of the identified vulnerability or vulnerabilities and actions required to mitigate. For more details and assistance on how to protect your installation, contact your local Schneider Electric representative or Schneider Electric Industrial Cybersecurity Services: <https://www.se.com/ww/en/work/solutions/cybersecurity/>. These organizations will be fully aware of this situation and can support you through the process.

For further information related to cybersecurity in Schneider Electric's products, visit the company's cybersecurity support portal page:

<https://www.se.com/ww/en/work/support/cybersecurity/overview.jsp>

LEGAL DISCLAIMER

THIS NOTIFICATION DOCUMENT, THE INFORMATION CONTAINED HEREIN, AND ANY MATERIALS LINKED FROM IT (COLLECTIVELY, THIS "NOTIFICATION") ARE INTENDED TO HELP PROVIDE AN OVERVIEW OF THE IDENTIFIED SITUATION AND SUGGESTED MITIGATION ACTIONS, REMEDIATION, FIX, AND/OR GENERAL SECURITY RECOMMENDATIONS AND IS PROVIDED ON AN "AS-IS" BASIS WITHOUT WARRANTY OR GUARANTEE OF ANY KIND. SCHNEIDER ELECTRIC DISCLAIMS ALL WARRANTIES RELATING TO THIS NOTIFICATION, EITHER EXPRESS OR IMPLIED, INCLUDING WARRANTIES OF MERCHANTABILITY OR FITNESS FOR A PARTICULAR PURPOSE. SCHNEIDER ELECTRIC MAKES NO WARRANTY THAT THE NOTIFICATION WILL RESOLVE THE IDENTIFIED SITUATION. IN NO EVENT SHALL SCHNEIDER ELECTRIC BE LIABLE FOR ANY DAMAGES OR LOSSES WHATSOEVER IN CONNECTION WITH THIS NOTIFICATION, INCLUDING DIRECT, INDIRECT, INCIDENTAL, CONSEQUENTIAL, LOSS OF BUSINESS PROFITS OR SPECIAL DAMAGES, EVEN IF SCHNEIDER ELECTRIC HAS BEEN ADVISED OF THE POSSIBILITY OF SUCH DAMAGES. YOUR USE OF THIS NOTIFICATION IS AT YOUR OWN RISK, AND YOU ARE SOLELY LIABLE FOR ANY DAMAGES TO YOUR SYSTEMS OR ASSETS OR OTHER LOSSES THAT MAY RESULT FROM YOUR USE OF THIS NOTIFICATION. SCHNEIDER ELECTRIC RESERVES THE RIGHT TO UPDATE OR CHANGE THIS NOTIFICATION AT ANY TIME AND IN ITS SOLE DISCRETION

Schneider Electric Security Notification

About Schneider Electric

At Schneider, we believe **access to energy and digital** is a basic human right. We empower all to **do more with less**, ensuring **Life Is On** everywhere, for everyone, at every moment.

We provide **energy and automation digital** solutions for **efficiency and sustainability**. We combine world-leading energy technologies, real-time automation, software and services into integrated solutions for Homes, Buildings, Data Centers, Infrastructure and Industries.

We are committed to unleash the infinite possibilities of an **open, global, innovative community** that is passionate with our **Meaningful Purpose, Inclusive and Empowered** values.

www.se.com

Revision Control:

| | |
|--|-----------------------|
| Version 1.0 <i>8 Jun 2021</i> | Original Release |
| Version 2.0 <i>10 Aug 2021</i> | Remediation available |