

Schneider Electric Security Notification

NTZ Mekhanotronika Rus. LLC SHAIIS-MT-111, SHASU-MT-107 and SHFK-MT, and SHFK-MT-104 Control Panels

10 August 2021

Overview

Schneider Electric is aware of the Microsoft Windows print spooler remote code execution vulnerabilities in its [NTZ Mekhanotronika Rus. LLC control panels](#).

NTZ Mekhanotronika Rus. LLC offers that contain Microsoft Windows operating system as part of the products could be affected by the vulnerabilities listed below. Failure to apply the remediations provided below may risk an attacker being able to take control of the system through the exploitation of the vulnerabilities.

Affected Products and Versions

| Affected Product | Serial Number | Microsoft Windows® version |
|----------------------------------|----------------------|---|
| SHAIIS-MT-111 DIVG.424327.111-02 | 2847 | MICROSOFT WIN 7 |
| SHAIIS-MT-111 DIVG.424327.111-04 | 2522 | MICROSOFT WIN 7 |
| SHAIIS-MT-111 DIVG.424327.111-06 | 2558 | MICROSOFT WIN 7 |
| SHAIIS-MT-111 DIVG.424327.111-08 | 2559 | MICROSOFT WIN 7 |
| SHAIIS-MT-111 DIVG.424327.111-11 | 2704 | MICROSOFT WIN 7 |
| SHAIIS-MT-111 DIVG.424327.111-12 | 2825 2828 2831 | MICROSOFT WIN 7 |
| SHAIIS-MT-111 DIVG.424327.111-14 | 2916 | MICROSOFT WIN 7 |
| SHAIIS-MT-111 DIVG.424327.111-16 | 3036 | MICROSOFT WIN 7 |
| SHAIIS-MT-111 DIVG.424327.111-19 | 3113 | MICROSOFT WIN 7 |
| SHAIIS-MT-111 DIVG.424327.111-20 | 3201 | MICROSOFT WIN 7 |
| SHASU-MT-107 DIVG.424327.107-01 | - | MICROSOFT WIN PRO 7 SP1 64Bit, P/N: FQC-04673 |
| SHASU-MT-107 DIVG.424327.107-02 | 2555 | MICROSOFT WIN PRO 7 SP1 64Bit, P/N: FQC-04673 |
| SHASU-MT-107 DIVG.424327.107-08 | 3043 | MICROSOFT WIN PRO 7 SP1 64Bit |
| SHFK-MT DIVG.424327.104-08 | 2686 | MICROSOFT WIN PRO 7 SP1 64Bit, P/N: FQC-04673 |
| SHFK-MT-104 DIVG.424327.104-09 | 2623 | MICROSOFT WIN PRO 7 SP1 64Bit, P/N: FQC-04673 |
| SHFK-MT-104 DIVG.424327.104-10 | 2846 | MICROSOFT WIN PRO 7 SP1 64Bit, P/N: FQC-04673 |

Schneider Electric Security Notification

| | | |
|--|----------------------|---|
| SHFK-MT-104 DIVG.424327.104-14 | 2521 | MICROSOFT WIN PRO 7 SP1 64Bit, P/N: FQC-04673 |
| SHFK-MT-104 DIVG.424327.104-24 | 2712 | MICROSOFT WIN PRO 7 SP1 64Bit, P/N: FQC-04673 |
| SHFK-MT-104 DIVG.424327.104-25 | 2823 2826 2829 | MICROSOFT WIN PRO 7 SP1 64Bit, P/N: FQC-04673 |
| SHFK-MT-104 DIVG.424327.104-27 | 2889 | MICROSOFT WIN PRO 7 SP1 64Bit, P/N: FQC-04673 |
| SHFK-MT-104 DIVG.424327.104-28 | 2915 | MICROSOFT WIN PRO 7 SP1 64Bit, P/N: FQC-04673 |
| SHFK-MT-104 DIVG.424327.104-30 | 3008 | MICROSOFT WIN PRO 7 SP1 64Bit, P/N: FQC-04673 |
| SHFK-MT-104 DIVG.424327.104-32 | 3035 | MICROSOFT WIN PRO 7 SP1 64Bit |
| SHFK-MT-104 DIVG.424327.104-33 | 3080 | MICROSOFT WIN PRO 7 SP1 64Bit |
| SHFK-MT-104 DIVG.424327.104-34 | 3112 | MICROSOFT WIN PRO 7 SP1 64Bit |
| SHFK-MT-104 DIVG.424327.104-35 | 3203 | MICROSOFT WIN 10 PRO, P/N: FQC-08909-D |
| SHFK-MT-104 DIVG.424327.104-36.01 SHFK-MT-104 DIVG.424327.104-36.20 | 3297 - 3316 | MICROSOFT WIN 10 PRO Version 1909, P/N: FQC-08909-D |
| SHFK-MT-104 DIVG.424327.104-36.21 SHFK-MT-104 DIVG.424327.104-36.25 | 3368 - 3372 | MICROSOFT WIN 10 PRO Version 1909, P/N: FQC-08909-D |
| SHFK-MT-104 DIVG.424327.104-36.26 SHFK-MT-104 DIVG.424327.104-36.65 | 3318 - 3357 | MICROSOFT WIN 10 PRO Version 1909, P/N: FQC-08909-D |
| SHFK-MT-104 DIVG.424327.104-36.66 SHFK-MT-104 DIVG.424327.104-36.70 | 3505 - 3509 | MICROSOFT WIN 10 PRO Version 1909, P/N: FQC-08909-D |
| SHFK-MT-104 DIVG.424327.104-36.71 SHFK-MT-104 DIVG.424327.104-36.80 | 3373 - 3382 | MICROSOFT WIN 10 PRO Version 1909, P/N: FQC-08909-D |
| SHFK-MT-104 DIVG.424327.104-36.81 SHFK-MT-104 DIVG.424327.104-37.11 | 3394 - 3423 | MICROSOFT WIN 10 PRO Version 1909, P/N: FQC-08909-D |
| SHFK-MT-104 DIVG.424327.104-37.12 SHFK-MT-104 DIVG.424327.104-37.21 | 3510 - 3519 | MICROSOFT WIN 10 PRO Version 1909, P/N: FQC-08909-D |
| SHFK-MT-104 DIVG.424327.104-37.22 SHFK-MT-104 DIVG.424327.104-37.81 | 3552 - 3611 | MICROSOFT WIN 10 PRO Version 1909, P/N: FQC-08909-D |
| SHFK-MT-104 DIVG.424327.104-37.82 SHFK-MT-104 DIVG.424327.104-38.01 | 3697 - 3715 | MICROSOFT WIN 10 PRO Version 1909, P/N: FQC-08909-D |
| SHFK-MT-104 DIVG.424327.104-38.02 SHFK-MT-104 DIVG.424327.104-38.38 | 3729 - 3765 | MICROSOFT WIN 10 PRO Version 1909, P/N: FQC-08909-D |
| SHFK-MT-104 DIVG.424327.104-38.39 SHFK-MT-104 DIVG.424327.104-38.58 | 3794 - 3813 | MICROSOFT WIN 10 PRO Version 1909, P/N: FQC-08909-D |
| SHFK-MT-104 DIVG.424327.104-38.59 SHFK-MT-104 DIVG.424327.104-38.78 | 3815 - 3834 | MICROSOFT WIN 10 PRO Version 1909, P/N: FQC-08909-D |
| SHFK-MT-104 DIVG.424327.104-38.79 SHFK-MT-104 DIVG.424327.104-39.13 | 3835 - 3867 | MICROSOFT WIN 10 PRO Version 1909, P/N: FQC-08909-D |
| SHFK-MT-104 DIVG.424327.104-40 | 3814 | MICROSOFT WIN 10 PRO, P/N: FQC-08909-D |
| SHFK-MT-104 DIVG.424327.104-41 | 3520 | MICROSOFT WIN 10 PRO, P/N: FQC-08909-D |
| SHFK-MT-104 DIVG.424327.104-43 | 3906 | MICROSOFT WIN 10 PRO, P/N: FQC-08909-D |
| SHFK-MT-104 DIVG.424327.104-45 | 3822 | MICROSOFT WIN 10 PRO Version 1909, P/N: FQC-08909-D |

Schneider Electric Security Notification

Vulnerability Details

CVE ID: **CVE-2021-34527**

CVSS v3.1 Base Score 8.8 | Critical | CVSS:3.1/AV:N/AC:L/PR:L/UI:N/S:U/C:H/I:H/A:H

A remote code execution vulnerability exists when the Windows Print Spooler service improperly performs privileged file operations. An attacker who successfully exploited this vulnerability could run arbitrary code with SYSTEM privileges. An attacker could then install programs; view, change, or delete data; or create new accounts with full user rights.

CVE ID: **CVE-2021-1675**

CVSS v3.1 Base Score 8.8 | Critical | CVSS:3.1/AV:N/AC:L/PR:N/UI:R/S:U/C:H/I:H/A:H

Windows Print Spooler Elevation of Privilege Vulnerability.

Remediation

The Microsoft Windows® operating system updates address the vulnerabilities for all the affected products listed in this notification are available for download here:

- CVE-2021-34527: <https://msrc.microsoft.com/update-guide/en-US/vulnerability/CVE-2021-34527>
- CVE-2021-1675: <https://msrc.microsoft.com/update-guide/en-US/vulnerability/CVE-2021-1675>

A reboot will be needed after the updates are applied.

Customers should use appropriate patching methodologies when applying these patches to their systems. We strongly recommend the use of back-ups and evaluating the impact of these patches in a Test and Development environment or on an offline infrastructure. Contact Schneider Electric's Customer Care Center if you need assistance removing a patch.

If customers choose not to apply the remediation provided above, they should follow the recommendations listed in the General Security Recommendations section below to reduce the risk of exploit.

General Security Recommendations

We strongly recommend the following industry cybersecurity best practices.

- Locate control and safety system networks and remote devices behind firewalls and isolate them from the business network.
- Install physical controls so no unauthorized personnel can access your industrial control and safety systems, components, peripheral equipment, and networks.

Schneider Electric Security Notification

- Place all controllers in locked cabinets and never leave them in the “Program” mode.
- Never connect programming software to any network other than the network for the devices that it is intended for.
- Scan all methods of mobile data exchange with the isolated network such as CDs, USB drives, etc. before use in the terminals or any node connected to these networks.
- Never allow mobile devices that have connected to any other network besides the intended network to connect to the safety or control networks without proper sanitation.
- Minimize network exposure for all control system devices and systems and ensure that they are not accessible from the Internet.
- When remote access is required, use secure methods, such as Virtual Private Networks (VPNs). Recognize that VPNs may have vulnerabilities and should be updated to the most current version available. Also, understand that VPNs are only as secure as the connected devices.

For more information refer to the Schneider Electric [Recommended Cybersecurity Best Practices](#) document.

For More Information

This document provides an overview of the identified vulnerability or vulnerabilities and actions required to mitigate. For more details and assistance on how to protect your installation, contact your local Schneider Electric representative or Schneider Electric Industrial Cybersecurity Services: <https://www.se.com/ww/en/work/solutions/cybersecurity/>. These organizations will be fully aware of this situation and can support you through the process.

For further information related to cybersecurity in Schneider Electric’s products, visit the company’s cybersecurity support portal page:
<https://www.se.com/ww/en/work/support/cybersecurity/overview.jsp>

LEGAL DISCLAIMER

THIS NOTIFICATION DOCUMENT, THE INFORMATION CONTAINED HEREIN, AND ANY MATERIALS LINKED FROM IT (COLLECTIVELY, THIS “NOTIFICATION”) ARE INTENDED TO HELP PROVIDE AN OVERVIEW OF THE IDENTIFIED SITUATION AND SUGGESTED MITIGATION ACTIONS, REMEDIATION, FIX, AND/OR GENERAL SECURITY RECOMMENDATIONS AND IS PROVIDED ON AN “AS-IS” BASIS WITHOUT WARRANTY OR GUARANTEE OF ANY KIND. SCHNEIDER ELECTRIC DISCLAIMS ALL WARRANTIES RELATING TO THIS NOTIFICATION, EITHER EXPRESS OR IMPLIED, INCLUDING WARRANTIES OF MERCHANTABILITY OR FITNESS FOR A PARTICULAR PURPOSE. SCHNEIDER ELECTRIC MAKES NO WARRANTY THAT THE NOTIFICATION WILL RESOLVE THE IDENTIFIED SITUATION. IN NO EVENT SHALL SCHNEIDER ELECTRIC BE LIABLE FOR ANY DAMAGES OR LOSSES WHATSOEVER IN CONNECTION WITH THIS NOTIFICATION, INCLUDING DIRECT, INDIRECT, INCIDENTAL, CONSEQUENTIAL, LOSS OF BUSINESS PROFITS OR SPECIAL DAMAGES, EVEN IF SCHNEIDER ELECTRIC HAS BEEN ADVISED OF THE POSSIBILITY OF SUCH DAMAGES. YOUR USE OF THIS NOTIFICATION IS AT YOUR OWN RISK, AND YOU ARE SOLELY LIABLE FOR ANY DAMAGES TO YOUR SYSTEMS OR ASSETS OR OTHER LOSSES THAT MAY RESULT FROM YOUR USE OF THIS NOTIFICATION. SCHNEIDER ELECTRIC RESERVES THE RIGHT TO UPDATE OR CHANGE THIS NOTIFICATION AT ANY TIME AND IN ITS SOLE DISCRETION

Schneider Electric Security Notification

About Schneider Electric

At Schneider, we believe **access to energy and digital** is a basic human right. We empower all to **do more with less**, ensuring **Life Is On** everywhere, for everyone, at every moment.

We provide **energy and automation digital** solutions for **efficiency and sustainability**. We combine world-leading energy technologies, real-time automation, software and services into integrated solutions for Homes, Buildings, Data Centers, Infrastructure and Industries.

We are committed to unleash the infinite possibilities of an **open, global, innovative community** that is passionate with our **Meaningful Purpose, Inclusive and Empowered** values.

www.se.com

Revision Control

| | |
|---|-------------------------|
| <p>Version 1.0 <i>10 August 2021</i></p> | <p>Original Release</p> |
|---|-------------------------|