

SDoC Identification Number: **0001/EY56C, EY56SO IND**

## Supplier Details

### Name (of NZ manufacturer, importer or agent)

**Schneider Electric (NZ) Ltd**

**New Zealand Company Number - 363533**

### Address

11 Moncur Place Middleton, Christchurch, New Zealand

### Telephone

+61 8 8161 0195

### Fax

+61 8 8161 0920


### Contact Name

Ngoc Dinh

### Email address

[ngoc.dinh@schneider-electric.com](mailto:ngoc.dinh@schneider-electric.com)


## Medium Risk Product Details - (Product name, type, model and serial numbers as applicable)

Product Range Description	Easy56 series Industrial Socket-outlet
Parental Product (range)	EY56SOxyz, EY56Cxyz
List of Cat Nos	EY56SO332, EY56SO410, EY56SO420, EY56SO432, EY56SO510, EY56SO520, EY56SO532, EY56C320, EY56C332, EY56C410, EY56C420, EY56C432, EY56C510, EY56C520, EY56C532
Marked Brand Names (as applicable)	

## Medium Risk Products listed above fully comply with Standards as listed:

Standard No/Year/Amdts	Standard Name
AS/NZS 3123:2005	Approval and test specification – Plugs, socket-outlets and couplers for general industrial application
AS/NZS 3133:2013+A1	Approval and test specification – Air-break switches
AS 60529:2004	Degrees of protection provided by enclosures (IP Code)

## Approval /Compliance Marking (shown as applicable)

RCM Compliance		This product complies with all relevant Australian and New Zealand electrical Safety and Performance Standards, including EMC.
----------------	---	--

## Documents used as the basis for compliance:

Test Report/Certificate No	Testing or Approval Authority
TR 4759/1R	ITACS
TR 4751/1R	ITACS
TR 4786740241-SA00	UL International New Zealand Ltd
TR S15101	SGS Electrical & Electronic Testing Laboratory

## Reference to any quality/management system

1	Accredited ISO 9001 quality assurance system applied
2	3rd party factory, batch quality inspection was carried out


SDoC Identification Number: **0001/EY56C, EY56SO IND**

## Declaration

We Schneider Electric (NZ) Limited declare under our sole responsibility that the above specified electrical equipment complies with requirements of applicable Product Safety and Performance Standards as well as Clause 83 of the New Zealand Electricity (Safety) Regulations 2010

For further information please contact Customer Care:  
New Zealand: 0800 652 999  
Australia: 1300 735 329

**Signature of Authorised Person**



**Position in Organisation**

Wiring Devices Pacific, Vice-President

**Printed Name**

Peter Cave

**Date of Declaration**

Wednesday 26 August 2015