



CSA INTERNATIONAL

Certificate of Compliance

Certificate: 1545090

Master Contract: 224330

Project: 1697318

Date Issued: 2005/12/22

Issued to: Schneider Toshiba Inverter SAS

32 rue Andre Blanchet
Pacy sur Eure, 27120
France
Attention: n/a

The products listed below are eligible to bear the CSA Mark shown



Issued by: Stanislav Christov, Eng.

Authorized by: Helene Vaillancourt, Manager,
Certification Services

PRODUCTS

CLASS 3211 06 - INDUSTRIAL CONTROL EQUIPMENT - Motor Controllers -
Miscellaneous

Solid state reduced voltage starters, Type ATS01N followed by suffixes, open type, line voltage 600V ac max, 1 or 3 ph, 50/60Hz, 75 hp max, 85A max continuous current, soft stop function is only provided with Type ATS01N2...

APPLICABLE REQUIREMENTS

CAN/CSA-C22.2 No. 14-05 - Industrial Control Equipment