



Certificate: 1559695

Master Contract: 164581

Project: 80263315

Date Issued: 2025-11-04

APPLICABLE REQUIREMENTS

CSA C22.2 No. 60947-4-1:22 - Third Edition - Low-voltage switchgear and controlgear - Part 4-1: Contractors and motor-starters - Electromechanical contractors and motor-starters

CSA C22.2 No. 60947-1:22 - Third Edition - Low-voltage switchgear and control gear - Part 1: General rules



Certificate: 1559695


Master Contract: 164581

Project: 80263315

Date Issued: 2025-11-04

Notes:

Products certified under Class(es) C321123 have been certified under CSA's ISO/IEC 17065 accreditation with the Standards Council of Canada (SCC). www.scc.ca





Supplement to Certificate of Compliance

Certificate: 1559695

Master Contract: 164581

*The products listed, including the latest revision described below,
are eligible to be marked in accordance with the referenced Certificate.*

Product Certification History

Project	Date	Description
80263315	2025-11-04	Update of report 164581-1559695 to add alternate plastic materials Type K222-KGV4 to item C, D, G, H, I, K, L of model LR97D series (Part A) and to item B, H; item 2 of model LT47 series (Part B); Type Starflam PA6 U2 Z22(f2) or P-1000 Z220(f2) or P10002E(f2) or PX06004(f2) or PX06020 to item I, L of model LR97D series (Part A); Update manufacturer's name for plastic materials type PA6 25GF U9 Z22 and PF-1005 Z222 in the report; correction of typo. All in accordance with the CSA Inform No. 82 dated Dec 6, 2022.
80067853	2021-01-22	Review certification report to modify class number from 3211-03 to 3211- 23 and also the evaluation as per the CSA C22.2 no.60947-4-1.
000070184784	2018-05-25	Update to report to cover addition of alternate capacitor, according to the latest revision of standards CSA C22.2 No. 14-18 (Industrial Control Equipment no. 60). Mise à jour du rapport 164581-1559695. Ajout de condensateurs alternatif. Selon CSA C22.2 No.14-18.
0002407142	2011-04-06	Update report including varistor. Certification report transferred from Samwha EOCR Ltd. master contract 225222 to Telemecanique/Schneider Electric Industries SAS master contract 164581.
0002079762	2009-01-21	Evaluation of easement in the number of samples required for the factory test. Addition of an alternative polymeric materials.
0001559695	2004-11-16	Solid State Overload Relay - Original Certification