

Certificate of Compliance

Certificate: 1765916 (LR 89150)

Master Contract: 226596

Project: 1765916

Date Issued: 2006/07/19

Issued to: Telemecanique/Schneider
Automation SAS
Zone Industrielle Sud
Rue Lavoisier
BP 6
Longvic Les Dijon, 21601
France
Attention: Mr. Christian Desante

The products listed below are eligible to bear the CSA Mark shown



Issued by: Patrick Quinty, Eng.

Authorized by: Helene Vaillancourt,
Operations Manager



PRODUCTS

CLASS 2252 01 - PROCESS CONTROL EQUIPMENT

CLASS 2258 02 - PROCESS CONTROL EQUIPMENT - For Hazardous Locations

PART A:

CLASS 2252 01 - PROCESS CONTROL EQUIPMENT

Programmable Controllers, Series Twido, open type, DIN rail mounted 60°C.



Certificate: 1765916 (LR 89150)

Master Contract: 226596

Project: 1765916

Date Issued: 2006/07/19

Models TWDXCAT3RJ and TWDXCAISO.

External power supply for TWDXCAISO only : 24Vdc / 80mA.

Note:

Open type devices are Certified as components for use only in other Certified equipment where the suitability of the combination is to be determined by CSA International.

PART B:

CLASS 2258 02 - PROCESS CONTROL EQUIPMENT – For Hazardous Locations

Class I Division 2 Groups A, B, C and D, max. ambient 60°C, Temperature Code T4A

Models TWDXCAT3RJ and TWDXCAISO.

External power supply for TWDXCAISO only : 24Vdc / 80mA

Note:

Open type devices are Certified as components for use only in other Certified equipment where the suitability of the combination is to be determined by CSA International.

APPLICABLE REQUIREMENTS

CSA C22.2 No 0.4-04 Bonding & Grounding of Electrical Equipment (Protective Grounding)

CSA C22.2 No.142-M1987 Process Control Equipment

CSA C22.2 No.213-M1987 Non-incendive Electrical Equipment for use in Class I Division 2 Hazardous Locations