

Schneider Electric  
2195 Keating Cross Road  
Saanichton  
British Columbia  
V8M 2A5  
Canada

SGS UK Ltd.,  
Unit 12,  
Bowburn South Industrial Est,  
Bowburn,  
Durham  
DH6 5AD

## Certificate of Conformity for Power Quality Meter ION9000

**Date of Issue:** 6<sup>th</sup> June 2019  
**SGS Reference:** EMA264454/1  
**Meter Type:** ION9000  
**Model:** METSEION92XXX

**Manufacturer:** Schneider Electric  
2195 Keating Cross Road  
Saanichton  
British Columbia  
V8M 2A5  
Canada

**Date of Receipt:** 7<sup>th</sup> February 2019

**Date of Tests:** 19<sup>th</sup> February 2019 To 2<sup>nd</sup> May 2019

**Tests Required:** Test for compliance with: -  
IEC 62052-11: 2003 All clauses except 6.3.4, 7.4, 7.5.8  
IEC 62053-22: 2003 Class 0.2  
IEC 62053-24: 2015 0.5 S. Clauses: 8.2, 8.3, 8.4, 8.5

**Conclusion:** In the configurations tested the meter type meets the requirements of the standards detailed above.

**Issue Number:** 1

"This document is issued by the Company subject to its General Conditions of Service available on request or accessible at [www.sgs.com/terms\\_and\\_conditions.htm](http://www.sgs.com/terms_and_conditions.htm) and, for electronic format documents, subject to Terms and Conditions for Electronic Documents at [www.sgs.com/terms\\_e-document.htm](http://www.sgs.com/terms_e-document.htm). Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law." "Unless otherwise stated the results shown in this test report refer only to the sample(s) tested and such sample(s) are retained for 28 days only."

*Authorised Signatory*



UK E&E Operations/Business Development Manager