



# Compliance Statement

## Screened Category 6 ISO/IEC, EN & ANSI/TIA Communication Cable

**Schneider Electric P/N VDIC176218**

Category 6 Overall Foil and Braid Screened  
100  $\Omega$ , 4 Twisted Pairs, 23 AWG, Flame Retardant, LSHF, Copper Cable

**Schneider Electric Industries SAS**

**35 rue Joseph Monier**

**92500 Rueil Malmaison, France**

*Compliance Statement No. 114884E*

*This Screened ISO/IEC, EN & ANSI/TIA Communication Cable has been tested by 3P Third Party Testing and complies with the Category 6 performance requirements of edition 2.2 of ISO/IEC Generic Cabling Standard 11801, CENELEC Generic Cabling Standard EN 50173-1:2011, ANSI/TIA Generic Cabling Standard 568-C.2, 2<sup>nd</sup> edition IEC Cable Standard 61156-5, incl. amendment 1 and the requirements of CENELEC Cable Standard EN 50288-5-1:2013. Flame safety is verified according to IEC 60332-1-2, IEC 61034-1, IEC 61034-2, incl. amendment 1 and IEC 60754-2. The cable has EMC Performance Rating 9. The Compliance Statement may be suspended or withdrawn if cable fails to pass a Maintenance Testing performed at 6 or 12 month intervals.*

Hoersholm, 3<sup>rd</sup> April 2017

A handwritten signature in blue ink, appearing to read "Ole Lambertsen".

Ole Lambertsen  
Test Responsible

Hoersholm, 3<sup>rd</sup> April 2017

A handwritten signature in blue ink, appearing to read "Poul Villien".

Poul Villien  
Coordinating Manager