



Compliance Statement

Screened Category 6_A ISO/IEC, EN & ANSI/TIA Communication Cable

Schneider Electric P/N VDIC62X228

Category 6_A, Two Individual Foil without Overall Foil Screen Unit
100 Ω, 2x4 Twisted Pairs, 23 AWG, Flame Retardant, LSHF, Copper Cable

Schneider Electric Industries SAS

35 rue Joseph Monier

92500 Rueil Malmaison, France

Compliance Statement No. 114887F

This Screened ISO/IEC, EN & ANSI/TIA Communication Cable has been tested by 3P Third Party Testing and complies with the Category 6_A performance requirements of edition 2.2 of ISO/IEC Generic Cabling Standard 11801, CENELEC Generic Cabling Standard EN 50173-1:2011, ANSI/TIA Generic Cabling Standard 568-C.2, 2nd edition IEC Cable Standard 61156-5, incl. amendment 1 and requirements of CENELEC Cable Standard EN 50288-10-1:2012. Flame safety is verified according to IEC 60332-1-2, IEC 61034-1, IEC 61034-2, incl. amendment 1 and IEC 60754-2. The cable has EMC Performance Rating 8. The Compliance Statement may be suspended or withdrawn if cable fails to pass a Maintenance Testing performed at 6 or 12 month intervals.

Hoersholm, 11th May 2017

A handwritten signature in blue ink, appearing to read "Ole Lambertsen".

Ole Lambertsen
Test Responsible

Hoersholm, 11th May 2017

A handwritten signature in blue ink, appearing to read "Poul Villien".

Poul Villien
Coordinating Manager