



Compliance Statement

Screened Category 7_A ISO/IEC, EN & Enhanced ANSI/TIA Communication Cable

Schneider Electric P/N VDIC648218 / VDIC648318

Category 7_A, Individual Foil and Overall Foil Screened
100 Ω, 4 Twisted Pairs, 23 AWG, Flame Retardant, LSHF, Copper Cable

Schneider Electric Industries SAS
35 rue Joseph Monier
92500 Rueil Malmaison, France

Compliance Statement No.114888F

This Screened ISO/IEC, EN & Enhanced ANSI/TIA Communication Cable has been tested by 3P Third Party Testing and complies with the Category 7_A performance requirements of edition 2.2 of ISO/IEC Generic Cabling Standard 11801, CENELEC Generic Cabling Standard EN 50173-1:2011 and 2nd edition IEC Cable Standard 61156-5, incl. amendment 1, the Category 6_A requirements of ANSI/TIA Generic Cabling Standard 568-C.2 and the requirements of CENELEC Cable Standard EN 50288-9-1:2012. Flame safety is verified according to IEC 60332-1-2, IEC 61034-1, IEC 61034-2, incl. amendment 1, and IEC 60754-2. The cable has EMC Performance Rating 8. The Compliance Statement may be suspended or withdrawn if cable fails to pass a Maintenance Testing performed at 6 or 12 month intervals.

Hoersholm, 8th March 2017

A handwritten signature in blue ink, appearing to read "Ole Lambertsen".

Ole Lambertsen
Test Responsible

Hoersholm, 8th March 2017

A handwritten signature in blue ink, appearing to read "Poul Villien".

Poul Villien
Coordinating Manager