

CERTIFICATE

Issued to:
Applicant:
Schneider Electric Industries SAS
35 rue Joseph Monier
92500 Rueil-Malmaison, France

Licensee:
Schneider Electric Sverige AB
Tillverkarvägen 2
611 29 Nyköping, Sweden

Product : socket-outlet
Trade name(s) : LEXEL
Type(s)/model(s) : S36 and S46

The product and any acceptable variation thereto is specified in the Annex to this certificate and the documents therein referred to.

DEKRA hereby declares that the above-mentioned product has been certified on the basis of:

- a type test according to the standard NEN 1020:1987, NEN 1020:1987/A2:2004, IEC 60884-1:2002, IEC 60884-1:2002/A1:2006 and IEC 60884-1:2002/A2:2013
- an inspection of the production location according to CENELEC Operational Document CIG 021
- a certification agreement with the number 901014

DEKRA hereby grants the right to use the KEMA-KEUR certification mark.

The KEMA-KEUR certification mark may be applied to the product as specified in this certificate for the duration of the KEMA-KEUR certification agreement and under the conditions of the KEMA-KEUR certification agreement.

This certificate is issued on 14 September 2018 and expires upon withdrawal of one of the above mentioned standards.

Certificate number: 71-105643

DEKRA Certification B.V.



drs. G.J. Zoetbrood
Managing Director



Henk Schendstok
Certification Manager

© Integral publication of this certificate is allowed

ACCREDITED BY THE
DUTCH ACCREDITATION
COUNCIL



SPECIFICATION OF THE CERTIFIED PRODUCT**Product data**

Product	: socket-outlet
Trade name(s)	: LEXEL
Type(s)/model(s)	: S36 and S46
Method of mounting	: flush type
Cover	: singular cover of thermoplastic material
Rated current	: 16 A
Rated voltage	: 250 V~
Earthing	: with side earthing-contacts
Design	: provided with shutter
Markings	: tradename, series-indication and electrical ratings on the socket-outlets

Product data – type S36

Design	: two-fold slave socket-outlet for use in combination with master socket-outlet, type S46 moreover this slave socket outlet may also be used in combination with the adaptor with supply terminals, type S56
Terminals	: screw terminals

Product data – type S46

Design	: three-fold master socket-outlet which can be used in combination with the slave socket-outlet, type S36
Terminals	: screw- or screwless terminals

TESTS**Test requirements**

NEN 1020:1987
NEN 1020:1987/A2:2004
IEC 60884-1:2002
IEC 60884-1:2002/A1:2006
IEC 60884-1:2002/A2:2013

Test result

The test results are laid down in DEKRA test file 223091500 and 218750900.

Additional information

This certificate replaces certificate No. 2187509.01 which we herewith declare invalid.

Conclusion

The examination proved that all requirements were met.

Factory location

AS M ja P Nurst
Ümarmäe 3
92414 Kärkla Hiiumaa, Estonia