

# CERTIFICATE

Issued to:  
Applicant:  
**Schneider Electric Industries SAS**  
35 rue Joseph Monier  
92500 Rueil-Malmaison, France

Licensee:  
**Schneider Electric Sverige AB**  
Eskilstunavägen 7A  
611 56 Nyköping, Sweden

Product : twist-on connecting device  
Trade name(s) : THORSMAN  
Type(s)/model(s) : TORIX T6

The product and any acceptable variation thereto is specified in the Annex to this certificate and the documents therein referred to.

DEKRA hereby declares that the above-mentioned product has been certified on the basis of:

- a type test according to the standard EN 60998-1:2004 and EN 60998-2-4:2005
- an inspection of the production location according to CENELEC Operational Document CIG 021
- a certification agreement with the number 901014


DEKRA hereby grants the right to use the KEMA-KEUR certification mark.

The KEMA-KEUR certification mark may be applied to the product as specified in this certificate for the duration of the KEMA-KEUR certification agreement and under the conditions of the KEMA-KEUR certification agreement.

This certificate is issued on 11 December 2019 and expires upon withdrawal of one of the above mentioned standards.

Certificate number: 71-111059

DEKRA Certification B.V.



B.T.M. Holtus  
Managing Director



A.C. Slingerland  
Certification Manager

© Integral publication of this certificate is allowed

ACCREDITED BY THE  
DUTCH ACCREDITATION  
COUNCIL



**SPECIFICATION OF THE CERTIFIED PRODUCT****Product data**

Product	: twist-on connecting device
Trade name(s)	: THORSMAN
Type(s)/model(s)	: TORIX T6
Rated insulation voltage	: 440 V
Rated current	: 41 A
Connecting capacity	: rigid 2-10 x 0,5 mm <sup>2</sup> 2-10 x 0,75 mm <sup>2</sup> 2-10 x 1,0 mm <sup>2</sup> 2-8 x 1,5 mm <sup>2</sup> 2-5 x 2,5 mm <sup>2</sup> 2-3 x 4 mm <sup>2</sup> 2 x 6 mm <sup>2</sup>  flexible 3-10 x 0,5 mm <sup>2</sup> 2-10 x 0,75 mm <sup>2</sup> 2-10 x 1,0 mm <sup>2</sup> 2-8 x 1,5 mm <sup>2</sup> 2-5 x 2,5 mm <sup>2</sup> 2-3 x 4 mm <sup>2</sup> 2 x 6 mm <sup>2</sup>
Description	: twist-on connecting device, red

**TESTS****Test requirements**

EN 60998-1:2004  
EN 60998-2-4:2005

**Test result**

The test results are laid down in DEKRA test file 224150500.

**Additional information**

This certificate replaces certificate No. 2197553.01 which we herewith declare invalid.

**Conclusion**

The examination proved that all requirements were met.

**Factory location**

SP Moulding Poland S.z.o.o.  
6 Mickiewiczza  
98-200 Sieradz, Poland