

DEKRA

LKRA D D DEKR HKRA D D DEKRA D DEKRA IA D DE D DEKRA RA D D D DEKRA

VDA

DEKRA RA D D DEKRA

D DEKRA

D DEKR

EKRA D

D DEK

DEKRA

DEKRA

D DEK

IEKRA

KRA D

D DEKRA EKRA D D DEKR DEKRA D D DEKR

TEST CERTIFICATE

Issued to:	Schneider Electric 5 Avenue Raymond Chanas 38320 Eybens France
For the product:	Low-voltage Switchgear and Controlgear assembly / Power Factor Correction bank
Trade name:	Schneider Electric
Type/Model:	VarSet 175 – 300 kvar Capacitor Bank
Ratings:	175 - 300 kVAR at 400V / 182 – 363 kVAR at 440 V, I_{cw} 50 kA - 1 s, U_e 400 V, U_i 690 V, U_{imp} 6 kV, IP31 for more details see annex
Manufactured by:	Schneider Electric 12A, Hosur road Attibele Industrial Area Neralur Post, Bangalore India
Subject:	Design verification
Requirements:	IEC 61439-1:2011 // IEC 61439-2:2011, clauses 10.2 - 10.13 IEC 61921:2003
Remarks:	-

This Test Certificate is granted on account of an examination by DEKRA, the results of which are laid down in report no. 2191708.02-INC, dated 20 December 2016.

The examination has been carried out on one single specimen of the product, submitted by the manufacturer. The Attestation does not include an assessment of the manufacturer's production. Conformity of his production with the specimen tested by DEKRA is not the responsibility of DEKRA.

Arnhem, 20 December 2016

Number: 2191708.101

DEKRA Certification B.V.

H.R.M. Barends Certification Manager

© Integral publication of this certificate and adjoining reports is allowed

DEKRA Certification B.V. Meander 1051, 6825 MJ Arnhem P.O. Box 5185, 6802 ED Arnhem, The Netherlands T +31 88 96 83000 F +31 88 96 83100 www.dekra-certification.com Company registration 09085396



ANNEX TO DEKRA TEST CERTIFICATE 2191708.101

Page 1 of 2

Overview of product evaluation according to IEC 61439-2:

IEC 61439-2	IEC 61921	Clause description	Tested ratings	Results
Clause	Clause		-	
10.2		Strength of material and parts		_
10.2.2		Resistance to corrosion	Severity test A: indoor	Pass
10.2.3		Properties of insulating materials		Pass
10.2.3.1		Verification of thermal stability of enclosures		Pass
10.2.3.2		Verification of resistance of insulating materials to abnormal heat and fire due to internal electric effects	Insulating materials retaining current-carrying parts in position: 960 °C Other insulating materials: 650 °C	Pass
10.2.5		Lifting	125 % of the weight of the assembly	Pass
10.2.6		Mechanical impact	IK10	Pass
10.2.7		Marking	Engraved plates	Pass
10.3	7.2.7	Degree of protection of assembly	IP31	Pass
10.3	7.2.5	Clearances and creepage distances	Clearances > 5,5 mm	Pass
			Creepage distances > 10 mm except for contactors in 25 kVAR circuit (= 10 mm)	1 400
10.5	7.2.4	Protection against electric shock and integrity of protective circuits		
10.5.2		Effective earth continuity between the exposed conductive parts of the assembly and the protective circuit	R<0,1 Ohms	Pass
10.5.3		Short-circuit withstand strength of the protective circuit	PE tested I _{cc} 30 kA / 240 V	Pass
10.6		Incorporation of switching devices and components	The examination of the compliance of components in the assembly, with their relevant product standard, is not part of this project	Pass
10.7		Internal electrical circuits and connections		Pass
10.8		Terminals for external conductors		Pass
10.9	7.2.2	Dielectric properties		
10.9.2		Power-frequency withstand voltage	Ui = 690 V	Pass
10.9.3		Impulse withstand voltage	Uimp 6 kV (excluding controller and auxiliary circuit)	Pass
10.10	7.2.1	Verification of temperature rise limits at 50 °C ambient temperature	Current level 572 A (1,32 * I _n)	Pass
10.11	7.2.3	Short-circuit withstand strength	Main busbar: $I_{cw} 50 \text{ kA} - 1,0 \text{ s}$ Incoming unit: $I_{cc} 50 \text{ kA} \text{ at } 440 \text{ V}$ Functional units (fuse links + contactors): $I_{cc} 50 \text{ kA} \text{ at } 440 \text{ V}$	Pass
10.12		EMC	No test required, environment A	Pass
10.12	7.2.6	Mechanical operation	200 operations	Pass
10.10	1.2.0	meenamear operation		1 400



ANNEX TO DEKRA TEST CERTIFICATE 2191708.101

Page 2 of 2

Product details:

	Description
In coming circuit	A. Ovitala Disconnector
Incoming circuit	1x Switch Disconnector
	Type: NS800NA 3 poles, 800 A
	Manufacturer: Schneider Electric
Capacitor bank stage ratings	2 x 25 kVAr, 400 V 50 Hz
	1 x 50 kVAr, 400 V 50 Hz
	2 x 100 kVAr, 400 V 50 Hz
Capacitor unit	3 Phase Delta connected with discharge resistor.
	Ambient temperature class D (-25 55 °C),
	Capacitor 25 kVAR (33.9 kVAR, 480 V): BLRCH339A407B48
	Capacitor 50 kVAR (67.8 kVAR, 480 V) : BLRCH339A407B48
	Capacitor 100 kVAR (136 kVAR, 480 V) : BLRCH453A544B48
	Manufacturer: Schneider Electric
Fuse links	160A SP Fuse base: Fuse link – 63 A, Type gG
	160A SP Fuse base: Fuse link – 125 A, Type gG
	250A SP Fuse base: Fuse link – 250 A, Type gG
	Manufacturer: ETI
Contactors	Contactor-for 25 kVAR, 230V coil: TeSys LC1E40U5
Condicions	Contactor-for 50 kVAR, 230V coil: TeSys LC1E95U5
	Contactor-for 100 kVAR, 200V coil: TeSys LC1E160U5
	Manufacturer: Schneider Electric
Detuned reactor	3 phase type, Iron core
	Electrical insulation class H
	25 kVAR (5,67%), Network 400 V, 50 Hz Type: LVR05250A40T
	50 kVAR (5,67%), Network 400 V, 50 Hz: Type LVR05500A40T
	100 kVAR (5,67%), Network 400 V, 50 Hz: Type LVR05X00A40T
	Manufacturer: Schneider Electric
P.F. Controller	Type Varplus Logic Controller VPL6N
	Electronic type
	Manufacturer: Schneider Electric
Main busbar	2 x 30 x 10 mm Cu per phase
PE bar	2 x 30 x 5 mm Cu



DEKRA TEST REPORT		2191708.02-INC F	age 1 of 56
Applicant	÷	Schneider Electric 5 Avenue Raymond Chanas 38320 Eybens France	
Application Date	•	4 November 2016	
Order Number	:	2166446.00-INC	
Product	•	Low-voltage switchgear and controlgear assembly / P Correction bank	ower Facto
Trade name	:	Schneider Electric	
Type/Model	:	VarSet 175 - 300 kVAR at 400V / 182 - 363 kVAR at 440 V	1
Arnhem, 20 December 2	2016		
Manufacturer/ Production sites:		Schneider Electric 12A, Hosur road Attibele Industrial Area Neralur Post, Bangalore India	
Subject	:	Design verification	
Requirements : IEC 61439-1 :2011 / IEC 61439-2:2011, clauses 10.2 - 10 IEC 61921:2003		3	
Remark	:	-	
Conclusion	:	The product complies with the specified requirements	
Tested by	:	H.G.M. Kormelink	
Checked by	:	H.L. Schendstok	
HKor		0583-16	<u></u>

© DEKRA Certification B.V. All rights reserved

Products may only be provided with a quality mark or put on the market as approved if DEKRA Certification B.V. has explicitly granted the right to carry a quality mark.

DEKRA Certification B.V. and/or its subsidiaries are not liable for any direct or indirect, incidental or consequential loss originating through or because of the use of the information or data from this document or due to the impossibility of using that information or data.

The contents of this report may not be made available to a third party other than as an entity provided with the aforementioned designations with respect to copyrights and liability.

DEKRA Certification B.V. Meander 1025, 6825 MJ Arnhem P.O. Box 5185, 6802 ED Arnhem, The Netherlands T +31 88 96 83000 F +31 88 96 83100 www.dekra-certification.com Company registration 09085396