


NOTE: ALL OUTLETS ARE VIEWED FROM INSIDE OF THE UNIT AND INPUT PLUGS ARE VIEWED FROM OUTSIDE OF THE UNIT.



NOTES:

- 1. INSTALLATION SHALL COMPLY WITH ALL APPLICABLE NATIONAL, STATE AND LOCAL ELECTRICAL REGULATIONS.
- 2. REFER TO PRODUCT DOCUMENTATION FOR ADDITIONAL DETAILS PRIOR TO INSTALLATION AND SITE PREPARATION WORK
- 3. THIS DRAWING DEPICTS THE POWER SYSTEM CONNECTIONS AND IS NOT REPRESENTATIVE OF THE PHYSICAL LAYOUT. PLEASE REFER TO MECHANICAL DRAWINGS FOR PHYSICAL LAYOUT.

THIS DRAWING AND SPECIFICATIONS HEREIN ARE THE PROPERTY OF SCHNEIDER ELECTRIC AND SHALL NOT BE COPIED, REPRODUCED USED IN WHOLE OR IN PART, AS THE BASS FOR THE MANUFACTURE OR SALE OF ITEMS WITHOUT WRITTEN PERMISSION FROM SCHNEIDER ELECTRIC. THIS DRAWING IS BASED UPON LATEST AVAILABLE INFORMATION AND IS SUB-BIFCT TO CHANCE WITHOUT NOTICE.



TITLE: RACK ATS	DWG NO:
20A, 200-208V INPUT: (2)NEMA L6-20P	
(8)IEC 320 C13, (2)IEC 320 C19 ELECTRICAL SCHEMATIC	DRAWN:
ELECTRICAL SCHEMATIC	ENGINEER:
PROJECT: SUBMITTAL DRAWINGS SHEET 2 OF 2	APPROVED:

DWG NO:	\P44	30A	REV.
DRAWN:	RANJITHA	23-JUN-22	FIRST
ENGINEER:	PETE FISCHER	31-AUG-22	ANGLE

JONATHAN R 31-AUG-22 PROJECTION