




FRONT VIEW
(SHOWN WITHOUT MOUNTING EARS, IEC RECEPTACLES AND PLUG)




LEFT SIDE VIEW




TOP VIEW



VIEW-A
(ENLARGED VIEW)




VIEW-B
NEMA L5-20 PLUG
(ENLARGED VIEW)



VIEW-C
NEMA 5-20 RECEPTACLE
(ENLARGED VIEW)

(10) NEMA 5-20R
OUTPUT RECEPTACLE



- NOTES:
1. INSTALLATION SHALL COMPLY WITH ALL APPLICABLE NATIONAL, STATE AND LOCAL ELECTRICAL REGULATIONS.
 2. REFER TO PRODUCT DOCUMENTATION FOR ADDITIONAL DETAILS PRIOR TO INSTALLATION AND SITE PREPARATION WORK.
 3. ALL DIMENSIONS ARE IN MILLIMETERS [INCHES].
 4. NET WEIGHT OF THE UNIT IS 4.4 kg [9.7 lb].
 5. LENGTH OF INPUT CORD IS 2438 mm [96 INCHES].

THIS DRAWING AND SPECIFICATIONS HEREIN ARE THE PROPERTY OF SCHNEIDER ELECTRIC AND SHALL NOT BE COPIED, REPRODUCED OR USED IN WHOLE OR IN PART, AS THE BASIS FOR THE MANUFACTURE OR SALE OF ITEMS WITHOUT WRITTEN PERMISSION FROM SCHNEIDER ELECTRIC. THIS DRAWING IS BASED UPON LATEST AVAILABLE INFORMATION AND IS SUBJECT TO CHANGE WITHOUT NOTICE.



TITLE: RACK ATS
20A, 120V
INPUT: (2) NEMA 5-20P
OUTPUT: (10) NEMA 5-20R
GENERAL ARRANGEMENT

PROJECT: SUBMITTAL DRAWINGS SHEET 1 OF 2


DWG NO: AP4452A REV. 1

DRAWN: RANJITHA 27-JUN-22 FIRST ANGLE PROJECTION

ENGINEER: PETE FISCHER 10-SEP-22

APPROVED: JONATHAN R 10-SEP-22

NOTE: ALL INPUT PLUGS AND OUTLETS ARE VIEWED FROM OUTSIDE OF THE UNIT.



- NOTES:
1. INSTALLATION SHALL COMPLY WITH ALL APPLICABLE NATIONAL, STATE AND LOCAL ELECTRICAL REGULATIONS.
 2. REFER TO PRODUCT DOCUMENTATION FOR ADDITIONAL DETAILS PRIOR TO INSTALLATION AND SITE PREPARATION WORK.
 3. THIS DRAWING DEPICTS THE POWER SYSTEM CONNECTIONS AND IS NOT REPRESENTATIVE OF THE PHYSICAL LAYOUT. PLEASE REFER TO MECHANICAL DRAWINGS FOR PHYSICAL LAYOUT.

THIS DRAWING AND SPECIFICATIONS HEREIN ARE THE PROPERTY OF SCHNEIDER ELECTRIC AND SHALL NOT BE COPIED, REPRODUCED OR USED IN WHOLE OR IN PART, AS THE BASIS FOR THE MANUFACTURE OR SALE OF ITEMS WITHOUT WRITTEN PERMISSION FROM SCHNEIDER ELECTRIC. THIS DRAWING IS BASED UPON LATEST AVAILABLE INFORMATION AND IS SUBJECT TO CHANGE WITHOUT NOTICE.



TITLE: RACK ATS
 20A, 120V
 INPUT: (2) NEMA 5-20P
 OUTPUT: (10) NEMA 5-20R
 GENERAL ARRANGEMENT
 PROJECT: SUBMITTAL DRAWINGS SHEET 2 OF 2

| | | | | |
|-----------|------------|-----------|-----------|------------------|
| DWG NO: | AP4452A | | REV: | 0 |
| DRAWN: | RANJITHA | 27-JUN-22 | ENGINEER: | PETE FISCHER |
| APPROVED: | JONATHAN R | 10-SEP-22 | PROJECT: | ANGLE PROJECTION |