

1. INSTALLATION SHALL COMPLY WITH ALL APPLICABLE NATIONAL, STATE AND LOCAL ELECTRICAL REGULATIONS.

2. REFER TO PRODUCT DOCUMENTATION FOR ADDITIONAL DETAILS PRIOR TO INSTALLATION AND SITE PREPARATION WORK.

3. ALL DIMENSIONS ARE IN MILLIMETERS [INCHES].

A FRONT AND REAR ACCESS REQUIRED FOR SERVICE. MINIMUM REQUIRED FRONT/REAR CLEARANCE IS 914 [36.0].

5. NET WEIGHT OF THE UNIT IS 170.9 kg [376.7 lb].

6. TOP AND BOTTOM CABLE ENTRY USING APPROPRIATE CUSTOMER PROVIDED SOLUTION.

8. AIR FLOW AND SERVICE REQUIREMENTS. AS WELL AS MINIMUM CLEARANCE TO FIRE SUPPRESSION SYSTEMS SHOULD BE CONSIDERED WHEN LOCATING THE ENCLOSURE.


9. PROTECTION CLASS: IP20.


10. COLOR: RAL 9003, WHITE.

THIS DRAWING AND SPECIFICATIONS HEREIN ARE THE PROPERTY OF SCHNEIDER ELECTRIC AND SHALL NOT BE COPIED, REPRODUCED OR USED IN WHOLE OR IN PART, AS THE BASIS FOR THE MANUFACTURE OR SALE OF ITEMS WITHOUT WRITTEN PERMISSION FROM SCHNEIDER ELECTRIC. THIS DRAWING IS BASED UPON LATEST AVAILABLE INFORMATION AND IS SUBJECT TO CHANGE WITHOUT NOTICE



	720, 73011111 MIDE X 120011111 DELI		DWG NO: AR3350W2			REV.	
			DRAWN BY:	JAYAPRAKASH	17-APR-24	FIRS	
	GENERAL ARRANGEME	GENERAL ARRANGEMENT		KIRK SHI	18-APR-24	ANGL	
	PROJECT: SUBMITTAL DRAWINGS	SHEET 1 OF 4	APPROVED BY:	KIRK SHI	18-APR-24	PROJECT	





SECTION B-B STANDARD POSITIONS FOR MOUNTING RAILS AND THEIR ADJUSTABILITY (LOOKING DOWN)


- 1. INSTALLATION SHALL COMPLY WITH ALL APPLICABLE NATIONAL, STATE AND LOCAL ELECTRICAL REGULATIONS
- 2. REFER TO PRODUCT DOCUMENTATION FOR ADDITIONAL DETAILS PRIOR TO INSTALLATION AND SITE PREPARATION WORK.
- 3. ALL DIMENSIONS ARE IN MILLIMETERS [INCHES].

 A FRONT AND REAR DOOR OPENING SHOWN IS 180'. MAXIMUM DOOR SWING CAN BE UP TO 266'.
 5. SOME STRUCTURAL DETAILS HAVE BEEN OMITTED FOR THE PURPOSE OF CLARITY.

THIS DRAWING AND SPECIFICATIONS HEREIN ARE THE PROPERTY OF SCHNEIDER ELECTRIC AND SHALL NOT BE COPIED, REPRODUCED OR USED IN WHOLE OR IN PART, AS THE BASIS FOR THE MANUFACTURE OR SALE OF ITEMS WITHOUT WRITTEN PERMISSION FROM SCHNEIDER ELECTRIC. THIS DRAWING IS BASED UPON LATEST AVAILABLE INFORMATION AND IS SUBJECT TO CHANGE WITHOUT NOTICE



	TITLE: APC NetShelter SX SERVER 42U, 750mm WIDE x 1200mr	SERVER RACK GEN 2 x 1200mm DEEP	DWG NO: AF	REV.		
	TOD A CENTION MEMO		DRAWN BY:	JAYAPRAKASH	17-APR-24	FIRST
			ENGINEER:	KIRK SHI	18-APR-24	ANGLE
	PROJECT: SUBMITTAL DRAWINGS SI	HEET 2 OF 4	APPROVED BY:	KIRK SHI	18-APR-24	PROJECTION



BOTTOM VIEW (WITH PALLET BRACKETS, CAN BE USED FOR ANCHORING) TOP ROOF NOT SHOWN

- 1. INSTALLATION SHALL COMPLY WITH ALL APPLICABLE NATIONAL, STATE AND LOCAL ELECTRICAL REGULATIONS.
- 2. REFER TO PRODUCT DOCUMENTATION FOR ADDITIONAL DETAILS PRIOR TO INSTALLATION AND SITE PREPARATION WORK.
- 3. ALL DIMENSIONS ARE IN MILLIMETERS [INCHES]
- 4. SOME STRUCTURAL DETAILS HAVE BEEN OMITTED FOR THE PURPOSE OF CLARITY. ANCHORING CAN BE INSTALLED EITHER INSIDE OR OUTSIDE THE NetShelter WITH ONE AT FRONT AND
- ⚠ BOLT-DOWN KIT (SKU# AR7701) IS OPTIONAL AND HAS TO BE ORDERED SEPARATELY.

THIS DRAWING AND SPECIFICATIONS HEREIN ARE THE PROPERTY OF SCHNEIDER ELECTRIC AND SHALL NOT BE COPIED, REPRODUCED OR USED IN WHOLE OR IN PART, AS THE BASIS FOR THE MANUFACTURE OR SALE OF ITEMS WITHOUT WRITTEN PERMISSION FROM SCHNEIDER ELECTRIC. THIS DRAWING IS BASED UPON LATEST AVAILABLE INFORMATION AND IS SUBJECT TO CHANGE WITHOUT NOTICE



TITLE: APC NetShelter SX SERVER RACK GEN 2 42U, 750mm WIDE x 1200mm DEEP	DWG NO: AR3350W2			REV. C
PERFORATED DOOR	DRAWN BY:	JAYAPRAKASH	17-APR-24	FIRS
ANCHORING DETAILS	ENGINEER:	KIRK SHI	18-APR-24	ANG
DDO IECT, CLIDWITTAL DOMINIOS SHEET 7 OF A	ADDDOVED DV.	NIDN CHI	19_ADD_24	חמט ובט

BOLT-DOWN BRACKET

55 [2.17]

> 1072 [42.21]

CASTERS

CENTER TO

CENTER

962

[37.89]

[2.52]

2 FRONT/2 BACK)

_(4-PLACES

R8

[R.31]

260

FRONT

29


[1.12]

190

[7.48]

BOTTOM VIEW

[10.24]



- 1. INSTALLATION SHALL COMPLY WITH ALL APPLICABLE NATIONAL, STATE AND LOCAL ELECTRICAL REGULATIONS.
- 2. REFER TO PRODUCT DOCUMENTATION FOR ADDITIONAL DETAILS PRIOR TO INSTALLATION AND SITE PREPARATION WORK.
- 3. ALL DIMENSIONS ARE IN MILLIMETERS [INCHES].
- 4. SOME STRUCTURAL DETAILS HAVE BEEN OMITTED FOR THE PURPOSE OF CLARITY.

THIS DRAWING AND SPECIFICATIONS HEREIN ARE THE PROPERTY OF SCHNEIDER ELECTRIC AND SHALL NOT BE COPIED, REPRODUCED OR USED IN WHOLE OR IN PART, AS THE BASIS FOR THE MANUFACTURE OR SALE OF ITEMS WITHOUT WRITTEN PERMISSION FROM SCHNEIDER ELECTRIC. THIS DRAWING IS BASED UPON LATEST AVAILABLE INFORMATION AND IS SUBJECT TO CHANGE WITHOUT NOTICE



TITLE: APC NetShelter SX SERVER RACK GEN 2	DWG NO: ∧ [2375	$\sim \sim \sim$	
42U, 750mm WIDE x 1200mm DEEP	AN 3330 WZ			
PERFORATED DOOR	DRAWN BY:	JAYAPRAKASH	17-APR-24	
INTERNAL VIEWS	ENGINEER:	KIRK SHI	18-APR-24	

PROJECT: SUBMITTAL DRAWINGS SHEET 4 OF 4 APPROVED BY:

18-APR-24

18-APR-24

KIRK SHI

KIRK SHI

FIRST

ANGLE

PROJECTION