



UK DECLARATION OF CONFORMITY

We : **MANUFACTURER**
Schneider Electric Industries SAS
35 rue Joseph Monier
Rueil Malmaison 92500 – France

UK Representative
Schneider Electric Limited
Stafford Park 5
Telford, TF3 3BL - United Kingdom

Hereby declare under our sole responsibility that the products:

Trademark	Schneider Electric
Product, Type	Altistart ATSO1
List of references and options	See next page

Are in conformity with the requirements of the following directives and conformity was checked in accordance with the following standards.

Directive	Harmonized standard
Electrical Equipment (Safety) Regulations SI 2016 No. 1101	EN 60947-1:2007 EN 60947-1:2007/A1:2011 EN 60947-1:2007/A2:2014 Low-voltage switchgear and controlgear — Part 1: General rules Low-voltage switchgear and control
The Electromagnetic Compatibility Regulations SI 2016 No. 1091	EN 60947-4-2:2012 Low-voltage switchgear and controlgear — Part 4- 2: Contactors and motor-starters — AC semi-conductor motor controllers and starters
The Restriction of the Use of Certain Hazardous Substances in Electrical and Electronic Equipment Regulations 2012 SI 2012 No. 3032	EN IEC 63000:2018 Technical documentation for the assessment of electrical and electronic products with respect to the restriction of hazardous substances

Subject to correct installation, maintenance and use conforming to its intended purpose, to the applicable regulations and standards, to the supplier's instructions and to accepted rules of the art.

This declaration becomes invalid in the case of any modification to the products not authorized by us.

Compliance with the EMC Directive will require the application of the EMC guide giving requirements, details and advices for installation of products used.

The guides are available on <https://www.se.com>

Person in charge of technical documentation:

Eric DELAUNE, Schneider Toshiba Inverter Europe, rue André Blanchet, 27120 Pacy/Eure – France.

Signed by:

David Williams

A578D60923D7459...

Name Name : **David WILLIAMS**
 VP Marketing UK&I
 Zone UK & Ireland

Issued at Telford – UNITED KINGDOM: March 11th 2026



UK DECLARATION OF CONFORMITY

References (1)

1 PH supply 110-230V or 3 PH supply 110-480V	3 PH supply 200-240V	3 PH Supply 230-400V	3 PH supply 380-415V	3 PH supply 440-480V	Motor current
ATS01N103FT	X	X	X	X	3A
ATS01N106FT	ATS01N206LU	ATS01N206LT	ATS01N206QN	ATS01N206RT	6A
ATS01N109FT	ATS01N209LU	ATS01N209LT	ATS01N209QN	ATS01N209RT	9A
ATS01N112FT	ATS01N212LU	ATS01N212LT	ATS01N212QN	ATS01N212RT	12A
X	ATS01N222LU	ATS01N222LT	ATS01N222QN	ATS01N222RT	22A
ATS01N125FT	X	X	X	X	25A
X	ATS01N232LU	ATS01N232LT	ATS01N232QN	ATS01N232RT	32A

3 PH supply 200-480V	Motor current
ATSU01N206LT	6A
ATSU01N209LT	9A
ATSU01N212LT	12A
ATSU01N222LT	22A
ATSU01N232LT	32A

(1) may be followed by 1 to 3 character.