

产品认证证书

II型自愿认证

证书编号: CQC21107320672

发证日期: 2021年11月19日

有效期至: 2031年11月19日

委托人名称 及注册地址	施耐德电气(中国)有限公司上海分公司 上海市普陀区绥德路669号
制造商名称 及注册地址	Schneider Electric Industries SAS 35 Rue Joseph Monier 92500 Rueil-Malmaison, France
生产企业名称 及生产地址	PT. Schneider Electric Manufacturing Batam Jl Beringin Lot 4, Lot 208, Lot 1, Lot 15, Lot 16, DAN Lot 16A BIP Muka Kuning Kel.Muka Kuning Kec. Sungai Beduk – Batam, Indonesia
产品名称和系列、 规格、型号	软起动器 ATS480D17Y、ATS480D22Y、ATS480D32Y、ATS480D38Y、ATS480D47Y; 详细参数见附件
产品标准和技术要求	GB/T 14048.6-2016
认证模式	产品型式试验+初次工厂检查+获证后监督

上述产品符合 CQC12-000001-2020 认证规则的要求, 特发此证。

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

可通过扫描下方二维码或登录国家认监委网站(www.cnca.gov.cn) 查验证书信息



授权签字人

陈昕

签发

谢肇煦

中国质量认证中心



<http://www.cqc.com.cn>

中国·北京·南四环西路188号9区 100070

电话: +86 10 83886666

C(2) 0115119

CERTIFICATE OF PRODUCT CERTIFICATION

TYPE II CQC CERTIFICATION

CERTIFICATE NO.: CQC21107320672

Valid from: Nov.19,2021

Valid until: Nov.19,2031

NAME AND REGISTERED ADDRESS OF THE APPLICANT	Schneider Electric (China) Co. Ltd. Shanghai Branch No. 669, Suide Road, Putuo District, Shanghai, P.R.China
NAME AND REGISTERED ADDRESS OF THE MANUFACTURER	Schneider Electric Industries SAS 35 Rue Joseph Monier 92500 Rueil-Malmaison, France
NAME AND LOCATION OF THE FACTORY	PT. Schneider Electric Manufacturing Batam Jl Beringin Lot 4, Lot 208, Lot 1, Lot 15, Lot 16, DAN Lot 16A BIP Muka Kuning Kel.Muka Kuning Kec. Sungai Beduk – Batam, Indonesia
PRODUCT NAME, MODEL AND SPECIFICATION	Soft Starter ATS480D17Y, ATS480D22Y, ATS480D32Y, ATS480D38Y, ATS480D47Y ; See the attachment for detailed parameters
THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS	GB/T 14048.6-2016
TYPE OF CERTIFICATION SCHEMES	Type Testing of Product + Initial Factory Inspection + Follow up Factory Inspection

This is to certify that the above mentioned product(s) complies with the requirements of certification rules of CQC12-000001-2020.
The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

The certificate information is available through the QR code below or CNCA's website: www.cnca.gov.cn



SIGN BY

陈昕

SIGNATURE

谢肇煦



CHINA QUALITY CERTIFICATION CENTRE



产品认证证书

II型自愿认证

证书编号: CQC21107320672

第1页 共2页

本证书及附件应同时使用, 信息查验说明见证书页

纸号: 115119

型号: ATS480D17Y、ATS480D22Y、ATS480D32Y、ATS480D38Y、
ATS480D47Y

额定冲击耐受电压(Uimp): 6kV

额定绝缘电压(Ui): 690V

约定发热电流

(Ith): 17A(ATS480D17Y), 22A(ATS480D22Y), 32A(ATS480D32Y),

38A(ATS480D38Y), 47A(ATS480D47Y)

额定工作电压(Ue): AC208-690V

额定工作电流(Ie):

17A(ATS480D17Y), 22A(ATS480D22Y), 32A(ATS480D32Y),

38A(ATS480D38Y), 47A(ATS480D47Y)

控制电动机的功率(Pe):

2.2kW-15kW(ATS480D17Y), 4kW-18.5kW(ATS480D22Y),

5.5kW-22kW(ATS480D32Y),

7.5kW-30kW(ATS480D38Y), 11-37kW(ATS480D47Y)

使用类别: AC-53a



中国质量认证中心



产品认证证书

II型自愿认证

证书编号: CQC21107320672

第2页 共2页

本证书及附件应同时使用, 信息查验说明见证书页

纸号: 115119

极数: 3P

IP20

<u>ATS480</u>	<u>D17</u>	<u>Y</u>
1	2	3

1 产品系列 ALTISTART 480

2 产品规格

17A	ATS480D17Y
22A	ATS480D22Y
32A	ATS480D32Y
38A	ATS480D38Y
47A	ATS480D47Y

3 电压等级 Y 控制电压 (208V 至 690V)



中国质量认证中心

