



# CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

本翻译文件不具有法律效力，  
不得单独使用  
This translated document  
does not have legal validity and  
cannot be used in isolation

**CERTIFICATE NO.:** 2024010304660730

**NAME AND ADDRESS OF THE APPLICANT**

Schneider Electric (China) Co. Ltd. Shanghai Branch  
No. 669, Suide Road, Putuo District, Shanghai, P.R.China

**NAME AND ADDRESS OF THE MANUFACTURER**

Schneider Electric Industries SAS  
35 Rue Joseph Monier 92500 Rueil-Malmaison, France

**NAME AND LOCATION OF THE FACTORY**

PT. Schneider Electric Manufacturing Batam  
Jl Beringin Lot 4, Lot 208, Lot 1, Lot 15, Lot 16, DAN Lot 16A BIP Muka Kuning Kel.Muka Kuning  
Kec. Sungai Beduk – Batam, Indonesia

**PRODUCT NAME,MODEL AND SPECIFICATION**

Soft Starter

ATS480C14Y、ATS480C17Y ; (Uimp): 6kV ; (Ui): 690V ; (Ith):140A(ATS480C14Y),170A(ATS480C17Y) ; (Ue):  
AC208-690V ; (Ie): 140A(ATS480C14Y),170A(ATS480C17Y) ; (Pe):  
30kW-110kW(ATS480C14Y),37kW-160kW(ATS480C17Y) ; AC-53a ; 3P ; (IP) : IP20

**STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS**

GB/T 14048.6-2016

This is to certify that the above mentioned product(s) complies with the requirements of  
implementation rules for compulsory certification(REFNO. CNCA-C03-02:2024).

**Valid from:** Jul.19,2024

**Valid until:** Jul.18,2029

The certificate information and validity could be checked by scanning the QR code below or logging in to  
the website of the issuing authority, or on the website of the CNCA (www.cnca.gov.cn).



**SIGNATURE:**

谢肇煦



**中国质量认证中心**  
CHINA QUALITY CERTIFICATION CENTRE

CHINA QUALITY CERTIFICATION CENTRE CO., LTD.







# 中国国家强制性产品认证证书

证书编号: 2024010304660730

**认证委托人名称及地址**

施耐德电气(中国)有限公司上海分公司  
上海市普陀区绥德路 669 号

**生产者名称及地址**

Schneider Electric Industries SAS  
35 Rue Joseph Monier 92500 Rueil-Malmaison, France

**生产企业名称及地址**

PT. Schneider Electric Manufacturing Batam  
Jl Beringin Lot 4, Lot 208, Lot 1, Lot 15, Lot 16, DAN Lot 16A BIP Muka Kuning  
Kel. Muka Kuning Kec. Sungai Beduk - Batam, Indonesia

**产品名称和系列、型号、规格**

软起动器

型号: ATS480C14Y、ATS480C17Y; 额定冲击耐受电压(Uimp): 6kV; 额定绝缘电压(Ui): 690V;  
约定发热电流(Ith): 140A(ATS480C14Y), 170A(ATS480C17Y); 额定工作电压(Ue): AC208-690V;  
额定工作电流(Ie): 140A(ATS480C14Y), 170A(ATS480C17Y); 控制电动机的功率(Pe):  
30kW-110kW(ATS480C14Y), 37kW-160kW(ATS480C17Y); 使用类别: AC-53a; 极数: 3P; 外  
壳防护等级(IP): IP20

**产品标准和技术要求**

GB/T 14048.6-2016

上述产品符合《强制性产品认证实施规则 低压电器 低压元器件》  
(CNCA-C03-02:2024) 的要求, 特发此证。

发证日期: 2024 年 07 月 19 日 有效期至: 2029 年 07 月 18 日

证书信息和有效性可扫描下方二维码或登录发证机构网站查验,  
也可在认监委网站 (www.cnca.gov.cn) 查询。



签发:

谢肇煦



中国质量认证中心  
CHINA QUALITY CERTIFICATION CENTRE

中国质量认证中心有限公司

