



# 中国国家强制性产品认证证书

证书编号：2026010304860598

**认证委托人名称及地址**

施耐德电气（中国）有限公司上海分公司  
上海市普陀区绥德路 669 号

**生产者名称及地址**

Schneider Electric Industries SAS  
35 Rue Joseph Monier 92500 Rueil-Malmaison, France

**生产企业名称及地址**

无锡普洛菲斯电子有限公司  
江苏省无锡市汉江路 20 号

**产品名称和系列、型号、规格**

软起动器

ATS490C14Y,ATS490C17Y ; 详见附页

**产品标准和技术要求**

GB/T 14048.6-2016

上述产品符合《强制性产品认证实施规则 低压电器 低压元器件》  
(CNCA-C03-02:2024) 的要求，特发此证。

发证日期：2026 年 04 月 16 日 有效期至：2031 年 04 月 15 日

证书信息和有效性可扫描下方二维码或登录发证机构网站查验，  
也可在认监委网站（www.cnca.gov.cn）查询。



签发：

刘江



中国质量认证中心  
CHINA QUALITY CERTIFICATION CENTRE

中国质量认证中心有限公司





# 中国国家强制性产品认证证书

证书编号: 2026010304860598

证书附页: 第 1 页 共 1 页

ATS490C14Y,ATS490C17Y Uimp: 6kV; Ui: 690V; Ith: ATS490C14Y: 140A, ATS490C17Y: 170A; Ue: 208V~690V; Ie: ATS490C14Y: 140A, ATS490C17Y: 170A; Pe: 详见下表; 使用类别: AC-53a; 极数: 3P

Commercial reference	HP @208V	HP @230V	HP @460V	HP @575V	kW @230V	kW @400V	kW @440V	kW @500V	kW @690V
ATS490C14Y	40	50	100	125	37	75	75	90	110
ATS490C17Y	50	60	125	150	45	90	90	110	160

### 3.3 型号的解释(Explanation of model/ type):

<u>ATS490</u>	<u>C14</u>	<u>Y</u>
1	2	3

- |        |                     |           |
|--------|---------------------|-----------|
| 1 产品系列 | ALTISTART 490       |           |
| 2 产品规格 | C14: 140A           | C17: 170A |
| 3 电压等级 | Y 额定电压(208V 至 690V) |           |

本页为证书附页, 应与证书主页同时使用。



中国质量认证中心  
CHINA QUALITY CERTIFICATION CENTRE

中国质量认证中心有限公司



# CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

本翻译文件不具有法律效力，  
不得单独使用  
This translated document  
does not have legal validity and  
cannot be used in isolation

**CERTIFICATE NO.:** 2026010304860598

**NAME AND ADDRESS OF THE APPLICANT**

Schneider Electric (China) Co. Ltd. Shanghai Branch  
No. 669, Suide Road, Putuo District, Shanghai, P.R.China

**NAME AND ADDRESS OF THE MANUFACTURER**

Schneider Electric Industries SAS  
35 Rue Joseph Monier 92500 Rueil-Malmaison, France

**NAME AND LOCATION OF THE FACTORY**

Wuxi Pro-face Co., Ltd  
No.20,Hanjiang Road, Wuxi,Jiangsu, Wuxi, China

**PRODUCT NAME,MODEL AND SPECIFICATION**

Soft Starter  
ATS490C14Y,ATS490C17Y ; See the Appendix

**STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS**

GB/T 14048.6-2016

This is to certify that the above mentioned product(s) complies with the requirements of implementation rules for compulsory certification(REFNO. CNCA-C03-02:2024).

**Valid from:** Apr.16,2026

**Valid until:** Apr.15,2031

The certificate information and validity could be checked by scanning the QR code below or logging in to the website of the issuing authority, or on the website of the CNCA (www.cnca.gov.cn).



**SIGNATURE:**



**中国质量认证中心**  
CHINA QUALITY CERTIFICATION CENTRE

CHINA QUALITY CERTIFICATION CENTRE CO., LTD.





# CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

本翻译文件不具有法律效力，  
不得单独使用  
This translated document  
does not have legal validity and  
cannot be used in isolation

CERTIFICATE NO. : 2026010304860598

Appendix : Page 1 of 1

ATS490C14Y,ATS490C17Y Uimp: 6kV; Ui: 690V; Ith: ATS490C14Y: 140A,  
ATS490C17Y: 170A; Ue: 208V~690V; Ie: ATS490C14Y: 140A, ATS490C17Y: 170A;  
Pe:see the blow; Utilization Category: AC-53a; pole: 3P

Commercial reference	HP @208V	HP @230V	HP @460V	HP @575V	kW @230V	kW @400V	kW @440V	kW @500V	kW @690V
ATS490C14Y	40	50	100	125	37	75	75	90	110
ATS490C17Y	50	60	125	150	45	90	90	110	160

3.3 型号的解释(Explanation of model/ type):

<u>ATS490</u>	<u>C14</u>	<u>Y</u>
1	2	3

- |        |                     |           |
|--------|---------------------|-----------|
| 1 产品系列 | ALTISTART 490       |           |
| 2 产品规格 | C14: 140A           | C17: 170A |
| 3 电压等级 | Y 额定电压(208V 至 690V) |           |

This page is attached to the certificate and should be used at the same time as the certificate page.



中国质量认证中心  
CHINA QUALITY CERTIFICATION CENTRE

CHINA QUALITY CERTIFICATION CENTRE CO., LTD.



# 中国国家强制性产品认证证书

证书编号：2024010304660697

## 认证委托人名称及地址

施耐德电气（中国）有限公司上海分公司  
上海市普陀区绥德路 669 号

## 生产者名称及地址

Schneider Electric Industries SAS  
35 Rue Joseph Monier, 92500 Rueil-Malmaison France

## 生产企业名称及地址

PT. Schneider Electric Manufacturing Batam  
Jl Beringin Lot 4, Lot 208, Lot 1, Lot 15, Lot 16, DAN Lot 16A BIP Muka Kuning  
Kel. Muka Kuning Kec. Sungai Beduk - Batam, Indonesia

## 产品名称和系列、型号、规格

软起动机

ATS490C14Y, ATS490C17Y;Uimp:6kV;Ui:690V;Ith: ATS490C14Y:140A, ATS490C17Y:170A;Ue:  
208V~690V;Ie: ATS490C14Y:140A, ATS490C17Y:170A;Pe: ATS490C14Y: 37kW(230V),  
75kW(415V), 75kW(440V), 90kW(500V),110kW(690V);ATS490C17Y: 45kW(230V), 90kW(415V),  
90kW(440V), 110kW(500V),160kW(690V);使用类别: AC-53a;极数: 3P

## 产品标准和技术要求

GB/T 14048.6-2016

上述产品符合《强制性产品认证实施规则 低压电器 低压元器件》  
(CNCA-C03-02:2024) 的要求，特发此证。

发证日期：2024 年 07 月 19 日 有效期至：2029 年 07 月 18 日

证书信息和有效性可扫描下方二维码或登录发证机构网站查验，  
也可在认监委网站（www.cnca.gov.cn）查询。



签发：

谢肇煦



中国质量认证中心  
CHINA QUALITY CERTIFICATION CENTRE

中国质量认证中心有限公司





# CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

本翻译文件不具有法律效力，  
不得单独使用  
This translated document  
does not have legal validity and  
cannot be used in isolation

**CERTIFICATE NO.:** 2024010304660697

**NAME AND ADDRESS OF THE APPLICANT**

Schneider Electric (China) Co. Ltd. Shanghai Branch  
No. 669, Suide Road, Putuo District, Shanghai, P.R.China

**NAME AND ADDRESS OF THE MANUFACTURER**

Schneider Electric Industries SAS  
35 Rue Joseph Monier, 92500 Rueil-Malmaison France

**NAME AND LOCATION OF THE FACTORY**

PT. Schneider Electric Manufacturing Batam  
Jl Beringin Lot 4, Lot 208, Lot 1, Lot 15, Lot 16, DAN Lot 16A BIP Muka Kuning Kel.Muka Kuning  
Kec. Sungai Beduk – Batam, Indonesia

**PRODUCT NAME,MODEL AND SPECIFICATION**

Soft Starter

ATS490C14Y , ATS490C17Y;Uimp:6kV;Ui:690V;Ith: ATS490C14Y:140A, ATS490C17Y:170A;Ue: 208V~690V;Ie:  
ATS490C14Y:140A, ATS490C17Y:170A;Pe: ATS490C14Y: 37kW(230V), 75kW(415V), 75kW(440V),  
90kW(500V),110kW(690V);ATS490C17Y: 45kW(230V), 90kW(415V), 90kW(440V),  
110kW(500V) ,160kW(690V);Utilization Category: AC-53a;pole: 3P

**STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS**

GB/T 14048.6-2016

This is to certify that the above mentioned product(s) complies with the requirements of  
implementation rules for compulsory certification(REFNO. CNCA-C03-02:2024).

**Valid from:** Jul.19,2024

**Valid until:** Jul.18,2029

The certificate information and validity could be checked by scanning the QR code below or logging in to  
the website of the issuing authority, or on the website of the CNCA (www.cnca.gov.cn).



SIGNATURE:

谢肇煦



中国质量认证中心  
CHINA QUALITY CERTIFICATION CENTRE

CHINA QUALITY CERTIFICATION CENTRE CO., LTD.

