

Page 1 of 2

Certificate No: LR21180095TA Issue Date: 20/05/2021 Expiry Date: 19/05/2026

Type Approval Certificate

This is to certify that the undernoted product(s) has/have been tested with satisfactory results in accordance with the relevant requirements of the Lloyd's Register Type Approval System.

Manufacturer Schneider Electric Industries SAS

Address 35 RUE JOSEPH MONNIER, RUEIL MALMAISON, 92500, France

Type Electronic Frequency Convertor

Description Altivar ATV Series Please Refer To Appendix For Details

Trade Name ATV930, ATV950 Series

Application Marine, offshore and industrial applications for use in environmental

categories ENV1 and ENV2 as defined in Lloyd's Register Type Approval

System, Test Specification No. 1: May 2018

Specified Standard Manufactures' specification

IACS UR E10 (Rev. 8 Feb. 2021)

Ratings Refer to Appendix for details

Other Conditions The complete installation and function is subject to separate plan appraisal

according applicable Rules and Regulations, when installed on LR classed vessels. Converters are to be in compliance with LR Rules and Regulations and

to be surveyed during manufacture and testing if used for essential or

emergency services and rated 100kW or above.

If used in marine and offshore applications the equipment is to be installed on

shock absorbers and according Schneider Installation Manual

Thorsten Wolff

Senior Specialist to Lloyd's Register EMEA A member of the Lloyd's Register group

71 Fenchurch Street, London, EC3M 4BS, United Kingdom

Lloyd's Register Group Limited, its affiliates and subsidiaries and their respective officers, employees or agents are, individually and collectively, referred to in this clause as 'Lloyd's Register'. Lloyd's Register assumes no responsibility and shall not be liable to any person for any loss, damage or expense caused by reliance on the information or advice in this document or howsoever provided, unless that person has signed a contract with the relevant Lloyd's Register entity for the provision of this information or advice and in that case any responsibility or liability is exclusively on the terms and conditions set out in that contract.



Page 2 of 2

Certificate No: LR21180095TA Issue Date: 20/05/2021

Expiry Date: 19/05/2026

Type Approval Certificate

EN_NHA80932_08 revision 04/2020.

Planned EMC measures are matter of assessment prior to installation onboard. The installation requirements according Schneider Installation Manual EN_EAV64301_10 revision 04/2020 have to be fulfilled.

The temperature range in operation for all types, except for IP 20 up to 160kW types, is up to 40°C. Current derating to be applied as per Schneider derating tables.

This certificate is not valid for equipment, the design, ratings or operating parameters of which have been varied from the specimen tested. The manufacturer should notify Lloyd's Register EMEA of any modification or changes to the equipment in order to obtain a valid Certificate.

The Design Appraisal Document HTS/ETS 41190-21 AHB/TW/AC and its supplementary Type Approval Terms and Conditions form part of this Certificate.

71 Fenchurch Street, London, EC3M 4BS, United Kingdom

Lloyd's Register Group Limited, its affiliates and subsidiaries and their respective officers, employees or agents are, individually and collectively, referred to in this clause as 'Lloyd's Register'. Lloyd's Register assumes no responsibility and shall not be liable to any person for any loss, damage or expense caused by reliance on the information or advice in this document or howsoever provided, unless that person has signed a contract with the relevant Lloyd's Register entity for the provision of this information or advice and in that case any responsibility or liability is exclusively on the terms and conditions set out in that contract.



Page 1 of 4

Certificate No: LR21180095TA Issue Date: 20.05.2021 Expiry Date: 19.05.2026

<u>Appendix</u>

TYPE

Altivar ATV 930, ATV 950 series frequency converter

Type	Frame Size	Power Rating	Current Rating		
71		Normal	at 40°C		
		Overload	IN [A]		
		at 40°C [kW]			
AC Mains Voltage 200 – 240 V					
ATV930U07M3	1	0.75	4.6		
ATV930U15M3	1	1.5	8		
ATV930U22M3	1	2.2	11.2		
ATV930U30M3	2	3.0	13.7		
ATV930U40M3	1	4.0	18.7		
ATV930U55M3	2	5.5	25.4		
ATV930U75M3	3	7.5	32.7		
ATV930D11M3	3	11	46.8		
ATV930D15M3	4	15	63.4		
ATV930D18M3	4	18.5	78.4		
ATV930D22M3	4	22	92.6		
ATV930D30M3	5	30	123		
ATV930D37M3	5	37	149		
ATV930D45M3	5	45	176		
ATV930D55M3	6	55	211		
ATV930D75M3	6	75	282		
AC Mains Voltage 380 – 480 V					
ATV930U07N4	1	0.75	2.2		
ATV930U15N4	1	1.5	4		
ATV930U22N4	1	2.2	5.6		
ATV930U30N4	1	3.0	7.2		
ATV930U40N4	1	4.0	9.3		
ATV930U55N4	1	5.5	12.7		
ATV930U75N4	2	7.5	16.5		
ATV930D11N4	2	11	23.5		
ATV930D15N4	3	15	31.7		
ATV930D18N4	3	18.5	39.2		
ATV930D22N4	3	22	46.3		
ATV930D30N4	4	30	61.5		
ATV930D37N4	4	37 45	74.5 88		
ATV930D45N4	4	43	88		

Lloyd's Register Group Limited, its affiliates and subsidiaries and their respective officers, employees or agents are, individually and collectively, referred to in this clause as 'Lloyd's Register'. Lloyd's Register assumes no responsibility and shall not be liable to any person for any loss, damage or expense caused by reliance on the information or advice in this document or howsoever provided, unless that person has signed a contract with the relevant Lloyd's Register entity for the provision of this information or advice and in that case any responsibility or liability is exclusively on the terms and conditions set out in that contract.

R R R

IR IR

R



Page 2 of 4

Certificate No: LR21180095TA Issue Date: 20.05.2021 Expiry Date: 19.05.2026

TYPE continued

	T	1	T			
Type	Frame Size	Power Rating	Current Rating			
		Normal	at 40°C			
		Overload	IN [A]			
		at 40°C [kW]				
	AC Mains Voltage 380 – 480 V					
ATV930D55N4	5	55	106			
ATV930D75N4	5	75	145			
ATV930D90N4	5	90	173			
ATV930C11N4	6	110	211			
ATV930C13N4	6	132	250			
ATV930C16N4	6	160	302			
ATV930C22N4	7	220	427			
ATV930C25N4	7	250	481			
ATV930C31N4	7	315	616			
	AC Mains Voltage 575 - 690 V					
ATV930U22Y6	3Y	2.2	3.1			
ATV930U30Y6	3Y	3.0	4.2			
ATV930U40Y6	3Y	4.0	5.4			
ATV930U55Y6	3Y	5.5	7.2			
ATV930U75Y6	3Y	7.5	9.5			
ATV930D11Y6	3Y	11	13.5			
ATV930D15Y6	3Y	15	18			
ATV930D18Y6	3Y	18.5	24			
ATV930D22Y6	3Y	22	29			
ATV930D30Y6	3Y	30	34			
ATV930D37Y6	5Y	37	45			
ATV930D45Y6	5Y	45	55			
ATV930U55Y6	5Y	55	66			
ATV930U75Y6	5Y	75	83			
ATV930U90Y6	5Y	90	108			
AC Mains Voltage 380 – 480 V						
ATV950U07N4	A1	0.75	2.2			
ATV950U15N4	A1	1.5	4			
ATV950U22N4	A1	2.2	5.6			
ATV950U30N4	A1	3.0	7.2			
ATV950U40N4	A1	4.0	9.3			
ATV950U55N4	A1	5.5	12.7			

Lloyd's Register Group Limited, its affiliates and subsidiaries and their respective officers, employees or agents are, individually and collectively, referred to in this clause as 'Lloyd's Register'. Lloyd's Register assumes no responsibility and shall not be liable to any person for any loss, damage or expense caused by reliance on the information or advice in this document or howsoever provided, unless that person has signed a contract with the relevant Lloyd's Register entity for the provision of this information or advice and in that case any responsibility or liability is exclusively on the terms and conditions set out in that contract.

R R

R R R R R

> R R

R

R



Page 3 of 4

Certificate No: LR21180095TA Issue Date: 20.05.2021 Expiry Date: 19.05.2026

TYPE continued

Туре	Frame Size	Power Rating	Current Rating		
		Normal	at 40°C		
		Overload	IN [A]		
		at 40°C [kW]			
AC Mains Voltage 380 – 480 V					
ATV950U75N4	A2	7.5	16.5		
ATV950D11N4	A2	11	23.5		
ATV950D15N4	A3	15	31.7		
ATV950D18N4	A3	18.5	39.2		
ATV950D22N4	A3	22	46.3		
ATV950D30N4	В	30	61.5		
ATV950D37N4	В	37	74.5		
ATV950D45N4	В	45	88		
ATV950D55N4	С	55	106		
ATV950D75N4	С	75	145		
ATV950D90N4	C	90	173		

Software Version: V3.1IE24

Degree of protection: ATV 930 series - IP 00

ATV 950 series - IP 55

Pollution degree: 2
Overvoltage Category: III
Nominal Input frequency: 50/60 Hz

PLACES OF PRODUCTION

Schneider WuXi Drives Co., Ltd. (1) No.20, Hanjiang Road,

National Hi-Tech Industrial Development Zone

214001 Wuxi, Jiangsu

China

PT Schneider Electric Manufacturing Batam (2) Batamindo Industrial Park Jl. Beringin Lot 208

Muka Kuning 29433 Batam Island

Indonesia

Lloyd's Register Group Limited, its affiliates and subsidiaries and their respective officers, employees or agents are, individually and collectively, referred to in this clause as 'Lloyd's Register'. Lloyd's Register assumes no responsibility and shall not be liable to any person for any loss, damage or expense caused by reliance on the information or advice in this document or howsoever provided, unless that person has signed a contract with the relevant Lloyd's Register entity for the provision of this information or advice and in that case any responsibility or liability is exclusively on the terms and conditions set out in that contract.



Page 4 of 4

Certificate No: LR21180095TA Issue Date: 20.05.2021 Expiry Date: 19.05.2026

PLACES OF PRODUCTION continued

Schneider Electric IT Business Pvt. Ltd. (3) 187/3 & 188/3 Jigani Village Jigani Hobli 562106 Bangladore

(1) For all types except 575-690 V types

India

- (2) For ATV930-types; 0.75 to 5.5kW; 200 -240V and 0.75 to 11kW; 380 480V only
- (3) For ATV930-types; 7.5 to 75kW; 200 -240V and 15 to 315kW; 380 480V and 2.2 to 90kW; 575 -690V only

Lloyd's Register Group Limited, its affiliates and subsidiaries and their respective officers, employees or agents are, individually and collectively, referred to in this clause as 'Lloyd's Register'. Lloyd's Register assumes no responsibility and shall not be liable to any person for any loss, damage or expense caused by reliance on the information or advice in this document or howsoever provided, unless that person has signed a contract with the relevant Lloyd's Register entity for the provision of this information or advice and in that case any responsibility or liability is exclusively on the terms and conditions set out in that contract.