

DEMKO CERTIFICATE

Certificate No. D-04236
Page 1/3
Date of Issue 2015-06-02

Certificate Holder SCHNEIDER ELECTRIC SVERIGE AB
Cms Product Dept
Tillverkarvagen 2
Po Box 1009
Nykoping, SE-611 29 Sweden

Manufacturer SCHNEIDER ELECTRIC SVERIGE AB
Cms Product Dept
Tillverkarvagen 2
Po Box 1009
Nykoping, SE-611 29 Sweden

Production site Elda-Eltra Elektrotechnika S.A.
ul Bugno 1 PL-78-400 Szczecinek
POLAND

See Page 2

Certified Product Model Junction box
TED 001, TED 002

Trademark



Rated Voltage / Frequency 440 V
Rated Current / Power -
Insulation Class -
Degree of protection (IP) 20
Tested acc. to EN 60670-1:2005/A1:2013, EN 60670-1:2005
Test Report No. 1507617 issued on 2015-03-12
Additional See Page 2
Expire date 2020-04-07

Certification Manager
Jan-Erik Storgaard

This is to certify that representative sample(s) of the Product described herein ("Certified Product") have been investigated and found in compliance with the Standard(s) indicated on this Certificate, in accordance with the D Mark Requirements. The Designated Certificate holder is entitled to use the d or for cables <DEMKO> for the Certified Product manufactured at the production site(s) identified above, in accordance with the D Mark Service Agreement, including without limitation the D Mark Testing and Certification Services Service Terms. Only those Products bearing the D Mark should be considered as being covered by UL's D Mark Service. This Certificate shall remain valid through the expiration date, unless terminated earlier in accordance with the Service Agreement including without limitation if the Standard identified on this Certificate is amended or withdrawn prior the expiration date.

Certification Body UL International Demko A/S, Borupvang 5A, DK-2750
Ballerup, Denmark, Tel. +45 44 85 65 65,
info.dk@ul.com
www.ul-europe.com



Appendix DEMKO CERTIFICATE

Certificate No. D-04236
Page 2/3
Date of Issue 2015-06-02

Production Sites:
Thorsman & CO AB
Tillverkarvägen 2 61129 Nyköping
SWEDEN

External Certification Information:
Certificate No. 1507617 dated 2015-03-12, issued by Intertek Semko AB.

Additional Information:

Product information:

Model TED 001: Box for surface mounting of insulated material of white colour. Dimension 92x62x29 mm.

Temperature range -15/+60 °C. Impact 1J.

For connecting of fixed cables.

With screw terminal TED-KP 18, 6mm².

Model TED 002: Box for surface mounting, of insulated material of white colour. Dimension 78x61x31 mm.

Temperature range -15/+60°C. Impact 1J.

For connecting of fixed cables.

With screw terminal TED-KP 18, 6mm²,

screwless terminal SLDK2 PIN, 2,5mm².


Certification Body

UL International Demko A/S, Borupvang 5A, DK-2750
Ballerup, Denmark, Tel. +45 44 85 65 65, info.dk@ul.com
www.ul-europe.com



Appendix DEMKO CERTIFICATE

Certificate No. D-04236
Page 3/3
Date of Issue 2015-06-02



Certification Body

UL International Demko A/S, Borupvang 5A, DK-2750
Ballerup, Denmark, Tel. +45 44 85 65 65, info.dk@ul.com
www.ul-europe.com

