

VERIFICATION

of conformity with
European Low Voltage Directive

No. 601637

Type of equipment: Service Posts, of metal (Al)
Document holder: Schneider Electric SA
Box 1010, 611 29 Nyköping, Sweden
Manufacturer: Thorsman & Co AB, P.O Box 1103, 611 29 Nyköping,
Sweden
Type designation: OPTILINE 45
Trade mark: MERLIN GERIN
Technical data: 16 A, 230 V a.c. IP40. Resistance to impact 2J (IK 0,7)
Temperature range -25/+60°C
Service Posts for mounting on floor

Sample of the equipment has been tested for CE-marking according to the EC Low Voltage Directive, 73/23/EEC, 93/68/EEC.


Standard(s) used for showing compliance with the essential requirements of the directive:

Standard(s):	Test report(s):	Issued by:	Date(s):
EN 50085-1:2005	Ref. No. 601637-1,	Intertek Semko	24 April 2006
(prEN 50085-2-1:2002)	Ref. No. 601637-1	Intertek Semko	24 April 2006
NF C 68-102:1990	Ref. No. 601637-2	Intertek Semko	24 April 2006

The referred test report(s) show that the product fulfils the requirements in the EC Low Voltage Directive for CE marking. On this basis, together with the manufactures own documented production control, the manufacturer (or his European authorised representative) can in his EC Declaration of Conformity verify compliance with the Low Voltage Directive.

Stockholm
24 April 2006

Intertek Semko AB
Component and Installation Accessories


Alve Nilsson



Intertek Semko is Notified Body to the Low Voltage Directive, 73/23/EEC, to the Machinery Directive, 89/392/EEC and to the EMC Directive, 89/336/EEC. Intertek Semko is Competent Body to the EMC Directive, 89/336/EEC. Identification No. 0413.

Intertek Semko AB

Torshamnsgatan 43, Box 1103, SE-164 22 Kista, Sweden
Telephone +46 8 750 00 00, Fax +46 8 750 60 30, www.sweden.intertek-etlsemko.com
Registered in Sweden: No SE556024059901, Registered office: As address

