

DEMKO CERTIFICATE

Certificate No. D-04396
Page 1/3
Date of Issue 2015-12-09

Certificate Holder Schneider Electric Sverige AB
CMS product department
Tillverkarvägen 2
61129 Nyköping, SWEDEN

Manufacturer SCHNEIDER ELECTRIC SVERIGE AB
CMS Product Dept
Tillverkarvagen 2
Nykoping, SE-611 29 Sweden

Production site SCHNEIDER ELECTRIC DENMARK A/S
Tinvej 1 to 5
Ringsted, 4100 Denmark

See Page 2

Certified Product Model Junction box
102J1007, 102J1008, 102J0360, 102J0361, 102J0362

Trademark LK NES for Model 102J0360, 102J0361, 102J0362
NES for Model 102J1007, 102J1008

Rated Voltage / Frequency -

Rated Current / Power -

Insulation Class -

Degree of protection (IP) 44/55

Tested acc. to EN 60670-1:2005/A1:2013, EN 60670-1:2005

Test Report No. 1507662 issued on 2015-07-27

Additional See Page 2

Expire date 2020-07-27

Certification Manager
Jan-Erik Storgaard

This is to certify that representative sample(s) of the Product described herein ("Certified Product") have been investigated and found in compliance with the Standard(s) indicated on this Certificate, in accordance with the D Mark Requirements. The Designated Certificate holder is entitled to use the d or for cables <DEMKO> for the Certified Product manufactured at the production site(s) identified above, in accordance with the D Mark Service Agreement, including without limitation the D Mark Testing and Certification Services Service Terms. Only those Products bearing the D Mark should be considered as being covered by UL's D Mark Service. This Certificate shall remain valid through the expiration date, unless terminated earlier in accordance with the Service Agreement including without limitation if the Standard identified on this Certificate is amended or withdrawn prior the expiration date.

Certification Body UL International Demko A/S, Borupvang 5A, DK-2750
Ballerup, Denmark, Tel. +45 44 85 65 65,
info.dk@ul.com
www.ul-europe.com



Appendix DEMKO CERTIFICATE

Certificate No. D-04396
Page 2/3
Date of Issue 2015-12-09

Production Sites:

SCHNEIDER ELECTRIC LEXEL FABRIKA SIA
35 A Krustpils Street
Riga, 1073 Latvia

External Certification Information:

Certificate No.1507662 issue on 2015-07-27 by Intertek Semko AB.

Additional Information:

Technical data

Type designation

102J0360, 102J0361, 102J0362

Product information

Boxes of insulated material for surface-mounting.

With provision for incorporating earthing terminal type 102J0018 for twice rigid conductors 1,5 mm².

Accessories type 102J0017, PG16 nipple to put together two boxes.

Temperature range -5°C /+60°C

Type designation

Type 102J1007, 102J1008

Product information

Boxes of metal for use in cast concrete with incorporated earthing terminal.

Earthing terminal can be connected with one rigid conductors 1,5 mm².

Accessories type 102J1013, metal plate to put together two boxes. Temperature range-5°C /+60°C

Accessories for be mounted into the boxes.

102JA002: Rotary switch, pattern 6, IP55, 250V AC 10A

102JA006: Rotary switch, pattern 7, IP55, 250V AC 10A

102JA008, Rotary switch, pattern 2, IP55, 440V AC 10A

102JA042. Rotary switch, pattern 6, IP55, 250V AC 10A

102JA116, Push button switch, pattern 1+1 momentary, IP54

102JA212, One fold flush- and surface type socket-outlet, IP 44


Certification Body

UL International Demko A/S, Borupvang 5A, DK-2750
Ballerup, Denmark, Tel. +45 44 85 65 65, info.dk@ul.com
www.ul-europe.com



Appendix DEMKO CERTIFICATE

Certificate No. D-04396
Page 3/3
Date of Issue 2015-12-09



Certification Body

UL International Demko A/S, Borupvang 5A, DK-2750
Ballerup, Denmark, Tel. +45 44 85 65 65, info.dk@ul.com
www.ul-europe.com

