

Certificate of Conformity

Global-Mark Pty. Ltd., certify the electrical equipment described hereunder complies with standards listed herein and authorises the certificate holder to affix the mentioned mark to products of the same type; or the Regulatory Compliance Mark (RCM) provided that the requirements of all relevant parts of AS/NZS 4417 applicable to the article are fulfilled. In placing the authorised mark on the product, the certificate holder makes a declaration of compliance with the certification standard(s) and confirms that the product is identical to the product certified herein.

CERTIFICATION AND CERTIFICATE HOLDER DETAILS

Company Name	Schneider Electric (Australia) Pty Ltd	
Address	33-37 Port Wakefield Road Gepps Cross 5094 SA Australia	
Client ID	102093	System 1 Approval
Certification and Authorized Mark Number	GMA-102093-EA-054	Revision Number 01
Certification Standard(s)	AS/NZS 3112:2011 including A1 - 2 Approval and test specification - Plugs and socket-outlets	
Type of Certification	Electrical Safety Product Scheme	Global-Mark Electrical Product Safety Certification Scheme

CERTIFICATE DATES

Certificate Issue Date	18/10/2015
Certificate Last Update Date	6/04/2017
Certification Expiry Date	18/10/2020

This certification remains valid until the above mentioned expiry date and subject to the organisation's continued compliance with the certification standard, and Global-Mark's Terms and Conditions. This Certificate of Conformity remains the property of Global-Mark Pty Ltd, Company Number: ACN.108-087-654. The use of the Accreditation Mark indicates accreditation by the Joint Accreditation System of Australia and New Zealand in respect to those activities covered by JAS-ANZ accreditation. Refer to www.jas-anz.org/register for verification.



Certification Manager

Certificate of Conformity

CERTIFIED ELECTRICAL EQUIPMENT				
Declared Article	Product Description	Trade Name	Model Number	Rating
Socket-outlet	Single Switched Socket Module - "O" Style, Double pole - Vertical.	Medilec	ML/ABC15VDM	250 Va.c., 10 A, 50 Hz
Socket-outlet	Single Switched Socket Module - "O" Style, Double pole - Vertical.	CLIPSAL	ML/ABC15VDM	250 Va.c., 10 A, 50 Hz
Socket-outlet	Single Switched Socket Module - "O" Style, Double pole with shutter and neon - Vertical	CLIPSAL	ML/ABC15VDNM	250 Va.c., 10 A, 50 Hz
Socket-outlet	Single Switched Socket Module - "O" Style, Double pole with shutter and neon - Vertical	Medilec	ML/ABC15VDNM	250 Va.c., 10 A, 50 Hz
Socket-outlet	Single Switched Socket Module - "O" Style, Vertical	Medilec	ML/ABC15VM	250 Va.c., 10 A, 50 Hz
Socket-outlet	Single Switched Socket Module - "O" Style, Vertical	CLIPSAL	ML/ABC15VM	250 Va.c., 10 A, 50 Hz
Socket-outlet	Single Switched Socket Module - "O" Style, with shutter and neon - Vertical.	CLIPSAL	ML/ABC15VNM	250 Va.c., 10 A, 50 Hz
Socket-outlet	Single Switched Socket Module - "O" Style, with shutter and neon - Vertical.	Medilec	ML/ABC15VNM	250 Va.c., 10 A, 50 Hz

RELEVANT TRADEMARK (S)

COMMENTS OR CONDITIONS ON THE CERTIFICATION
2017/04/06 Modification 1 - add alternative model 30MD20 20 A switch mechanism in lieu of the model 30MD 10 A switch mechanism

End of document

This certification remains valid until the above mentioned expiry date and subject to the organisation's continued compliance with the certification standard, and Global-Mark's Terms and Conditions. This Certificate of Conformity remains the property of Global-Mark Pty Ltd, Company Number: ACN.108-087-654. The use of the Accreditation Mark indicates accreditation by the Joint Accreditation System of Australia and New Zealand in respect to those activities covered by JAS-ANZ accreditation. Refer to www.jas-anz.org/register for verification.



Certification Manager

