

Certificate of Conformity

Global-Mark Pty. Ltd., certify the electrical equipment described hereunder complies with standards listed herein and authorises the certificate holder to affix the mentioned mark to products of the same type; or the Regulatory Compliance Mark (RCM) provided that the requirements of all relevant parts of AS/NZS 4417 applicable to the article are fulfilled. In placing the authorised mark on the product, the certificate holder makes a declaration of compliance with the certification standard(s) and confirms that the product is identical to the product certified herein.

CERTIFICATION AND CERTIFICATE HOLDER DETAILS

Company Name	Schneider Electric (Australia) Pty Ltd	
Address	33-37 Port Wakefield Road Gepps Cross 5094 SA Australia	
Client ID	102093	System 1 Approval
Certification and Authorized Mark Number	GMA-102093-EA-062	Revision Number 00
Certification Standard(s)	AS/NZS 61009.1:2011 Residual current operated circuit-breakers with integral overcurrent protection for household and similar uses (RCBOs) - General rules (IEC 61009-1, Ed. 3.0 (2010) MOD)	
Type of Certification	Electrical Safety Product <i>Scheme</i>	Global-Mark Electrical Product Safety Certification Scheme

CERTIFICATE DATES

Certificate Issue Date	18/01/2016
Certificate Last Update Date	
Certification Expiry Date	18/01/2021

This certification remains valid until the above mentioned expiry date and subject to the organisation's continued compliance with the certification standard, and Global-Mark's Terms and Conditions. This Certificate of Conformity remains the property of Global-Mark Pty Ltd, Company Number: ACN.108-087-654. The use of the Accreditation Mark indicates accreditation by the Joint Accreditation System of Australia and New Zealand in respect to those activities covered by JAS-ANZ accreditation. Refer to www.jas-anz.org/register for verification.



Certification Manager



CERTIFIED ELECTRICAL EQUIPMENT				
Declared Article	Product Description	Trade Name	Model Number	Rating
Residual current device	RCD/MCB module	Clipsal	4EBE210/30	10A, 30mA, 240V~,10kA, A type, C curve, 1 phase
Residual current device	RCD/MCB module	Clipsal	4EBE216/30	16A, 30mA, 240V~,10kA, A type, C curve, 1 phase
Residual current device	RCD/MCB module	Clipsal	4EBE210/10	10A, 10mA, 240V~,10kA, A type, C curve, 1 phase
Residual current device	RCD/MCB module	Clipsal	4EBE216/10	16A, 10mA, 240V~,10kA, A type, C curve, 1 phase
Residual current device	RCD/MCB module	Clipsal	4EBE220/10	20A, 10mA, 240V~,10kA, A type, C curve, 1 phase
Residual current device	RCD/MCB module	Clipsal	4EBE232/10	32A, 10mA, 240V~,10kA, A type, C curve, 1 phase
Residual current device	RCD/MCB module	Clipsal	E01CNN10	10A, 10mA, 240V~,10kA, A type, C curve, 1 phase
Residual current device	RCD/MCB module	Clipsal	E01CNN16	16A, 10mA, 240V~,10kA, A type, C curve, 1 phase
Residual current device	RCD/MCB module	Clipsal	E01CNN20	20A, 10mA, 240V~,10kA, A type, C curve, 1 phase
Residual current device	RCD/MCB module	Clipsal	E01CNN32	32A, 10mA, 240V~,10kA, A type, C curve, 1 phase
Residual current device	RCD/MCB module	Medilec	E01CNN10	10A, 10mA, 240V~,10kA, A type, C curve, 1 phase
Residual current device	RCD/MCB module	Medilec	E01CNN16	16A, 10mA, 240V~,10kA, A type, C curve, 1 phase
Residual current device	RCD/MCB module	Medilec	E01CNN20	20A, 10mA, 240V~,10kA, A type, C curve, 1 phase
Residual current device	RCD/MCB module	Medilec	E01CNN32	32A, 10mA, 240V~,10kA, A type, C curve, 1 phase
Residual current device	RCD/MCB module	E.S.P	E01CNN10	10A, 10mA, 240V~,10kA, A type, C curve, 1 phase
Residual current device	RCD/MCB module	E.S.P	E01CNN16	16A, 10mA, 240V~,10kA, A type, C curve, 1 phase
Residual current device	RCD/MCB module	E.S.P	E01CNN20	20A, 10mA, 240V~,10kA, A type, C curve, 1 phase
Residual current device	RCD/MCB module	E.S.P	E01CNN32	32A, 10mA, 240V~,10kA, A type, C curve, 1 phase
Residual current device	Flush Mount Metal Plate, Combination RCD / MCBs	Clipsal	E01/10/2	10A, 10mA, 240V~,10kA, A type, C curve, 1 phase
Residual current device	Flush Mount Metal Plate, Combination RCD / MCBs	Clipsal	E01/16/2	16A, 10mA, 240V~,10kA, A type, C curve, 1 phase
Residual current device	Flush Mount Metal Plate, Combination RCD / MCBs	Clipsal	E01/20/2	20A, 10mA, 240V~,10kA, A type, C curve, 1 phase
Residual current device	Flush Mount Metal Plate, Combination RCD / MCBs	Clipsal	E01/32/2	32A, 10mA, 240V~,10kA, A type, C curve, 1 phase

This certification remains valid until the above mentioned expiry date and subject to the organisation's continued compliance with the certification standard, and Global-Mark's Terms and Conditions. This Certificate of Conformity remains the property of Global-Mark Pty Ltd, Company Number: ACN.108-087-654. The use of the Accreditation Mark indicates accreditation by the Joint Accreditation System of Australia and New Zealand in respect to those activities covered by JAS-ANZ accreditation. Refer to www.jas-anz.org/register for verification.



Certification Manager






global-mark®

Certificate of Conformity

Residual current device	Flush Mount Metal Plate, Combination RCD / MCBs	Medilec	E01/10/2	10A, 10mA, 240V~,10kA, A type, C curve, 1 phase
Residual current device	Flush Mount Metal Plate, Combination RCD / MCBs	Medilec	E01/16/2	16A, 10mA, 240V~,10kA, A type, C curve, 1 phase
Residual current device	Flush Mount Metal Plate, Combination RCD / MCBs	Medilec	E01/20/2	20A, 10mA, 240V~,10kA, A type, C curve, 1 phase
Residual current device	Flush Mount Metal Plate, Combination RCD / MCBs	Medilec	E01/32/2	32A, 10mA, 240V~,10kA, A type, C curve, 1 phase
Residual current device	Flush Mount Metal Plate, Combination RCD / MCBs	E.S.P	E01/10/2	10A, 10mA, 240V~,10kA, A type, C curve, 1 phase
Residual current device	Flush Mount Metal Plate, Combination RCD / MCBs	E.S.P	E01/16/2	16A, 10mA, 240V~,10kA, A type, C curve, 1 phase
Residual current device	Flush Mount Metal Plate, Combination RCD / MCBs	E.S.P	E01/20/2	20A, 10mA, 240V~,10kA, A type, C curve, 1 phase
Residual current device	Flush Mount Metal Plate, Combination RCD / MCBs	E.S.P	E01/32/2	32A, 10mA, 240V~,10kA, A type, C curve, 1 phase

RELEVANT TRADEMARK (S)

COMMENTS OR CONDITIONS ON THE CERTIFICATION
Nil

End of document

This certification remains valid until the above mentioned expiry date and subject to the organisation's continued compliance with the certification standard, and Global-Mark's Terms and Conditions. This Certificate of Conformity remains the property of Global-Mark Pty Ltd, Company Number: ACN.108-087-654. The use of the Accreditation Mark indicates accreditation by the Joint Accreditation System of Australia and New Zealand in respect to those activities covered by JAS-ANZ accreditation. Refer to www.jas-anz.org/register for verification.



Certification Manager



JAS-ANZ

