

# Certificate of Conformity

Global-Mark Pty. Ltd., certify the electrical equipment described hereunder complies with standards listed herein and authorises the certificate holder to affix the mentioned mark to products of the same type; or the Regulatory Compliance Mark (RCM) provided that the requirements of all relevant parts of AS/NZS 4417 applicable to the article are fulfilled. In placing the authorised mark on the product, the certificate holder makes a declaration of compliance with the certification standard(s) and confirms that the product is identical to the product certified herein.

## CERTIFICATION AND CERTIFICATE HOLDER DETAILS

Company Name	<b>Schneider Electric (Australia) Pty Ltd</b>		
Address	<b>33-37 Port Wakefield Road Gepps Cross 5094 SA Australia</b>		
Client ID	<b>102093</b>	Global-Mark File Number:	<b>102093-115</b>
Certification and Authorized Mark Number	<b>GMA-501675-EA</b>	System 1 Approval	Revision Number <b>02</b>
Certification Standard(s)	<b>AS/NZS 3190:2016 Approval and test specification - Residual Current Device (current-operated earth-leakage devices)</b>		
Type of Certification	<b>Electrical Safety Product</b>	Scheme	<b>Global-Mark Electrical Product Safety Certification Scheme</b>

## CERTIFICATE DATES

Certificate Issue Date	<b>10/03/2017</b>
Certificate Last Update Date	<b>6/12/2017</b>
Certification Expiry Date	<b>10/03/2022</b>

This certification remains valid until the above mentioned expiry date and subject to the organisation's continued compliance with the certification standard, and Global-Mark's Terms and Conditions. This Certificate of Conformity remains the property of Global-Mark Pty Ltd, Company Number: ACN.108-087-654. The use of the Accreditation Mark indicates accreditation by the Joint Accreditation System of Australia and New Zealand in respect to those activities covered by JAS-ANZ accreditation. Refer to [www.jas-anz.org/register](http://www.jas-anz.org/register) for verification.



Certification Manager



# Certificate of Conformity

CERTIFIED ELECTRICAL EQUIPMENT				
Declared Article	Product Description	Trade Name	Model Number	Rating
Residual Current Device	RCD protected Twin Socket Outlet, 2000 series	CLIPSAL by Schneider Electric	2025RCD10	SO: 230 - 240 V a.c, 50 Hz, 10A, RCD: 20A, 10mA, 3kA Type I
Residual Current Device	RCD protected Twin Socket Outlet, C2000 series	CLIPSAL by Schneider Electric	2025RCD30	SO: 230 - 240 V a.c, 50 Hz, 10A, RCD: 20A, 30mA, 3kA Type II
Residual Current Device	RCD protected Twin Socket Outlet, 2000 series	CLIPSAL by Schneider Electric	2031RCD30	SO: 230 - 240 V a.c, 50 Hz, 10A, RCD: 20A, 30mA, 3kA Type II
Residual Current Device	RCD protected Twin Socket Outlet, 2000 series	MEDILEC	ML2031RCD10	SO: 230 - 240 V a.c, 50 Hz, 10A, RCD: 20A, 10mA, 3kA Type I
Residual Current Device	RCD protected Twin Socket Outlet, 2000 series	MEDILEC	ML2025RCD10	SO: 230 - 240 V a.c, 50 Hz, 10A, RCD: 20A, 10mA, 3kA Type I
Residual Current Device	RCD protected Twin Socket Outlet Vertical, 2000 series	CLIPSAL by Schneider Electric	2031VRCD10	SO: 230 - 240 V a.c, 50 Hz, 10A, RCD: 20A, 10mA, 3kA Type I
Residual Current Device	RCD protected Twin Socket outlet PDL 600 series	PDL by Schneider Electric	695RCD-30	SO: 230 - 240 V a.c, 50 Hz, 10A, RCD: 20A, 30mA, 3kA Type II
Residual Current Device	RCD protected Twin Socket Outlet, 2000 series	CLIPSAL by Schneider Electric	2031RCD10	SO: 230 - 240 V a.c, 50 Hz, 10A, RCD: 20A, 10mA, 3kA Type I
Residual Current Device	RCD protected Twin Socket Outlet, Cleaner, 2000 series	MEDILEC	ML2025RCD10C	SO: 230 - 240 V a.c, 50 Hz, 10A, RCD: 20A, 10mA, 3kA Type I

This certification remains valid until the above mentioned expiry date and subject to the organisation's continued compliance with the certification standard, and Global-Mark's Terms and Conditions. This Certificate of Conformity remains the property of Global-Mark Pty Ltd, Company Number: ACN.108-087-654. The use of the Accreditation Mark indicates accreditation by the Joint Accreditation System of Australia and New Zealand in respect to those activities covered by JAS-ANZ accreditation. Refer to [www.jas-anz.org/register](http://www.jas-anz.org/register) for verification.



**Certification Manager**




# Certificate of Conformity

Residual Current Device	RCD protected Twin Socket Outlet Vertical, 2000 series	CLIPSAL by Schneider Electric	2031VRCD30	SO: 230 - 240 V a.c, 50 Hz, 10A, RCD: 20A, 30mA, 3kA Type II
Residual Current Device	RCD protected Twin Socket Outlet, C2000 series	CLIPSAL by Schneider Electric	C2025RCD10	SO: 230 - 240 V a.c, 50 Hz, 10A, RCD: 20A, 10mA, 3kA Type I
Residual Current Device	RCD protected Twin Socket Outlet, Cleaner, 2000 series	CLIPSAL by Schneider Electric	2025RCD10C	SO: 230 - 240 V a.c, 50 Hz, 10A, RCD: 20A, 10mA, 3kA Type I
Residual Current Device	RCD protected Twin Socket Outlet, 2000 series	CLIPSAL by Schneider Electric	C2025RCD30	SO: 230 - 240 V a.c, 50 Hz, 10A, RCD: 20A, 30mA, 3kA Type II
Residual Current Device	RCD protected Twin Socket Outlet, 2000 series	MEDILEC	ML2031VRCD10	SO: 230 - 240 V a.c, 50 Hz, 10A, RCD: 20A, 10mA, 3kA Type I
Residual Current Device	RCD protected Twin Socket outlet PDL 600 series	PDL by Schneider Electric	695RCD-10	SO: 230 - 240 V a.c, 50 Hz, 10A, RCD: 20A, 10mA, 3kA Type I

## RELEVANT TRADEMARK (S)

## COMMENTS OR CONDITIONS ON THE CERTIFICATION

2017/03/27 Modification 1  
 - correct model number 2025RCD10  
 2017/12/06 Modification 2  
 - add "Type I" or "Type II" classification to the rating

End of document

This certification remains valid until the above mentioned expiry date and subject to the organisation's continued compliance with the certification standard, and Global-Mark's Terms and Conditions. This Certificate of Conformity remains the property of Global-Mark Pty Ltd, Company Number: ACN.108-087-654. The use of the Accreditation Mark indicates accreditation by the Joint Accreditation System of Australia and New Zealand in respect to those activities covered by JAS-ANZ accreditation. Refer to [www.jas-anz.org/register](http://www.jas-anz.org/register) for verification.



Certification Manager

