

Certificate of Conformity

Global-Mark Pty. Ltd., certify the electrical equipment described hereunder complies with standards listed herein and authorises the certificate holder to affix the mentioned mark to products of the same type; or the Regulatory Compliance Mark (RCM) provided that the requirements of all relevant parts of AS/NZS 4417 applicable to the article are fulfilled. In placing the authorised mark on the product, the certificate holder makes a declaration of compliance with the certification standard(s) and confirms that the product is identical to the product certified herein.

CERTIFICATION AND CERTIFICATE HOLDER DETAILS

Company Name	Schneider Electric (Australia) Pty Ltd		
Address	33-37 Port Wakefield Road Gepps Cross 5094 SA Australia		
Client ID	102093	Global-Mark File Number:	102093-151
Certification and Authorized Mark Number	GMA-503062-EA	System 1 Approval	
Certification Standard(s)	AS/NZS IEC 60947.2:2015 Low-voltage switchgear and controlgear Part 2: Circuit-breakers		
Type of Certification	Electrical Safety Product	Scheme	Global-Mark Electrical Product Safety Certification Scheme
		Revision Number	00

CERTIFICATE DATES

Certificate Issue Date	23/12/2017
Certificate Last Update Date	
Certification Expiry Date	23/12/2022

This certification remains valid until the above mentioned expiry date and subject to the organisation's continued compliance with the certification standard, and Global-Mark's Terms and Conditions. This Certificate of Conformity remains the property of Global-Mark Pty Ltd, Company Number: ACN.108-087-654. The use of the Accreditation Mark indicates accreditation by the Joint Accreditation System of Australia and New Zealand in respect to those activities covered by JAS-ANZ accreditation. Refer to www.jas-anz.org/register for verification.



Certification Manager






global-mark®

Certificate of Conformity

CERTIFIED ELECTRICAL EQUIPMENT				
Declared Article	Product Description	Trade Name	Model Number	Rating
Miniature overcurrent circuitbreaker	Miniature overcurrent circuitbreaker C60H-DC, single-pole	Schneider Electric	A9N61500	250 Vdc, 0.5 A, Ics 4.5 kA, Icu 6 kA, C curve
Miniature overcurrent circuitbreaker	Miniature overcurrent circuitbreaker C60H-DC, single-pole	Schneider Electric	A9N61501	250 Vdc, 1 A, Ics 4.5 kA, Icu 6 kA, C, K curve
Miniature overcurrent circuitbreaker	Miniature overcurrent circuitbreaker C60H-DC, single-pole	Schneider Electric	A9N61502	250 Vdc, 2 A, Ics 4.5 kA, Icu 6 kA, C, K curve
Miniature overcurrent circuitbreaker	Miniature overcurrent circuitbreaker C60H-DC, single-pole	Schneider Electric	A9N61503	250 Vdc, 3 A, Ics 4.5 kA, Icu 6 kA, C, K curve
Miniature overcurrent circuitbreaker	Miniature overcurrent circuitbreaker C60H-DC, single-pole	Schneider Electric	A9N61504	250 Vdc, 4 A, Ics 4.5 kA, Icu 6 kA, C, K curve
Miniature overcurrent circuitbreaker	Miniature overcurrent circuitbreaker C60H-DC, single-pole	Schneider Electric	A9N61505	250 Vdc, 5 A, Ics 4.5 kA, Icu 6 kA, C curve
Miniature overcurrent circuitbreaker	Miniature overcurrent circuitbreaker C60H-DC, single-pole	Schneider Electric	A9N61506	250 Vdc, 6 A, Ics 4.5 kA, Icu 6 kA, C,B,K curve
Miniature overcurrent circuitbreaker	Miniature overcurrent circuitbreaker C60H-DC, single-pole	Schneider Electric	A9N61508	250 Vdc, 10 A, Ics 4.5 kA, Icu 6 kA, C,B,K curve
Miniature overcurrent circuitbreaker	Miniature overcurrent circuitbreaker C60H-DC, single-pole	Schneider Electric	A9N61509	250 Vdc, 13 A, Ics 4.5 kA, Icu 6 kA, C,B,K curve
Miniature overcurrent circuitbreaker	Miniature overcurrent circuitbreaker C60H-DC, single-pole	Schneider Electric	A9N61510	250 Vdc, 15 A, Ics 4.5 kA, Icu 6 kA, C curve
Miniature overcurrent circuitbreaker	Miniature overcurrent circuitbreaker C60H-DC, single-pole	Schneider Electric	A9N61511	250 Vdc, 16 A, Ics 4.5 kA, Icu 6 kA, C,B,K curve
Miniature overcurrent circuitbreaker	Miniature overcurrent circuitbreaker C60H-DC, single-pole	Schneider Electric	A9N61512	250 Vdc, 20 A, Ics 4.5 kA, Icu 6 kA, C,B,K curve
Miniature overcurrent circuitbreaker	Miniature overcurrent circuitbreaker C60H-DC, single-pole	Schneider Electric	A9N61513	250 Vdc, 25 A, Ics 4.5 kA, Icu 6 kA, C,B,K curve
Miniature overcurrent circuitbreaker	Miniature overcurrent circuitbreaker C60H-DC, single-pole	Schneider Electric	A9N61514	250 Vdc, 30 A, Ics 4.5 kA, Icu 6 kA, C curve

This certification remains valid until the above mentioned expiry date and subject to the organisation's continued compliance with the certification standard, and Global-Mark's Terms and Conditions. This Certificate of Conformity remains the property of Global-Mark Pty Ltd, Company Number: ACN.108-087-654. The use of the Accreditation Mark indicates accreditation by the Joint Accreditation System of Australia and New Zealand in respect to those activities covered by JAS-ANZ accreditation. Refer to www.jas-anz.org/register for verification.



Certification Manager



JAS-ANZ



Certificate of Conformity

Miniature overcurrent circuitbreaker	Miniature overcurrent circuitbreaker C60H-DC, single-pole	Schneider Electric	A9N61515	250 Vdc, 32 A, Ics 4.5 kA, Icu 6 kA, C,B,K curve
Miniature overcurrent circuitbreaker	Miniature overcurrent circuitbreaker C60H-DC, single-pole	Schneider Electric	A9N61517	250 Vdc, 40 A, Ics 4.5 kA, Icu 6 kA, C,B,K curve
Miniature overcurrent circuitbreaker	Miniature overcurrent circuitbreaker C60H-DC, single-pole	Schneider Electric	A9N61518	250 Vdc, 50 A, Ics 4.5 kA, Icu 6 kA, C,B,K curve
Miniature overcurrent circuitbreaker	Miniature overcurrent circuitbreaker C60H-DC, single-pole	Schneider Electric	A9N61519	250 Vdc, 63 A, Ics 4.5 kA, Icu 6 kA, C,B,K curve
Miniature overcurrent circuitbreaker	Miniature overcurrent circuitbreaker C60H-DC, double-pole	Schneider Electric	A9N61520	500 Vdc, 0.5 A, Ics 4.5 kA, Icu 6 kA, C curve
Miniature overcurrent circuitbreaker	Miniature overcurrent circuitbreaker C60H-DC, double-pole	Schneider Electric	A9N61521	500 Vdc, 1 A, Ics 4.5 kA, Icu 6 kA, C, K curve
Miniature overcurrent circuitbreaker	Miniature overcurrent circuitbreaker C60H-DC, double-pole	Schneider Electric	A9N61522	500 Vdc, 2 A, Ics 4.5 kA, Icu 6 kA, C, K curve
Miniature overcurrent circuitbreaker	Miniature overcurrent circuitbreaker C60H-DC, double-pole	Schneider Electric	A9N61523	500 Vdc, 3 A, Ics 4.5 kA, Icu 6 kA, C, K curve
Miniature overcurrent circuitbreaker	Miniature overcurrent circuitbreaker C60H-DC, double-pole	Schneider Electric	A9N61524	500 Vdc, 4 A, Ics 4.5 kA, Icu 6 kA, C, K curve
Miniature overcurrent circuitbreaker	Miniature overcurrent circuitbreaker C60H-DC, double-pole	Schneider Electric	A9N61525	500 Vdc, 5 A, Ics 4.5 kA, Icu 6 kA, C curve
Miniature overcurrent circuitbreaker	Miniature overcurrent circuitbreaker C60H-DC, double-pole	Schneider Electric	A9N61526	500 Vdc, 6 A, Ics 4.5 kA, Icu 6 kA, C,B,K curve
Miniature overcurrent circuitbreaker	Miniature overcurrent circuitbreaker C60H-DC, double-pole	Schneider Electric	A9N61528	500 Vdc, 10 A, Ics 4.5 kA, Icu 6 kA, C,B,K curve
Miniature overcurrent circuitbreaker	Miniature overcurrent circuitbreaker C60H-DC, double-pole	Schneider Electric	A9N61529	500 Vdc, 13 A, Ics 4.5 kA, Icu 6 kA, C,B,K curve
Miniature overcurrent circuitbreaker	Miniature overcurrent circuitbreaker C60H-DC, double-pole	Schneider Electric	A9N61530	500 Vdc, 15 A, Ics 4.5 kA, Icu 6 kA, C curve
Miniature overcurrent circuitbreaker	Miniature overcurrent circuitbreaker C60H-DC, double-pole	Schneider Electric	A9N61531	500 Vdc, 16 A, Ics 4.5 kA, Icu 6 kA, C,B,K curve

This certification remains valid until the above mentioned expiry date and subject to the organisation's continued compliance with the certification standard, and Global-Mark's Terms and Conditions. This Certificate of Conformity remains the property of Global-Mark Pty Ltd, Company Number: ACN.108-087-654. The use of the Accreditation Mark indicates accreditation by the Joint Accreditation System of Australia and New Zealand in respect to those activities covered by JAS-ANZ accreditation. Refer to www.jas-anz.org/register for verification.



Certification Manager






global-mark®

Certificate of Conformity

Miniature overcurrent circuitbreaker	Miniature overcurrent circuitbreaker C60H-DC, double-pole	Schneider Electric	A9N61532	500 Vdc, 20 A, Ics 4.5 kA, Icu 6 kA, C,B,K curve
Miniature overcurrent circuitbreaker	Miniature overcurrent circuitbreaker C60H-DC, double-pole	Schneider Electric	A9N61533	500 Vdc, 25 A, Ics 4.5 kA, Icu 6 kA, C,B,K curve
Miniature overcurrent circuitbreaker	Miniature overcurrent circuitbreaker C60H-DC, double-pole	Schneider Electric	A9N61534	500 Vdc, 30 A, Ics 4.5 kA, Icu 6 kA, C curve
Miniature overcurrent circuitbreaker	Miniature overcurrent circuitbreaker C60H-DC, double-pole	Schneider Electric	A9N61535	500 Vdc, 32 A, Ics 4.5 kA, Icu 6 kA, C,B,K curve
Miniature overcurrent circuitbreaker	Miniature overcurrent circuitbreaker C60H-DC, double-pole	Schneider Electric	A9N61537	500 Vdc, 40 A, Ics 4.5 kA, Icu 6 kA, C,B,K curve
Miniature overcurrent circuitbreaker	Miniature overcurrent circuitbreaker C60H-DC, double-pole	Schneider Electric	A9N61538	500 Vdc, 50 A, Ics 4.5 kA, Icu 6 kA, C,B,K curve
Miniature overcurrent circuitbreaker	Miniature overcurrent circuitbreaker C60H-DC, double-pole	Schneider Electric	A9N61539	500 Vdc, 63 A, Ics 4.5 kA, Icu 6 kA, C,B,K curve

RELEVANT TRADEMARK (S)

COMMENTS OR CONDITIONS ON THE CERTIFICATION
Nil

End of document

This certification remains valid until the above mentioned expiry date and subject to the organisation's continued compliance with the certification standard, and Global-Mark's Terms and Conditions. This Certificate of Conformity remains the property of Global-Mark Pty Ltd, Company Number: ACN.108-087-654. The use of the Accreditation Mark indicates accreditation by the Joint Accreditation System of Australia and New Zealand in respect to those activities covered by JAS-ANZ accreditation. Refer to www.jas-anz.org/register for verification.



Certification Manager



JAS-ANZ

