



global-mark®

Certificate of Conformity

Global-Mark Pty. Ltd., certify the electrical equipment described hereunder complies with standards listed herein and notifies the certificate holder to affix the authorised Approval Mark on the product of the same type and the Regulatory Compliance Mark (RCM) mark provided that the requirements of all relevant parts of AS/NZS 4417 applicable to the article are fulfilled. In placing the Approval and RCM mark on the product, the Responsible Supplier makes a declaration of compliance with the certification standard(s) and confirms that the product is identical to the product certified herein. – This Certificate meets the requirements of a Recognised External Certification Scheme (EESS- RECS) and a Recognised External Approval Scheme (NSW-REAS).

CERTIFICATION AND CERTIFICATE HOLDER DETAILS

Company Name	Schneider Electric (Australia) Pty Ltd	Other Name	
Address	33-37 Port Wakefield Road Gepps Cross SA 5094 Australia		
Client ID	102093	Global-Mark File Number:	102093-151
Certificate Number & Approval Mark	GMA-503062-EA	Revision Number	02
Certification Standard(s)	AS/NZS IEC 60947.2:2015 Low-voltage switchgear and controlgear Part 2: Circuit-breakers		
Type of Certification	Electrical Safety Product	Scheme	Global-Mark Electrical Product Safety Certification Scheme

System 1 Approval

CERTIFICATE DATES

Certificate Issue Date	23/12/2017
Certificate Last Update Date	13/12/2022
Certification Expiry Date	23/12/2027

This certification remains valid until the above mentioned expiry date and subject to the organisation's continued compliance with the certification standard, and Global-Mark's Terms and Conditions. This Certificate of Conformity remains the property of Global-Mark Pty Ltd, Company Number: ACN.108-087-654. The use of the Accreditation Mark indicates accreditation by the Joint Accreditation System of Australia and New Zealand in respect to those activities covered by JAS-ANZ accreditation. Refer to www.jas-anz.org/register for verification.



Certification Manager

Global-Mark Pty Ltd, Copyright 2012 - 407, 32 Delhi Road, North Ryde NSW 2113, Australia



Global-Mark.com.au®



WWW.JAS-ANZ.ORG/REGISTER



global-mark®

Certificate of Conformity

CERTIFIED ELECTRICAL EQUIPMENT				
Declared Article	Product Description	Trade Name	Model Number	Rating
Miniature overcurrent circuitbreaker	Miniature overcurrent circuitbreaker C60H-DC, double-pole	Schneider Electric	A9N61538	500 Vdc, 50 A, Ics 4.5 kA, Icu 6 kA, C,B,K curve
Miniature overcurrent circuitbreaker	Miniature overcurrent circuitbreaker C60H-DC, double-pole	Schneider Electric	A9N61531	500 Vdc, 16 A, Ics 4.5 kA, Icu 6 kA, C,B,K curve
Miniature overcurrent circuitbreaker	Miniature overcurrent circuitbreaker C60H-DC, double-pole	Schneider Electric	A9N61533	500 Vdc, 25 A, Ics 4.5 kA, Icu 6 kA, C,B,K curve
Miniature overcurrent circuitbreaker	Miniature overcurrent circuitbreaker C60H-DC, double-pole	Schneider Electric	A9N61537	500 Vdc, 40 A, Ics 4.5 kA, Icu 6 kA, C,B,K curve
Miniature overcurrent circuitbreaker	Miniature overcurrent circuitbreaker C60H-DC, double-pole	Schneider Electric	A9N61523	500 Vdc, 3 A, Ics 4.5 kA, Icu 6 kA, C, K curve
Miniature overcurrent circuitbreaker	Miniature overcurrent circuitbreaker C60H-DC, double-pole	Schneider Electric	A9N61526	500 Vdc, 6 A, Ics 4.5 kA, Icu 6 kA, C,B,K curve
Miniature overcurrent circuitbreaker	Miniature overcurrent circuitbreaker C60H-DC, double-pole	Schneider Electric	A9N61529	500 Vdc, 13 A, Ics 4.5 kA, Icu 6 kA, C,B,K curve
Miniature overcurrent circuitbreaker	Miniature overcurrent circuitbreaker C60H-DC, double-pole	Schneider Electric	A9N61528	500 Vdc, 10 A, Ics 4.5 kA, Icu 6 kA, C,B,K curve
Miniature overcurrent circuitbreaker	Miniature overcurrent circuitbreaker C60H-DC, double-pole	Schneider Electric	A9N61534	500 Vdc, 30 A, Ics 4.5 kA, Icu 6 kA, C curve
Miniature overcurrent circuitbreaker	Miniature overcurrent circuitbreaker C60H-DC, double-pole	Schneider Electric	A9N61532	500 Vdc, 20 A, Ics 4.5 kA, Icu 6 kA, C,B,K curve
Miniature overcurrent circuitbreaker	Miniature overcurrent circuitbreaker C60H-DC, double-pole	Schneider Electric	A9N61530	500 Vdc, 15 A, Ics 4.5 kA, Icu 6 kA, C curve
Miniature overcurrent circuitbreaker	Miniature overcurrent circuitbreaker C60H-DC, double-pole	Schneider Electric	A9N61524	500 Vdc, 4 A, Ics 4.5 kA, Icu 6 kA, C, K curve
Miniature overcurrent circuitbreaker	Miniature overcurrent circuitbreaker C60H-DC, double-pole	Schneider Electric	A9N61525	500 Vdc, 5 A, Ics 4.5 kA, Icu 6 kA, C curve
Miniature overcurrent circuitbreaker	Miniature overcurrent circuitbreaker C60H-DC, double-pole	Schneider Electric	A9N61521	500 Vdc, 1 A, Ics 4.5 kA, Icu 6 kA, C, K curve

This certification remains valid until the above mentioned expiry date and subject to the organisation's continued compliance with the certification standard, and Global-Mark's Terms and Conditions. This Certificate of Conformity remains the property of Global-Mark Pty Ltd, Company Number: ACN.108-087-654. The use of the Accreditation Mark indicates accreditation by the Joint Accreditation System of Australia and New Zealand in respect to those activities covered by JAS-ANZ accreditation. Refer to www.jas-anz.org/register for verification.



Certification Manager

Handwritten signature of Jerrisa Hobbs

Global-Mark Pty Ltd, Copyright 2012 - 407, 32 Delhi Road, North Ryde NSW 2113, Australia



Global-Mark.com.au®



WWW.JAS-ANZ.ORG/REGISTER

Certificate of Conformity

Miniature overcurrent circuitbreaker	Miniature overcurrent circuitbreaker C60H-DC, double-pole	Schneider Electric	A9N61522	500 Vdc, 2 A, Ics 4.5 kA, Icu 6 kA, C, K curve
Miniature overcurrent circuitbreaker	Miniature overcurrent circuitbreaker C60H-DC, double-pole	Schneider Electric	A9N61535	500 Vdc, 32 A, Ics 4.5 kA, Icu 6 kA, C,B,K curve
Miniature overcurrent circuitbreaker	Miniature overcurrent circuitbreaker C60H-DC, double-pole	Schneider Electric	A9N61539	500 Vdc, 63 A, Ics 4.5 kA, Icu 6 kA, C,B,K curve
Miniature overcurrent circuitbreaker	Miniature overcurrent circuitbreaker C60H-DC, double-pole	Schneider Electric	A9N61520	500 Vdc, 0.5 A, Ics 4.5 kA, Icu 6 kA, C curve
Miniature overcurrent circuitbreaker	Miniature overcurrent circuitbreaker C60H-DC, single-pole	Schneider Electric	A9N61518	250 Vdc, 50 A, Ics 4.5 kA, Icu 6 kA, C,B,K curve
Miniature overcurrent circuitbreaker	Miniature overcurrent circuitbreaker C60H-DC, single-pole	Schneider Electric	A9N61502	250 Vdc, 2 A, Ics 4.5 kA, Icu 6 kA, C, K curve
Miniature overcurrent circuitbreaker	Miniature overcurrent circuitbreaker C60H-DC, single-pole	Schneider Electric	A9N61505	250 Vdc, 5 A, Ics 4.5 kA, Icu 6 kA, C curve
Miniature overcurrent circuitbreaker	Miniature overcurrent circuitbreaker C60H-DC, single-pole	Schneider Electric	A9N61519	250 Vdc, 63 A, Ics 4.5 kA, Icu 6 kA, C,B,K curve
Miniature overcurrent circuitbreaker	Miniature overcurrent circuitbreaker C60H-DC, single-pole	Schneider Electric	A9N61513	250 Vdc, 25 A, Ics 4.5 kA, Icu 6 kA, C,B,K curve
Miniature overcurrent circuitbreaker	Miniature overcurrent circuitbreaker C60H-DC, single-pole	Schneider Electric	A9N61508	250 Vdc, 10 A, Ics 4.5 kA, Icu 6 kA, C,B,K curve
Miniature overcurrent circuitbreaker	Miniature overcurrent circuitbreaker C60H-DC, single-pole	Schneider Electric	A9N61515	250 Vdc, 32 A, Ics 4.5 kA, Icu 6 kA, C,B,K curve
Miniature overcurrent circuitbreaker	Miniature overcurrent circuitbreaker C60H-DC, single-pole	Schneider Electric	A9N61503	250 Vdc, 3 A, Ics 4.5 kA, Icu 6 kA, C, K curve
Miniature overcurrent circuitbreaker	Miniature overcurrent circuitbreaker C60H-DC, single-pole	Schneider Electric	A9N61517	250 Vdc, 40 A, Ics 4.5 kA, Icu 6 kA, C,B,K curve
Miniature overcurrent circuitbreaker	Miniature overcurrent circuitbreaker C60H-DC, single-pole	Schneider Electric	A9N61506	250 Vdc, 6 A, Ics 4.5 kA, Icu 6 kA, C,B,K curve
Miniature overcurrent circuitbreaker	Miniature overcurrent circuitbreaker C60H-DC, single-pole	Schneider Electric	A9N61504	250 Vdc, 4 A, Ics 4.5 kA, Icu 6 kA, C, K curve

This certification remains valid until the above mentioned expiry date and subject to the organisation's continued compliance with the certification standard, and Global-Mark's Terms and Conditions. This Certificate of Conformity remains the property of Global-Mark Pty Ltd, Company Number: ACN.108-087-654. The use of the Accreditation Mark indicates accreditation by the Joint Accreditation System of Australia and New Zealand in respect to those activities covered by JAS-ANZ accreditation. Refer to www.jas-anz.org/register for verification.



Certification Manager





global-mark®

Certificate of Conformity

Miniature overcurrent circuitbreaker	Miniature overcurrent circuitbreaker C60H-DC, single-pole	Schneider Electric	A9N61510	250 Vdc, 15 A, Ics 4.5 kA, Icu 6 kA, C curve
Miniature overcurrent circuitbreaker	Miniature overcurrent circuitbreaker C60H-DC, single-pole	Schneider Electric	A9N61511	250 Vdc, 16 A, Ics 4.5 kA, Icu 6 kA, C,B,K curve
Miniature overcurrent circuitbreaker	Miniature overcurrent circuitbreaker C60H-DC, single-pole	Schneider Electric	A9N61501	250 Vdc, 1 A, Ics 4.5 kA, Icu 6 kA, C, K curve
Miniature overcurrent circuitbreaker	Miniature overcurrent circuitbreaker C60H-DC, single-pole	Schneider Electric	A9N61509	250 Vdc, 13 A, Ics 4.5 kA, Icu 6 kA, C,B,K curve
Miniature overcurrent circuitbreaker	Miniature overcurrent circuitbreaker C60H-DC, single-pole	Schneider Electric	A9N61500	250 Vdc, 0.5 A, Ics 4.5 kA, Icu 6 kA, C curve
Miniature overcurrent circuitbreaker	Miniature overcurrent circuitbreaker C60H-DC, single-pole	Schneider Electric	A9N61512	250 Vdc, 20 A, Ics 4.5 kA, Icu 6 kA, C,B,K curve
Miniature overcurrent circuitbreaker	Miniature overcurrent circuitbreaker C60H-DC, single-pole	Schneider Electric	A9N61514	250 Vdc, 30 A, Ics 4.5 kA, Icu 6 kA, C curve
Miniature overcurrent circuitbreaker	Multi9 C60H-DC MCB double pole	Schneider Electric	M9U21201	500Vdc 2P 1A C 6kA
Miniature overcurrent circuitbreaker	Multi9 C60H-DC MCB double pole	Schneider Electric	M9U21202	500Vdc 2P 2A C 6kA
Miniature overcurrent circuitbreaker	Multi9 C60H-DC MCB double pole	Schneider Electric	M9U21203	500Vdc 2P 3A C 6kA
Miniature overcurrent circuitbreaker	Multi9 C60H-DC MCB double pole	Schneider Electric	M9U21204	500Vdc 2P 4A C 6kA
Miniature overcurrent circuitbreaker	Multi9 C60H-DC MCB double pole	Schneider Electric	M9U21206	500Vdc 2P 6A C 6kA
Miniature overcurrent circuitbreaker	Multi9 C60H-DC MCB double pole	Schneider Electric	M9U21210	500Vdc 2P 10A C 6kA
Miniature overcurrent circuitbreaker	Multi9 C60H-DC MCB double pole	Schneider Electric	M9U21213	500Vdc 2P 13A C 6kA
Miniature overcurrent circuitbreaker	Multi9 C60H-DC MCB double pole	Schneider Electric	M9U21216	500Vdc 2P 16A C 6kA

This certification remains valid until the above mentioned expiry date and subject to the organisation's continued compliance with the certification standard, and Global-Mark's Terms and Conditions. This Certificate of Conformity remains the property of Global-Mark Pty Ltd, Company Number: ACN.108-087-654. The use of the Accreditation Mark indicates accreditation by the Joint Accreditation System of Australia and New Zealand in respect to those activities covered by JAS-ANZ accreditation. Refer to www.jas-anz.org/register for verification.



Certification Manager

Global-Mark Pty Ltd, Copyright 2012 - 407, 32 Delhi Road, North Ryde NSW 2113, Australia



Global-Mark.com.au®

JAS-ANZ



WWW.JAS-ANZ.ORG/REGISTER

Certificate of Conformity

Miniature overcurrent circuitbreaker	Multi9 C60H-DC MCB double pole	Schneider Electric	M9U21220	500Vdc 2P 20A C 6kA
Miniature overcurrent circuitbreaker	Multi9 C60H-DC MCB double pole	Schneider Electric	M9U21225	500Vdc 2P 25A C 6kA
Miniature overcurrent circuitbreaker	Multi9 C60H-DC MCB double pole	Schneider Electric	M9U21232	500Vdc 2P 32A C 6kA
Miniature overcurrent circuitbreaker	Multi9 C60H-DC MCB double pole	Schneider Electric	M9U21240	500Vdc 2P 40A C 6kA
Miniature overcurrent circuitbreaker	Multi9 C60H-DC MCB double pole	Schneider Electric	M9U21250	500Vdc 2P 50A C 6kA
Miniature overcurrent circuitbreaker	Multi9 C60H-DC MCB double pole	Schneider Electric	M9U21263	500Vdc 2P 63A C 6kA
Miniature overcurrent circuitbreaker	Multi9 C60H-DC MCB double pole	Schneider Electric	M9U21270	500Vdc 2P 0.5A C 6kA
Miniature overcurrent circuitbreaker	Multi9 C60H-DC MCB single pole	Schneider Electric	M9U21101	250Vdc 1P 1A C 6kA
Miniature overcurrent circuitbreaker	Multi9 C60H-DC MCB single pole	Schneider Electric	M9U21102	250Vdc 1P 2A C 6kA
Miniature overcurrent circuitbreaker	Multi9 C60H-DC MCB single pole	Schneider Electric	M9U21103	250Vdc 1P 3A C 6kA
Miniature overcurrent circuitbreaker	Multi9 C60H-DC MCB single pole	Schneider Electric	M9U21104	250Vdc 1P 4A C 6kA
Miniature overcurrent circuitbreaker	Multi9 C60H-DC MCB single pole	Schneider Electric	M9U21106	250Vdc 1P 6A C 6kA
Miniature overcurrent circuitbreaker	Multi9 C60H-DC MCB single pole	Schneider Electric	M9U21110	250Vdc 1P 10A C 6kA
Miniature overcurrent circuitbreaker	Multi9 C60H-DC MCB single pole	Schneider Electric	M9U21113	250Vdc 1P 13A C 6kA
Miniature overcurrent circuitbreaker	Multi9 C60H-DC MCB single pole	Schneider Electric	M9U21116	250Vdc 1P 16A C 6kA

This certification remains valid until the above mentioned expiry date and subject to the organisation's continued compliance with the certification standard, and Global-Mark's Terms and Conditions. This Certificate of Conformity remains the property of Global-Mark Pty Ltd, Company Number: ACN.108-087-654. The use of the Accreditation Mark indicates accreditation by the Joint Accreditation System of Australia and New Zealand in respect to those activities covered by JAS-ANZ accreditation. Refer to www.jas-anz.org/register for verification.



Certification Manager





global-mark®

Certificate of Conformity

Miniature overcurrent circuitbreaker	Multi9 C60H-DC MCB single pole	Schneider Electric	M9U21120	250Vdc 1P 20A C 6kA
Miniature overcurrent circuitbreaker	Multi9 C60H-DC MCB single pole	Schneider Electric	M9U21125	250Vdc 1P 25A C 6kA
Miniature overcurrent circuitbreaker	Multi9 C60H-DC MCB single pole	Schneider Electric	M9U21132	250Vdc 1P 32A C 6kA
Miniature overcurrent circuitbreaker	Multi9 C60H-DC MCB single pole	Schneider Electric	M9U21140	250Vdc 1P 40A C 6kA
Miniature overcurrent circuitbreaker	Multi9 C60H-DC MCB single pole	Schneider Electric	M9U21150	250Vdc 1P 50A C 6kA
Miniature overcurrent circuitbreaker	Multi9 C60H-DC MCB single pole	Schneider Electric	M9U21163	250Vdc 1P 63A C 6kA
Miniature overcurrent circuitbreaker	Multi9 C60H-DC MCB single pole	Schneider Electric	M9U21170	250Vdc 1P 0.5A C 6kA

RELEVANT TRADEMARK (S)

COMMENTS OR CONDITIONS ON THE CERTIFICATION
2021/11/19 Modification 1 - add alternative models 2022/12/13 Modification 2 - Recertification revise expiry date

End of document

This certification remains valid until the above mentioned expiry date and subject to the organisation's continued compliance with the certification standard, and Global-Mark's Terms and Conditions. This Certificate of Conformity remains the property of Global-Mark Pty Ltd, Company Number: ACN.108-087-654. The use of the Accreditation Mark indicates accreditation by the Joint Accreditation System of Australia and New Zealand in respect to those activities covered by JAS-ANZ accreditation. Refer to www.jas-anz.org/register for verification.



Certification Manager

Global-Mark Pty Ltd, Copyright 2012 - 407, 32 Delhi Road, North Ryde NSW 2113, Australia



Global-Mark.com.au®



WWW.JAS-ANZ.ORG/REGISTER