

Certificate of Conformity

Global-Mark Pty. Ltd., certify the electrical equipment described hereunder complies with standards listed herein and notifies the certificate holder to affix the Regulatory Compliance Mark (RCM) mark to products of the same type provided that the requirements of all relevant parts of AS/NZS 4417 applicable to the article are fulfilled. In placing the RCM mark on the product, the Responsible Supplier makes a declaration of compliance with the certification standard(s) and confirms that the product is identical to the product certified herein. – **This Certificate meets the requirements of a Recognised External Certification Scheme (RECS) including the rules of the EESS.**

CERTIFICATION AND CERTIFICATE HOLDER DETAILS

Company Name	Schneider Electric (Australia) Pty Ltd			
Address	33-37 Port Wakefield Road Gepps Cross SA 5094 Australia			
Client ID	102093	Global-Mark File Number:	102093-060	System 1 Approval
Certificate Number	GMA-507613-EA	Revision Number	00	
Certification Standard(s)	AS/NZS 3112:2017 Approval and test specification - Plugs and socket-outlets			
Type of Certification	Electrical Safety Product	Scheme	Global-Mark Electrical Product Safety Certification Scheme	

CERTIFICATE DATES

Certificate Issue Date	25/11/2015
Certificate Last Update Date	25/06/2020
Certification Expiry Date	25/06/2025

This certification remains valid until the above mentioned expiry date and subject to the organisation's continued compliance with the certification standard, and Global-Mark's Terms and Conditions. This Certificate of Conformity remains the property of Global-Mark Pty Ltd, Company Number: ACN.108-087-654. The use of the Accreditation Mark indicates accreditation by the Joint Accreditation System of Australia and New Zealand in respect to those activities covered by JAS-ANZ accreditation. Refer to www.jas-anz.org/register for verification.



Certification Manager



Certificate of Conformity

CERTIFIED ELECTRICAL EQUIPMENT				
Declared Article	Product Description	Trade Name	Model Number	Rating
Socket-outlet	ML2000 Series - Twin vertical switched socket with RCD label, circuit ID and power indicator	Medilec	ML2025VI	250V a.c., 10A
Socket-outlet	Single Pole Switched Socket Outlet with Shutter and Removable Switch	CLIPSAL by Schneider Electric	2025VXA	250V a.c., 10 A
Socket-outlet	Single Pole Switched Socket Outlet with Shutter, Removable Switch and Neon	CLIPSAL by Schneider Electric	2025VXS	250V a.c., 10 A
Socket-outlet	Single Pole Switched Socket Outlet with Shutter, Removable Switch and Power available Neon and Circuit ID	CLIPSAL by Schneider Electric	ML2025VI	250V a.c., 10 A

RELEVANT TRADEMARK (S)

COMMENTS OR CONDITIONS ON THE CERTIFICATION

Alternative base material changed from Noryl to Polycarbonate
 2016/01/16 Modification 1
 - add alternative trade name Medilec and model number
 - add alternative LED indicator in lieu of neon indicators
 2020/06/25 Re-issued as GMA-507613-EA Rev 00
 - update standards - AS/NZS 3112:2017 AS/NZS 3133:2013 + A1 - 2 & AS/NZS 3100:2017 + A1- 3

End of document

This certification remains valid until the above mentioned expiry date and subject to the organisation's continued compliance with the certification standard, and Global-Mark's Terms and Conditions. This Certificate of Conformity remains the property of Global-Mark Pty Ltd, Company Number: ACN.108-087-654. The use of the Accreditation Mark indicates accreditation by the Joint Accreditation System of Australia and New Zealand in respect to those activities covered by JAS-ANZ accreditation. Refer to www.jas-anz.org/register for verification.



Certification Manager