



04 April 2016

33-37 Port Wakefield Road, Gepps Cross SA 5094, Australia

Schneider Electric (Australia) Pty. Ltd.

Attention: Les Blaszczyk

Dear Sir / Madam,

APPROVAL OF PRESCRIBED EQUIPMENT

Enclosed is the Certificate(s) in respect to your recent application received by Office of the Technical Regulator.

Please take time to check the certificate to ensure that all details are correct in accordance with your application, and that you understand all of the conditions imposed on the approval.

Should you have any queries, please contact George Nestic on telephone ,or email george.nestic@sa.gov.au

Any samples that accompanied your application are available for collection, and if not collected within 20 business days of the date hereon may be disposed of.

Notification must be given to Office of the Technical Regulator of any change of registered Address within 20 business days.

Yours faithfully

A handwritten signature in blue ink that reads "George Nestic".

AUTHORISED OFFICER

Ref: OTR160163/00



Certificate Number: OTR160163/00



Certificate of Approval

This is to certify that the Authorised officer has approved the electrical equipment described hereunder.

Registered Declarant: Schneider Electric (Australia) Pty. Ltd.
33-37 Port Wakefield Road, Gepps Cross SA 5094, Australia

Required Marking: OTR160163

Electrical equipment covered by this approval must comply in all respects with the approved article, and prior to being supplied or offered for supply, must be clearly and indelibly marked with the required marking indicated above, or the Regulatory Compliance Mark (RCM) provided that the requirements of all relevant parts of AS/NZS 4417 applicable to the article are fulfilled.

Any modifications to the electrical equipment or its place of manufacture must be approved by Office of the Technical Regulator prior to the equipment being supplied or offered for supply.

Notification must be given to Office of the Technical Regulator of any change to the name or address of the holder of the certificate within 20 business days.

ARTICLE DETAILS

Electrical Equipment:	Level 3 Miniature Overcurrent Circuit-Breaker Miniature Overcurrent Circuit-Breaker
Relevant Standards:	AS/NZS60898.1:2004
Expiry Date:	04 April 2021
Conditions of Approval:	

A handwritten signature in blue ink that reads "George Nasic".

DATE OF APPROVAL: 04 April 2016 Page: (2/ 4)

Authorised officer



Government of South Australia
Department of State Development

Certificate Number: OTR160163/00



Approval details

Model	C1201P10C080, C1201P10C100, C1201P10C125
Rated at	Input: 240 Vac, 80, 100 & 125 A, 50/60 Hz
Trade Name	Schneider
Comments	Schneider C120 series, 1 pole, 1.5 module wide, C type tripping curve, breaking capacity 10 kA

Model	C1202P10C080, C1202P10C100, C1202P10C125
Rated at	Input: 415 Vac, 80, 100 & 125 A, 50/60 Hz
Trade Name	Schneider
Comments	Schneider C120 series, 2 pole, 1.5 module wide, C type tripping curve, breaking capacity 10 kA

Model	C1203P10C080, C1203P10C100, C1203P10C125
Rated at	Input: 415 Vac, 80, 100 & 125 A, 50/60 Hz
Trade Name	Schneider
Comments	Schneider C120 series, 3 pole, 1.5 module wide, C type tripping curve, breaking capacity 10 kA

Model	4CB180/10, 4CB1100/10, 4CB1125/10
Rated at	Input: 240 Vac, 80, 100 & 125 A, 50/60 Hz

A handwritten signature in blue ink that reads "George Nasic".

Certificate Number: OTR160163/00



Trade Name	Clipsal
Comments	Clipsal 4CB series, 1 pole, 1.5 module wide, C type tripping curve, breaking capacity 10 kA

Model	4CB280/10, 4CB2100/10, 4CB2125/10
Rated at	Input: 415 Vac, 80, 100 & 125 A, 50/60 Hz
Trade Name	Clipsal
Comments	Clipsal 4CB series, 2 pole, 1.5 module wide, C type tripping curve, breaking capacity 10 kA

Model	4CB380/10, 4CB3100/10, 4CB3125/10
Rated at	Input: 415 Vac, 80, 100 & 125 A, 50/60 Hz
Trade Name	Clipsal
Comments	Clipsal 4CB series, 1 pole, 1.5 module wide, C type tripping curve, breaking capacity 10 kA

A handwritten signature in blue ink that reads "George Nasic".

