



15 September 2016

33-37 Port Wakefield Road, Gepps Cross SA 5094, Australia

Schneider Electric (Australia) Pty. Ltd.

Attention: Les Blaszczyk

Dear Sir / Madam,

### **APPROVAL OF PRESCRIBED EQUIPMENT**

Enclosed is the Certificate(s) in respect to your recent application received by Office of the Technical Regulator.

Please take time to check the certificate to ensure that all details are correct in accordance with your application, and that you understand all of the conditions imposed on the approval.

Should you have any queries, please contact George Nestic on telephone ,or email [george.nestic@sa.gov.au](mailto:george.nestic@sa.gov.au)

Any samples that accompanied your application are available for collection, and if not collected within 20 business days of the date hereon may be disposed of.

Notification must be given to Office of the Technical Regulator of any change of registered Address within 20 business days.

Yours faithfully

A handwritten signature in blue ink that reads "George Nestic".

**AUTHORISED OFFICER**

Ref: OTR160512/00



Certificate Number: OTR160512/00



# Certificate of Approval

This is to certify that the Authorised officer has approved the electrical equipment described hereunder.

**Registered Declarant:** Schneider Electric (Australia) Pty. Ltd.  
33-37 Port Wakefield Road, Gepps Cross SA 5094, Australia

## Required Marking: OTR160512

Electrical equipment covered by this approval must comply in all respects with the approved article, and prior to being supplied or offered for supply, must be clearly and indelibly marked with the required marking indicated above, or the Regulatory Compliance Mark (RCM) provided that the requirements of all relevant parts of AS/NZS 4417 applicable to the article are fulfilled.

Any modifications to the electrical equipment or its place of manufacture must be approved by Office of the Technical Regulator prior to the equipment being supplied or offered for supply.

Notification must be given to Office of the Technical Regulator of any change to the name or address of the holder of the certificate within 20 business days.

### ARTICLE DETAILS

Electrical Equipment:	Level 3 Miniature Overcurrent Circuit-Breaker Polarised Miniature Overcurrent Circuit-Breaker
Relevant Standards:	AS/NZS 60947.2:2015
Expiry Date:	15 September 2021
Conditions of Approval:	

A handwritten signature in blue ink that reads "George Nasic".



Certificate Number: OTR160512/00



## Approval details

Model	4CB102/6DC, 4CB104/6DC, 4CB106/6DC, 4CB110/6DC, 4CB116/6DC, 4CB120/6DC, 4CB125/6DC, 4CB132/6DC, 4CB140/6DC
Rated at	Input: 250 Vdc, 2, 4, 6, 10, 16, 20, 25, 32 & 40 A
Trade Name	Clipsal, Clipsal by Schneider, Schneider or Schneider Electric
Comments	Polarised, DC type, 6 kA breaking capacity, C type tripping curve, 1 pole.

Model	4CB202/6DC, 4CB204/6DC, 4CB206/6DC, 4CB210/6DC, 4CB216/6DC, 4CB220/6DC, 4CB225/6DC, 4CB232/6DC, 4CB240/6DC
Rated at	Input: 500 Vdc, 2, 4, 6, 10, 16, 20, 25, 32 & 40 A
Trade Name	Clipsal, Clipsal by Schneider, Schneider or Schneider Electric
Comments	Polarised, DC type, 6 kA breaking capacity, C type tripping curve, 2 pole.

A handwritten signature in blue ink that reads "George Nasic".

DATE OF APPROVAL: 15 September 2016

Page: (3/ 3)

Authorised officer



Government of South Australia  
Department of State Development