



15 August 2017

33-37 Port Wakefield Road, Gepps Cross SA 5094, Australia

Schneider Electric (Australia) Pty. Ltd.

Attention: Les Blaszczyk

Dear Sir / Madam,

APPROVAL OF PRESCRIBED EQUIPMENT

Enclosed is the Certificate(s) in respect to your recent application received by Office of the Technical Regulator.

Please take time to check the certificate to ensure that all details are correct in accordance with your application, and that you understand all of the conditions imposed on the approval.

Should you have any queries, please contact Office of the Technical Regulator on telephone -,or email tim.rahill@sa.gov.au

Any samples that accompanied your application are available for collection, and if not collected within 20 business days of the date hereon may be disposed of.

Notification must be given to Office of the Technical Regulator of any change of registered Address within 20 business days.

Yours faithfully

A handwritten signature in blue ink, appearing to read "George N. K. K." with a stylized flourish below it.

AUTHORISED OFFICER

Ref: OTR170401/00



Certificate Number: OTR170401/00



Certificate of Approval

This is to certify that the Authorised officer has approved the electrical equipment described hereunder.

Registered Declarant: Schneider Electric (Australia) Pty. Ltd.
33-37 Port Wakefield Road, Gepps Cross SA 5094, Australia

Required Marking: OTR170401

Electrical equipment covered by this approval must comply in all respects with the approved article, and prior to being supplied or offered for supply, must be clearly and indelibly marked with the required marking indicated above, or the Regulatory Compliance Mark (RCM) provided that the requirements of all relevant parts of AS/NZS 4417 applicable to the article are fulfilled.

Any modifications to the electrical equipment or its place of manufacture must be approved by Office of the Technical Regulator prior to the equipment being supplied or offered for supply.

Notification must be given to Office of the Technical Regulator of any change to the name or address of the holder of the certificate within 20 business days.

ARTICLE DETAILS

Electrical Equipment:	Level 3 Residual Current Device Schneider iC60N & iC60H series RCBOs
Relevant Standards:	AS/NZS 61009.1: 2015
Expiry Date:	15 August 2022
Conditions of Approval:	

A handwritten signature in blue ink that reads 'George Nasic'.



Certificate Number: OTR170401/00



Approval details

Model	A9D31806, A9D31810, A9D31816, A9D31820, A9D31825, A9D31832, A9D31840, A9D31845
Rated at	Input: 240 Vac, 30mA, 10kA, B-Curve, Type A, 6, 10 16, 20, 25, 32, 40, 45 A, 50/60 Hz
Trade Name	Schneider Electric
Comments	

Model	A9D10806, A9D10810, A9D10816, A9D10820, A9D10825, A9D10832, A9D10840, A9D10845
Rated at	Input: 240 Vac, 10mA, 10kA, C-Curve, Type A, 6, 10 16, 20, 25, 32, 40, 45 A, 50/60 Hz
Trade Name	Schneider Electric
Comments	

Model	A9D11806, A9D11810, A9D11816, A9D11820, A9D11825, A9D11832, A9D11840, A9D11845
Rated at	Input: 240 Vac, 30mA, 10kA, C-Curve, Type A, 6, 10 16, 20, 25, 32, 40, 45 A, 50/60 Hz
Trade Name	Schneider Electric
Comments	

Model	A9D12806, A9D12810, A9D12816, A9D12820, A9D12825, A9D12832, A9D12840, A9D12845
Rated at	Input: 240 Vac, 100mA, 10kA, C-

A handwritten signature in blue ink that reads 'George Nasic'.

Certificate Number: OTR170401/00



	Curve, Type A, 6, 10 16, 20, 25, 32, 40, 45 A, 50/60 Hz
Trade Name	Schneider Electric
Comments	

Model	A9D61806, A9D61810, A9D61816, A9D61820, A9D61825, A9D61832, A9D61840, A9D61845
Rated at	Input: 240 Vac, 30mA, 6 kA, C-Curve, Type A, 6, 10 16, 20, 25, 32, 40, 45 A, 50/60 Hz
Trade Name	Schneider Electric
Comments	

A handwritten signature in blue ink that reads "George Nesic".

