

Certificate Number: AZ 69026459

Page: 0001



CERTIFICATE OF CONFORMITY / APPROVAL

Authorised marking: TUV-026459-EA

TÜV Rheinland Australia Pty Ltd "Electrical Product Safety Certification (EPSC) Scheme", accredited by JAS-ANZ in accordance with ISO/IEC 17065, has issued this certificate under the Queensland Electrical Safety Act / Recognised External Certification Scheme (RECS), and under the NSW Gas and Electricity (Consumer safety) Act / Recognised External Approval Scheme (REAS). The electrical equipment described hereunder has been evaluated and complied with the standard(s) listed below in accordance with the scheme herein at the time of certification. It is a requirement that all equipment supplied under this certificate shall be identical to the equipment as certified. The certificate holder shall use the Regulatory Compliance Mark (RCM) provided all the requirements of AS/NZS 4417.1 & AS/NZS 4417.2 applicable to the article are fulfilled. The certificate holder shall place the above mentioned authorised marking on the product.

CERTIFICATE HOLDER:

Schneider Electric (Australia) Pty. Ltd.
33-37 Port Wakefield Road
Gepps Cross, SA 5094
Australia

DESCRIPTION OF EQUIPMENT

Risk Classification:

In-scope Risk Level 3

Declared class:

RESIDUAL CURRENT DEVICE

Product:

Residual Current Device with Integral Overcurrent Protection

Trade Name / Manufacturer:

Schneider Electric

Model Number:

Vigi iC60 Series

Ratings:

Refer to Appendix sheet 1.0 on page 01 for model and rating details

Remark: Product is suitable for sales in New Zealand.

Standard:

AS/NZS 61009.1:2015+A1:2024

Issue Date:

21/03/2025

Expiry Date:

21/03/2030

Signed for and on behalf of TÜV Rheinland Australia Pty Ltd

A handwritten signature in blue ink, appearing to read 'John Wang'.

John Wang



www.jas-anz.org/register

Appendix

Authorised marking: TUV-026459-EA

Version: 1.0

Issue date: 21-03-2025

Model/ Type reference/Rated Power

Product	Trade Name	Model	Rating
Vigi iC60 RCBO	Schneider Electric	A9V51263	230/240V ac, 50Hz, 63A, 30mA, 2P, Type A
Vigi iC60 RCBO	Schneider Electric	A9V51363	400/415V ac, 50Hz, 63A, 30mA, 3P, Type A
Vigi iC60 RCBO	Schneider Electric	A9V51463	400/415V ac, 50Hz, 63A, 30mA, 4P, Type A
Vigi iC60 RCBO	Schneider Electric	A9V61263	230/240V ac, 50Hz, 63A, 30mA, 2P, Type ASI
Vigi iC60 RCBO	Schneider Electric	A9V61363	400/415V ac, 50Hz, 63A, 30mA, 3P, Type ASI
Vigi iC60 RCBO	Schneider Electric	A9V61463	400/415V ac, 50Hz, 63A, 30mA, 4P, Type ASI
Vigi iC60 RCBO	Schneider Electric	A9V54263	230/240V ac, 50Hz, 63A, 300mA, 2P, Type A
Vigi iC60 RCBO	Schneider Electric	A9V54363	400/415V ac, 50Hz, 63A, 300mA, 3P, Type A
Vigi iC60 RCBO	Schneider Electric	A9V54463	400/415V ac, 50Hz, 63A, 300mA, 4P, Type A
Vigi iC60 RCBO	Schneider Electric	A9V25263	230/240V ac, 50Hz, 63A, 300mA, 2P, Type A-S
Vigi iC60 RCBO	Schneider Electric	A9V25363	400/415V ac, 50Hz, 63A, 300mA, 3P, Type A-S
Vigi iC60 RCBO	Schneider Electric	A9V25463	400/415V ac, 50Hz, 63A, 300mA, 4P, Type A-S
Vigi iC60 RCBO	Schneider Electric	A9V65263	230/240V ac, 50Hz, 63A, 300mA, 2P, Type ASI-S
Vigi iC60 RCBO	Schneider Electric	A9V65363	400/415V ac, 50Hz, 63A, 300mA, 3P, Type ASI-S
Vigi iC60 RCBO	Schneider Electric	A9V65463	400/415V ac, 50Hz, 63A, 300mA, 4P, Type ASI-S
Vigi iC60 RCBO	Schneider Electric	A9V02663	230/240V ac, 50Hz, 63A, 30mA, 1P+N, Type A
Vigi iC60 RCBO	Schneider Electric	A9V02763	400/415V ac, 50Hz, 63A, 30mA, 3P+N, Type A
Vigi iC60 RCBO	Schneider Electric	A9V06663	230/240V ac, 50Hz, 63A, 300mA, 1P+N, Type A
Vigi iC60 RCBO	Schneider Electric	A9V06763	400/415V ac, 50Hz, 63A, 300mA, 3P+N, Type A

Signed for and on behalf of TÜV Rheinland Australia Pty Ltd



John Wang



www.jas-anz.org/register