

Certificate Number: AZ 69026455

Page: 0001



CERTIFICATE OF APPROVAL

Authorised marking: TUV-026455-EA

TÜV Rheinland Australia Pty Ltd "Electrical Product Safety Certification (EPSC) Scheme", accredited by JAS-ANZ in accordance with ISO/IEC 17065, has issued this certificate under the Gas and Electricity (Consumer safety) Act 2017 as a declared Recognised External Approval Scheme (REAS). The electrical equipment described hereunder has been evaluated and found to be electrically safe at the time of certification. It is a requirement that all equipment supplied under this certificate shall be identical to the equipment as certified. The certificate holder shall place the above mentioned authorised marking on the product. The certificate holder may use the Regulatory Compliance Mark (RCM) provided all the requirements of AS/NZS 4417.1 & AS/NZS 4417.2 applicable to the article are fulfilled.

CERTIFICATE HOLDER:

Schneider Electric
(Australia) Pty. Ltd.
33-37 Port Wakefield Road
Gepps Cross SA 5094
Australia

DESCRIPTION OF EQUIPMENT

Declared class:

RESIDUAL CURRENT DEVICE

Product:

Two & Four pole, single & 3 phase RCCB

Trade Name / Manufacturer:

Schneider Electric

Model Number:

A9R series

Ratings:

230/240V~, 50/60Hz, Single Phase,
400/415V~, 50/60Hz, Three Phase, 40, 63, 80 & 100A,
Tripping current: 30mA, 100mA & 300mA, I_{Δm} 1500A, Inc 10kA,
I_{Δc} 10kA, Refer to CONTINUATION SHEET 1 to 2 for models
detail, Remarks: Alternative Authorised Marking: TUV-026440-EA
Is applicable to above mentioned models,
The A9R series are suitable for sale in New Zealand

Standard:

AS/NZS 61008.1:2015+A1

Issue Date:

30/06/2024

Expiry Date:

30/06/2029

Signed for and on behalf of TÜV Rheinland Australia Pty Ltd

A handwritten signature in blue ink, appearing to read 'John Wang'.

John Wang



www.jas-anz.org/register

Certificate Number: AZ 69026455

Page: 0002



CERTIFICATE OF APPROVAL

Authorised marking: TUV-026455-EA

CONTINUATION SHEET 1

DESCRIPTION OF EQUIPMENT

Rating voltage for Single phase: 230/240V~ , 2 Pole:

Schneider Commercial Cat. No./Schneider Generic Designation/
Voltage (V) / Rated Current (A) / Residual Tripping Current
(mA)

A9R51240 / iID 2P 40A 30mA A-type / 230/240V~ / 40 / 30

A9R51263 / iID 2P 63A 30mA A-type / 230/240V~ / 63 / 30

A9R21291 / iID 2P 100A 30mA A-type / 230/240V~ / 100 / 30

A9R91240 / iID 2P 40A 30mA A-SI-type / 230/240V~ / 40 / 30

A9R91263 / iID 2P 63A 30mA A-SI-type / 230/240V~ / 63 / 30

A9R54240 / iID 2P 40A 300mA A-type / 230/240V~ / 40 / 300

A9R54263 / iID 2P 63A 300mA A-type / 230/240V~ / 63 / 300

A9R24291 / iID 2P 100A 300mA A-type / 230/240V~ / 100 / 300

A9R25240 / iID 2P 40A 300mA-S A-type / 230/240V~ / 40 / 300

A9R25263 / iID 2P 63A 300mA-S A-type / 230/240V~ / 63 / 300

A9R25291 / iID 2P 100A 300mA-S A-type / 230/240V~ / 100 / 300

A9R35240 / iID 2P 40A 300mA-S A-SI-type / 230/240V~/ 40 / 300

A9R35263 / iID 2P 63A 300mA-S A-SI-type / 230/240V~/ 63 / 300

A9R35291 / iID 2P 100A 300mA-S A-SI-type / 230/240V~/100/300

Issue Date: 30/06/2024

Expiry Date: 30/06/2029

Signed for and on behalf of TÜV Rheinland Australia Pty Ltd

A handwritten signature in blue ink, appearing to read 'John Wang'.

John Wang



www.jas-anz.org/register

Certificate Number: AZ 69026455

Page: 0003



CERTIFICATE OF APPROVAL

Authorised marking: TUV-026455-EA

CONTINUATION SHEET 2

DESCRIPTION OF EQUIPMENT

A9R22240 / iID 2P 40A 100mA A-type / 230/240V~ / 40 / 100
A9R22263 / iID 2P 63A 100mA A-type / 230/240V~ / 63 / 100
A9R22280 / iID 2P 80A 100mA A-type / 230/240V~ / 80 / 100
A9R22291 / iID 2P 100A 100mA A-type / 230/240V~ / 100 / 100

Rating voltage for Three phase: 400/415V~ , 4 Pole:
Schneider Commercial Cat. No./Schneider Generic Designation/
Voltage (V) / Rated Current (A) / Residual Tripping Current

A9R51440 / iID 4P 40A 30mA A-type / 400/415V~ / 40 / 30
A9R51463 / iID 4P 63A 30mA A-type / 400/415V~ / 63 / 30
A9R21480 / iID 4P 80A 30mA A-type / 400/415V~ / 80 / 30
A9R21491 / iID 4P 100A 30mA A-type / 400/415V~ / 100 / 30
A9R91440 / iID 4P 40A 30mA A-SI-type / 400/415V~ / 40 / 30
A9R91463 / iID 4P 63A 30mA A-SI-type / 400/415V~ / 63 / 30
A9R31480 / iID 4P 80A 30mA A-SI-type / 400/415V~ / 63 / 30
A9R31491 / iID 4P 100A 30mA A-SI-type / 400/415V~ / 100 / 30

Issue Date: 30/06/2024

Expiry Date: 30/06/2029

Signed for and on behalf of TÜV Rheinland Australia Pty Ltd

A handwritten signature in blue ink, appearing to read 'John Wang'.

John Wang



www.jas-anz.org/register