

CERTIFICATE OF APPROVAL

Authorised marking: TUV023019EA

This is to certify that TÜV Rheinland Australia Pty Ltd as accredited by JAS-ANZ in accordance with ISO/IEC Guide 65 has examined for compliance with certification standards, the electrical equipment described hereunder and authorises the certificate holder to affix the above mentioned mark to products of the same type; or the Regulatory Compliance Mark (RCM) provided that the requirements of all relevant parts of AS/NZS 4417 applicable to the article are fulfilled

CERTIFICATE HOLDER: Schneider Electric (Australia) Pty. Ltd.
33-37 Port Wakefield Road
Gepps Cross, SA 5094, Australia

DESCRIPTION OF EQUIPMENT

Declared class: SOCKET-OUTLET

Product: Lifesaver Power Outlet/RCD Protected Socket Outlet

Trade Name / Manufacturer: Clipsal; Medilec.

Model Number: 1) 2025RC; C2025RC; 2) 2025RC10; C2025RC10;
3) ML 2025RC10; ML 2025RC10C.


Ratings: 250V~, 50Hz, 20A, 10mA or 30mA.
Clipsal: 1): Socket: 10A, RCD: 20A, IΔn 30mA, Type A;
Clipsal: 2): Socket: 10A, RCD: 20A, IΔn 10mA, Type I;
Medilec: 3): Socket: 10A, RCD: 20A, IΔn 10mA, Type I.

Standard: AS/NZS 3112:2017
AS/NZS 3190:2016
AS/NZS 3100:2017

Issue Date: 21/09/2018

Expiry Date: 21/09/2023

Signed for and on behalf of TÜV Rheinland Australia Pty Ltd,


Billy Chu



Acc. No. Z2870404AA
www.jas-anz.org/register