

## CERTIFICATE OF APPROVAL

**Authorised marking:** TUV023022EA

*This is to certify that TÜV Rheinland Australia Pty Ltd as accredited by JAS-ANZ in accordance with ISO/IEC Guide 65 has examined for compliance with certification standards, the electrical equipment described hereunder and authorises the certificate holder to affix the above mentioned mark to products of the same type; or the Regulatory Compliance Mark (RCM) provided that the requirements of all relevant parts of AS/NZS 4417 applicable to the article are fulfilled*

**CERTIFICATE HOLDER:** Schneider Electric (Australia) Pty. Ltd.  
33-37 Port Wakefield Road  
Gepps Cross, SA 5094, Australia

### DESCRIPTION OF EQUIPMENT

**Declared class:** RESIDUAL CURRENT DEVICE

**Product:** Lifesaver Safety Switch

**Trade Name / Manufacturer:** Clipsal; Medilec.


**Model Number:**  
1) Clipsal: 2031RC30, 2031VRC30;  
2) Clipsal: 2031RC10, 2031VRC10;  
3) Medilec: ML2031RC10, ML2031VRC10.

**Ratings:** 250V~, 50Hz, 20A, 10mA or 30mA.  
1): 20A, I $\Delta$ n 30mA, Type A;  
2): 20A, I $\Delta$ n 10mA, Type I;  
3): 20A, I $\Delta$ n 10mA, Type I.

**Standard:** AS/NZS 3190:2016  
AS/NZS 3100:2017+A1

**Issue Date:** 21/09/2018  
**Expiry Date:** 21/09/2023

*Signed for and on behalf of TÜV Rheinland Australia Pty Ltd*

  
Billy Chu



Acc. No. Z2870404AA  
[www.jas-anz.org/register](http://www.jas-anz.org/register)