

Certificate Number: AZ 69024131

Page: 0001



CERTIFICATE OF APPROVAL

Authorised marking: TUV024131EA

This is to certify that TÜV Rheinland Australia Pty Ltd as accredited by JAS-ANZ in accordance with ISO/IEC Guide 65 has examined for compliance with certification standards, the electrical equipment described hereunder and authorises the certificate holder to affix the above mentioned mark to products of the same type; or the Regulatory Compliance Mark (RCM) provided that the requirements of all relevant parts of AS/NZS 4417 applicable to the article are fulfilled

CERTIFICATE HOLDER:

Schneider Electric (Australia) Pty. Ltd.
33-37 Port Wakefield Road
Gepps Cross, SA 5094
Australia

DESCRIPTION OF EQUIPMENT

Declared class:

SOCKET-OUTLET

Product:

RCD Protected Twin Switched Socket Outlet

Trade Name / Manufacturer:

Clipsal ; PDL .

Model Number:

P3025RCD10 ; P395RCD10

Ratings:

250V~, 50Hz
Clipsal: P3025RCD10:Socket: 10A, RCD: 20A, I Δ n 10mA, Type I
PDL: P395RCD10:Socket: 10A, RCD: 20A, I Δ n 10mA, Type I

Standard:

AS/NZS 3112:2017
AS/NZS 3190:2016
AS/NZS 3133:2013+A1+A2
AS/NZS 3100:2017+A1

Issue Date:

17/03/2020

Expiry Date:

17/03/2025

Signed for and on behalf of TÜV Rheinland Australia Pty Ltd

A handwritten signature in blue ink, appearing to read 'Grant Li', written over a horizontal line.

Grant Li



Acc. No. Z2870404AA
www.jas-anz.org/register

Certificate Number: AZ 69024131

Page: 0002



CERTIFICATE OF APPROVAL

Authorised marking: TUV024131EA

CONTINUATION SHEET 1

(Modification 1)

Add additional models:

Clipsal : 3025RCD30 : Socket: 250V~, 50Hz, 10A, RCD: 20A,
IΔn 30mA, 3kA, Type II

PDL : 395RCD30 : Socket: 250V ~, 50Hz, 10A, RCD: 20A,
IΔn 30mA, 3kA, Type II

PDL : 391RCD30 : Socket: 250V ~, 50Hz, 10A, RCD: 20A,
IΔn 30mA, 3kA, Type II

Clipsal : P3025RCD30 : Socket: 250V ~, 50Hz, 10A,
RCD: 20A, IΔn 30mA, 3kA, Type II

PDL : P395RCD30 : Socket: 250V ~, 50Hz, 10A, RCD: 20A,
IΔn 30mA, 3kA, Type II

PDL : P391RCD30 : Socket: 250V ~, 50Hz, 10A, RCD: 20A,
IΔn 30mA, 3kA, Type II

- Add alternative plunger for all models 10mA and 30mA.

- Add alternative core of sensing coil for 10mA models.

Test standard update:

From: AS/NZS 3100:2017 + A1

To: AS/NZS 3100:2017 + A1 + A2 + A3

Issue Date: 16/06/2020

Expiry Date: 17/03/2025

Signed for and on behalf of TÜV Rheinland Australia Pty Ltd

A handwritten signature in black ink, appearing to read 'Billy Chu', written over a horizontal line.

Billy Chu



Acc. No. Z2870404AA
www.jas-anz.org/register