

**Certificate Number:** AZ 69024268

Page: 0001



## CERTIFICATE OF APPROVAL

Authorised marking: TUV024268EA

*This is to certify that TÜV Rheinland Australia Pty Ltd as accredited by JAS-ANZ in accordance with ISO/IEC Guide 65 has examined for compliance with certification standards, the electrical equipment described hereunder and authorises the certificate holder to affix the above mentioned mark to products of the same type; or the Regulatory Compliance Mark (RCM) provided that the requirements of all relevant parts of AS/NZS 4417 applicable to the article are fulfilled*

### CERTIFICATE HOLDER:

Schneider Electric  
33-37 Port Wakefield Road  
Gepps Cross SA 5094  
Australia

### DESCRIPTION OF EQUIPMENT

**Declared class:**

RESIDUAL CURRENT DEVICE

**Product:**

Residual Current Device

**Trade Name / Manufacturer:**

Clipsal

**Model Number:**

Model Number details refer to CONTINUATION SHEET 1

**Ratings:**

230-240V a.c., 50Hz, 20A,  
Further Ratings refer to CONTINUATION SHEET 1

**Standard:**

AS/NZS 3190:2016  
AS/NZS 3100:2017+A1+A2+A3

**Issue Date:**

19/05/2020

**Expiry Date:**

19/05/2025

*Signed for and on behalf of TÜV Rheinland Australia Pty Ltd*

A handwritten signature in blue ink, appearing to read 'Billy Chu', written over a horizontal line.

Billy Chu



Acc. No. Z2870404AA  
[www.jas-anz.org/register](http://www.jas-anz.org/register)

**Certificate Number:** AZ 69024268

Page: 0002



## CERTIFICATE OF APPROVAL

Authorised marking: TUV024268EA

CONTINUATION SHEET 1

DESCRIPTION OF EQUIPMENT

Clipsal type 2031RCD10 : 230-240Va.c., 50Hz, 20A,  
IΔn 10mA, 3kA, Type I

Clipsal type 2031VRCD10 : 230-240Va.c., 50Hz, 20A,  
IΔn 10mA, 3kA, Type I

Clipsal type ML2031RCD10 : 230-240Va.c., 50Hz, 20A,  
IΔn 10mA, 3kA, Type I

Clipsal type ML2031VRCD10 : 230-240Va.c., 50Hz, 20A,  
IΔn 10mA, 3kA, Type I

Clipsal type 2031RCD30 : 230-240Va.c., 50Hz, 20A,  
IΔn 30mA, 3kA, Type II

Clipsal type 2031VRCD30 : 230-240Va.c., 50Hz, 20A,  
IΔn 30mA, 3kA, Type II

Issue Date: 19/05/2020

Expiry Date: 19/05/2025

*Signed for and on behalf of TÜV Rheinland Australia Pty Ltd*

A handwritten signature in black ink, appearing to read 'Billy Chu', written over a horizontal line.

Billy Chu



Acc. No. Z2870404AA  
[www.jas-anz.org/register](http://www.jas-anz.org/register)

**Certificate Number:** AZ 69024268

Page: 0003



## CERTIFICATE OF APPROVAL

Authorised marking: TUV024268EA

CONTINUATION SHEET 2

(Modification 1)

- Add alternative plunger for all models 10mA and 30mA.
- Add alternative core of sensing coil for 10mA models.

Issue Date: 16/06/2020

Expiry Date: 19/05/2025

*Signed for and on behalf of TÜV Rheinland Australia Pty Ltd*

  
TÜVRheinland<sup>®</sup>



Billy Chu



Acc. No. Z2870404AA  
[www.jas-anz.org/register](http://www.jas-anz.org/register)