

Certificate Number: AZ 69020890

Page: 0001



CERTIFICATE OF APPROVAL

Authorised marking: TUV020890EA

This is to certify that TÜV Rheinland Australia Pty Ltd as accredited by JAS-ANZ in accordance with ISO/IEC Guide 65 has examined for compliance with certification standards, the electrical equipment described hereunder and authorises the certificate holder to affix the above mentioned mark to products of the same type; or the Regulatory Compliance Mark (RCM) provided that the requirements of all relevant parts of AS/NZS 4417 applicable to the article are fulfilled

CERTIFICATE HOLDER: Schneider Electric (Australia) Pty. Ltd.
33-37 Port Wakefield Road
Gepps Cross, SA 5094, Australia

DESCRIPTION OF EQUIPMENT

Declared class: Residual Current Device

Product: Portable Residual Current Device

Trade Name / Manufacturer: Clipsal; Medilec E.S.P.

Model Number: 485 series
Refer to Continuation Sheet 1-2 for models list in details.

Ratings: Refer to Continuation Sheet 1-2.

Standard: AS/NZS 3190:2011

Issue Date: 06/04/2016

Expiry Date: 06/04/2021

Signed for and on behalf of TÜV Rheinland Australia Pty Ltd

A handwritten signature in blue ink, appearing to be "Brian Wong".

Brian Wong



Acc. No. Z2870404AA
www.jas-anz.org/register

Certificate Number: AZ 69020890

Page: 0002



CERTIFICATE OF APPROVAL

Authorised marking: TUV020890EA

CONTINUATION SHEET 1

Trade name : Clipsal

Model No. : 485P2CB30

Ratings : 240Va.c., 10A, Tripping current: 30mA

RCD Protected, Portable Protected Power Outlets, Twin switched sockets 10A with 30mA electronic RCD/MCB Class PSOA, IP33.

Trade name : Clipsal

Model No. : 485P3CB30

Ratings : 240Va.c., 10A, Tripping current: 30mA

RCD Protected, Portable Protected Power Outlets, Three switched sockets 10A with 30mA electronic RCD/MCB - Fitted with 2 x 10A, 1 x 15A sockets, Class PSOA, IP33.

Trade name : Clipsal

Model No. : 485P4CB10

Ratings : 240Va.c., 10A, Tripping current: 10mA

RCD Protected, Portable Protected Power Outlets, Four switched sockets 10A with 10mA electronic RCD/MCB - Medical Grade 10mA RCD, IP33, Class H.

Issue Date: 06/04/2016

Expiry Date: 06/04/2021

Signed for and on behalf of TÜV Rheinland Australia Pty Ltd


Brian Wong



Acc. No. Z2870404AA
www.jas-anz.org/register

TUV Rheinland Australia Pty Ltd
182 Dougherty Road, Heidelberg West VIC 3081
Phone: +61 (3) 9450 1400
Email: certification@au.tuv.com
Website: www.au.tuv.com

Certificate Number: AZ 69020890

Page: 0003



CERTIFICATE OF APPROVAL

Authorised marking: TUV020890EA

CONTINUATION SHEET 2

Trade name : Clipsal
Model No. : 485P4CB30
Ratings : 240Va.c., 10A, Tripping current: 30mA
RCD Protected, Portable Protected Power Outlets,
Four switched sockets 10A with 30mA electronic RCD/MCB,
Class PSOA, IP33.

Trade name : Clipsal
Model No. : 485P4CB15/30
Ratings : 240Va.c., 15A, Tripping current: 30mA
RCD Protected, Portable Protected Power Outlets,
Four switched sockets 15A with 30mA electronic RCD/MCB
Class PSOA, IP33.

Trade name : Medilec E.S.P.
Model No. : E13
Ratings : 240Va.c., 10A, Tripping current: 10mA
Portable RCD/MCB Protected Power Outlets, 10A, 10mA,
4 Outlet, IP33, Class H.

Issue Date: 06/04/2016

Expiry Date: 06/04/2016

Signed for and on behalf of TÜV Rheinland Australia Pty Ltd

A handwritten signature in blue ink, appearing to be 'Brian Wong', written over a horizontal line.

Brian Wong



Acc. No. Z2870404AA
www.jas-anz.org/register

Certificate Number: AZ 69020890

Page: 0004



CERTIFICATE OF APPROVAL

Authorised marking: TUV020890EA

CONTINUATION SHEET 3

Modification 1

Correction on the Expiry Date of CONTINUATION SHEET 2
due to system printing error.

The Expiry Date on the CONTINUATION SHEET 2 was corrected
as below:

Expiry Date: 06/04/2021

Issue Date: 26/04/2016

Expiry Date: 06/04/2021

Signed for and on behalf of TÜV Rheinland Australia Pty Ltd

A handwritten signature in blue ink, appearing to be 'Brian Wong', written over a horizontal line.

Brian Wong



Acc. No. Z2870404AA
www.jas-anz.org/register

Certificate Number: AZ 69020890

Page: 0005



CERTIFICATE OF APPROVAL

Authorised marking: TUV020890EA

CONTINUATION SHEET 4

(Modification 2)

Add alternative approved slim RCBOs:

RCBO models 4RCBE210/30S, 4RCBE216/30S and 4RCBE210/10S,
are applied to previously approved Clipsal type 485P4CB30,
485P4CB15/30 and Medilec E.S.P type E13 respectively.

Modification of the RCBO compartment on the enclosure to
fit with the slim RCBO.

Issue Date: 19/07/2016

Expiry Date: 06/04/2021

Signed for and on behalf of TÜV Rheinland Australia Pty Ltd

A handwritten signature in blue ink, appearing to read 'Billy Chu', written over a horizontal line.

Billy Chu



Acc. No. Z2870404AA
www.jas-anz.org/register

TUV Rheinland Australia Pty Ltd
182 Dougharty Road, Heidelberg West VIC 3081
Phone: +61 (3) 9450 1400
Email: certification@au.tuv.com
Website: www.au.tuv.com