

IEC**IECEE**

®

™

Ref. Certif. No.

FR_714616/A1**IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME****CB TEST CERTIFICATE**

Product

Circuit-breaker for overcurrent protection for household and similar installations

Name and address of the applicant

SCHNEIDER ELECTRIC INDUSTRIES SAS
31 rue Pierre Mendès France, Eybens
38050 GRENOBLE Cedex 9
FRANCE

Name and address of the manufacturer

SCHNEIDER ELECTRIC INDUSTRIES SAS
31 rue Pierre Mendès France, Eybens
38050 GRENOBLE Cedex 9
FRANCE

Note: When more than one factory, please report on page 2

 Additional Information on page 2

Ratings and principal characteristics

See Annex

Trademark / Brand (if any)



Customer's Testing Facility (CTF) Stage used

CTF2

Model / Type Ref.

Series C120H – 15kA
References : See Annex

Additional information (if necessary may also be reported on page 2)

Supersedes CBTC FR_714616 dated 03/05/2022. Editorial correction, correction of technical characteristics.

 Additional Information on page 2

A sample of the product was tested and found to be in conformity with

IEC 60898-1:2015 +A1:2019

As shown in the Test Report Ref. No. which forms part of this Certificate

22284019-800743B

This CB Test Certificate is issued by the National Certification Body

**LCIE**

LABORATOIRE CENTRAL DES INDUSTRIES ELECTRIQUES - LCIE

33 avenue du Général Leclerc
92260 Fontenay-aux-Roses, FRANCEwww.lcie.fr

Date: 11/06/2024

LABORATOIRE CENTRAL DES
INDUSTRIES ELECTRIQUES
S.A.S au capital de 15.745.984 €
RCS Nanterre B 398 263 174
33 avenue du Général Leclerc
F - 92266 FONTENAY AUX ROSESSignature: 
Julien GAUTHIER
Certification Officer

IEC

IECEE

Ref. Certif. No.

FR_714616/A1

ANNEX

Name and address of the factories:

MERLIN GERIN ALES

16 Boulevard Charles Peguy
30319 ALES CEDEX
FRANCE


SCHNEIDER ELECTRIC Low Voltage Co. Ltd

Teda Mu Ning Road 66, 7th Avenue
300457 TIANJIN
CHINA



LABORATOIRE CENTRAL DES INDUSTRIES ELECTRIQUES - LCIE
33 avenue du Général Leclerc
92260 Fontenay-aux-Roses, FRANCE
www.lcie.fr

Date: 11/06/2024



Signature:  **Julien GAUTHIER**
Certification Officer

ANNEX

References, ratings and main characteristics:

Generic reference	Instantaneous Tripping current	Number of poles	In (A)
C1201P15B010	B	1P	10
C1201P15B016	B	1P	16
C1201P15B020	B	1P	20
C1201P15B025	B	1P	25
C1201P15B032	B	1P	32
C1201P15B040	B	1P	40
C1201P15B050	B	1P	50
C1201P15B063	B	1P	63
C1201P15B080	B	1P	80
C1201P15B100	B	1P	100
C1201P15B125	B	1P	125
C1201P15C010	C	1P	10
C1201P15C016	C	1P	16
C1201P15C020	C	1P	20
C1201P15C025	C	1P	25
C1201P15C032	C	1P	32
C1201P15C040	C	1P	40
C1201P15C050	C	1P	50
C1201P15C063	C	1P	63
C1201P15C080	C	1P	80
C1201P15C100	C	1P	100
C1201P15C125	C	1P	125
C1202P15B010	B	2P	10
C1202P15B016	B	2P	16
C1202P15B020	B	2P	20
C1202P15B025	B	2P	25
C1202P15B032	B	2P	32
C1202P15B040	B	2P	40
C1202P15B050	B	2P	50
C1202P15B063	B	2P	63
C1202P15B080	B	2P	80
C1202P15B100	B	2P	100
C1202P15B125	B	2P	125



LABORATOIRE CENTRAL DES INDUSTRIES ELECTRIQUES - LCIE
 33 avenue du Général Leclerc
 92260 Fontenay-aux-Roses, FRANCE
www.lcie.fr



Signature: **Julien GAUTHIER**
 Certification Officer

Date: 11/06/2024

ANNEX

Generic reference	Instantaneous Tripping current	Number of poles	In (A)
C1202P15C010	C	2P	10
C1202P15C016	C	2P	16
C1202P15C020	C	2P	20
C1202P15C025	C	2P	25
C1202P15C032	C	2P	32
C1202P15C040	C	2P	40
C1202P15C050	C	2P	50
C1202P15C063	C	2P	63
C1202P15C080	C	2P	80
C1202P15C100	C	2P	100
C1202P15C125	C	2P	125
C1203P15B010	B	3P	10
C1203P15B016	B	3P	16
C1203P15B020	B	3P	20
C1203P15B025	B	3P	25
C1203P15B032	B	3P	32
C1203P15B040	B	3P	40
C1203P15B050	B	3P	50
C1203P15B063	B	3P	63
C1203P15B080	B	3P	80
C1203P15B100	B	3P	100
C1203P15B125	B	3P	125
C1203P15C010	C	3P	10
C1203P15C016	C	3P	16
C1203P15C020	C	3P	20
C1203P15C025	C	3P	25
C1203P15C032	C	3P	32
C1203P15C040	C	3P	40
C1203P15C050	C	3P	50
C1203P15C063	C	3P	63
C1203P15C080	C	3P	80
C1203P15C100	C	3P	100
C1203P15C125	C	3P	125



LABORATOIRE CENTRAL DES INDUSTRIES ELECTRIQUES - LCIE
 33 avenue du Général Leclerc
 92260 Fontenay-aux-Roses, FRANCE

www.lcie.fr

Date: 11/06/2024



LABORATOIRE CENTRAL DES
 INDUSTRIES ELECTRIQUES
 S.A.S au capital de 15.745.984 €
 RCS Nanterre B 408 363 174
 33 avenue du Général Leclerc
 F - 92266 FONTENAY AUX ROSES

Signature: *Julien Gauthier*
Julien GAUTHIER
 Certification Officer

ANNEX

Generic reference	Instantaneous Tripping current	Number of poles	In (A)
C1204P15B010	B	4P	10
C1204P15B016	B	4P	16
C1204P15B020	B	4P	20
C1204P15B025	B	4P	25
C1204P15B032	B	4P	32
C1204P15B040	B	4P	40
C1204P15B050	B	4P	50
C1204P15B063	B	4P	63
C1204P15B080	B	4P	80
C1204P15B100	B	4P	100
C1204P15B125	B	4P	125
C1204P15C010	C	4P	10
C1204P15C016	C	4P	16
C1204P15C020	C	4P	20
C1204P15C025	C	4P	25
C1204P15C032	C	4P	32
C1204P15C040	C	4P	40
C1204P15C050	C	4P	50
C1204P15C063	C	4P	63
C1204P15C080	C	4P	80
C1204P15C100	C	4P	100
C1204P15C125	C	4P	125



LABORATOIRE CENTRAL DES INDUSTRIES ELECTRIQUES - LCIE
 33 avenue du Général Leclerc
 92260 Fontenay-aux-Roses, FRANCE
www.lcie.fr

Date: 11/06/2024



LABORATOIRE CENTRAL DES
 INDUSTRIES ELECTRIQUES
 S.A.S au capital de 15.745.984 €
 RCS Nanterre B 408 363 174
 33 avenue du Général Leclerc
 F - 92266 FONTENAY AUX ROSES

Signature:  **Julien GAUTHIER**
 Certification Officer

ANNEX

Technical Characteristics	
Rated operational voltage U_e : (V)	1P :230/400, 240/415 2P, 3P, 4P : 400, 415
Rated current I_n : (A)	see above table
Rated frequency : (Hz)	50/60
Nature of supply :	~
Total number of poles :	see above table
Number of protected poles :	all
Rated insulation voltage U_i : (V)	500
Rated impulse withstand voltage U_{imp} : (V)	4000
Instantaneous tripping current :	see above table
Reference ambient calibration air temperature : (°C)	30
Rated short-circuit capacity I_{cn} : (A)	15000
Rated making and breaking capacity on one pole separately : (A)	15000
Service short-circuit capacity I_{cs} : (A)	7500
Energy limiting class (I^2t) :	1 (10A up to 63A)
Grid distance (short-circuit tests) :	1P : 200 mm 2P, 3P, 4P : 120 mm
Protection against external influences :	enclosed
Protection degree :	IP20
Material group :	II
Method of mounting :	panel board/distribution board, on rail
Method of electrical connection	not associated with the mechanical-mounting
Type of terminals :	pillar terminals
Nominal diameter of thread : (mm)	6,9 mm
Type of metal used for terminals :	Acier / steel
Operating means	Lever Insulating material
Colour	White Bistable locking clip : yellow Protection flap : black



LABORATOIRE CENTRAL DES INDUSTRIES ELECTRIQUES - LCIE
 33 avenue du Général Leclerc
 92260 Fontenay-aux-Roses, FRANCE
www.lcie.fr

Date: 11/06/2024



Signature: **Julien GAUTHIER**
 Certification Officer