


IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT  
(IECEE) CB SCHEME

## CB TEST CERTIFICATE

Product	Circuit-breakers for overcurrent protection for household and similar installations
Name and address of the applicant	SCHNEIDER ELECTRIC INDUSTRIES SAS 31 rue Pierre Mendès France, Eybens F-38050 Grenoble Cedex 9 France
Name and address of the manufacturer	SCHNEIDER ELECTRIC INDUSTRIES SAS 31 rue Pierre Mendès France, Eybens F-38050 Grenoble Cedex 9 France
Name and address of the factory	<input type="checkbox"/> Additional information on page 2 SCHNEIDER ELECTRIC BULGARIA EOOD Plovdiv plant 4202 Radinovo Bulgaria
Ratings and principal characteristics	1P (Ue = 230 V), 1P+N (Ue = 230 V), 2P (Ue = 400 V), 3P (Ue = 400 V), 3P+N (Ue = 400 V) or 4P (Ue = 400 V) – 50-60 Hz Curve C – In = 6, 10, 16, 20, 25 or 32 A – Icn = 6000 A (see also pages 7 and 9 of Test Report No. PB20-0051970-02-00)
Trademark (if any)	 Schneider Electric
Customer's Testing Facility (CTF) Stage used	
Model / Type Ref.	Series Resi9 XP 6000 (see also Additional Sheet and page 9 of Test Report No. PB20-0051970-02-00)
Additional information (if necessary may also be reported on page 2)	<input type="checkbox"/> Additional information on page 2
A sample of the product was tested and found to be in conformity with	IEC 60898-1:2015 National differences: EU Group Differences
As shown in the Test Report Ref. No. which forms part of this Certificate	PB20-0051970-02-00 and from PB20-0051970-02-01 to PB20-0051970-02-18

This CB Test Certificate is issued by the National Certification Body

IMQ S.p.A.  
Via Quintiliano 43, IT-20138 Milano, Italy

**Description of the generic reference of the circuit-breakers  
for overcurrent protection series Resi9 XP 6000**

