

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Uninterruptible power supply

Name and address of the applicant

APC by Schneider Electric
Boston ONE Campus, 800 Federal Street, Andover MA
01810-1067

UNITED STATES OF AMERICA

Name and address of the manufacturer

APC by Schneider Electric
Boston ONE Campus, 800 Federal Street, Andover MA
01810-1067

UNITED STATES OF AMERICA

Name and address of the factory

AMERICAN POWER CONVERSION CORPORATION
(A.P.C.) B.V.

Lot 3, Block 14, Phase III, PEZA, 4106 ROSARIO,

CAVITE

PHILIPPINES

Note: When more than one factory, please report on page 2☐ Additional Information on page 2

Ratings and principal characteristics

Input: AC 220-240 V, 50-60 Hz, 30 A

Output: AC 220-240 V, 50/60 Hz, 22 A, 5000 VA/4000 W

Trademark (if any)



Customer's Testing Facility (CTF) Stage used

Model / Type Ref.

SUA5000RMI5U

Additional information (if necessary may also be reported on page 2)

☐ Additional Information on page 2

A sample of the product was tested and found to be in conformity with

IEC 62040-1:2017

IEC 62040-1:2017/AMD1:2021

As shown in the Test Report Ref. No. which forms part of this Certificate

290799-TL4-1

This CB Test Certificate is issued by the National Certification Body

VDE Prüf- und Zertifizierungsinstitut GmbH
VDE Testing and Certification Institute
Zertifizierungsstelle und internat. Angelegenheiten
Certification Body and internat. Affairs



J. Richter

Date: 2021-12-15

Signature: